

Federal Energy Act Report

October 1, 2018 thru September 30, 2019

(Public Record Posted Date: November 26, 2019)

General Information:

Total Number of Active UST Facilities: **6,325**
 Total Number of Active USTs: **17,792**

Summary Information For On-Site Inspections:

Number of UST Facilities Inspected: **1,728**
 Inspection Period Dates: **April 1, 2019 to September 30, 2019**
 Percent Compliance (Technical Compliance Rate Measure): **23%**

Note:

Facility and tank information is based on onsite inspections of all active federally regulated UST facilities and covers all federally regulated active tanks at those facilities. Active regulated Illinois UST facilities are inspected on a two year cycle. Onsite inspections measure compliance against Illinois UST requirements at 41 Illinois Administrative Code Parts 174, 175, 176 & 177 and federal UST regulations at 40 CFR Part 280.

Summary Information For Releases:

Number of Confirmed UST Releases: **396**

Sources and Causes of Environmental Releases from Underground Storage Tanks in Illinois

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%	
Tank	296	74.8	0	0.00	9	2.21	5	1.33	105	26.55	0	0.00	0	0.00	177	44.69
Piping	49	12.4	0	0.00	0	0.00	0	0.00	14	3.54	0	0.00	0	0.00	35	8.85
Dispenser	4	0.9	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	4	0.88
Submersible (STP)	0	0.0	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
Delivery Problem	4	0.0	0	0.00	4	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
Unknown	44	11.1	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	44	11.06
Other	0	0.0	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
Totals	397	100.0	0	0.00	13	3.09	5	1.33	119	30.09	0	0.00	0	0.00	260	65.48

(source of data: Illinois Environmental Protection Agency)

To view site specific information at the Office of the State Fire Marshal, please visit: <http://webapps.sfm.illinois.gov/ustsearch/>

To view the LUST Incident Tracking Database, please visit: <http://epadata.epa.state.il.us/land/ust/Search.asp>