

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Asset: P.S. 24 - BROOKLYN, 427 38TH STREET, New York, 11232

Inspection Id	Inspection Type	Time In	Last Edited
ME : K024	Mechanical	2024-01-03 7:52 AM	2024-01-12 8:50 AM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	2
Total capacity of all above ground tanks in gal.	10,275
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Fan Rooms 501, 502, 503
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Basement Corridor
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Refrigerant Leak Detection System; Gas Fired Domestic Water Heater; Domestic Hot Water Remote Storage Tanks
	Years: 2022
	Systems: CO/Gas Leak Detection
	Years: 2021
	Systems: Kitchen - Hot Water Temperature Booster
	Years: 2019
	Systems: Climate Control System - Air Compressor; Fixtures - Toilets, Urinals; Electric Domestic Water Heater in Kitchen
	Years: 2018
	Systems: Enclosed IDF Room 323 - Dedicated A/C Equipment (DX Split System); Climate Control System - BMS
	Years: 2016

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
Yes	Defective Boiler Safety Auxiliary	Leaky Boiler Safety Valves	HEATING PLANT Boiler Auxiliaries Boiler Safety Valve	Boiler Room / Boiler #1	Richard Afflitto	Fireman	Sent to DSF	

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Inspected
Absorption Chiller	Does not Exist
Air Cooled Chiller	Inspected
Instance	Fan Room 503
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-22
Instance Manufacturer	McQuay

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
AIR CONDITIONING	
Chilled Water System	
Air Cooled Chiller	
Equipment	CH-1
Capacity/Size Quantity	180
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Fan Room 503
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-22
Instance Manufacturer	McQuay
Equipment	CH-2
Capacity/Size Quantity	180
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Air Cooled Condenser	Inspected
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	C-1
Capacity/Size Quantity	90
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	C-2
Capacity/Size Quantity	90
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
AIR CONDITIONING	
Chilled Water System	
Air Cooled Condenser	
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	C-3
Capacity/Size Quantity	90
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	C-4
Capacity/Size Quantity	90
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Chilled Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Backflow Preventer	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Central Station Air Handler	Inspected
Instance	Fan Room 501
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	AHU-2
Capacity/Size Quantity	9,600
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Fan Room 501
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
AIR CONDITIONING	
Chilled Water System	
Central Station Air Handler	
Instance Manufacturer	McQuay
Equipment	AHU-3
Capacity/Size Quantity	8,000
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Fan Room 501
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	AHU-5
Capacity/Size Quantity	7,000
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Fan Room 502
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	AHU-1
Capacity/Size Quantity	7,000
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Fan Room 502
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	AHU-4
Capacity/Size Quantity	4,300
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Fan Room 502
Instance Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
AIR CONDITIONING	
Chilled Water System	
Central Station Air Handler	
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	AHU-6
Capacity/Size Quantity	5,000
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fan Coil Unit	Does not Exist
Packaged Air Cooled Chiller	Does not Exist
Water Cooled Chiller	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Outdoor Unit	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	
Condition	1 - Good
Deficiency	No deficiencies recorded
Refrigerant Piping	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Return Fan	
Condition	3 - Fair
Deficiency	No deficiencies recorded
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	
BMS	Inspected
Instance	Throughout
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Installation Year	2016
Source of Installation	Documented
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
CLIMATE CONTROL SYSTEM	Inspected
Pneumatic System	Does not Exist
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Inspected
Dumbwaiter	Does not Exist
Elevator	Inspected
Are all the existing elevators operable?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Does not Exist
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pump
Equipment	N/A
Capacity/Size Quantity	3
Capacity/Size UOM	Total # Pumps
Capacity/Size2 Quantity	7
Capacity/Size2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Hydraulic/Pneumatic Booster System	Does not Exist
Water Service	Inspected
Instance	Room 001 (RPZ in Room 101)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Room 001
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Room 020 (RPZ in Room 222 Closet)

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	RayPak
Equipment	N/A
Capacity/Size Quantity	1,223
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	0
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2022
Source of Installation	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Inspected
Dual Temperature Distribution: Piping, Pumps and	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	
Dual Temperature Distribution: Piping, Pumps and	Inspected
Deficiency	No deficiencies recorded
Dual Temperature Terminal Fan Coil Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
GAS SERVICE	
CO/Gas Leak Detection	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2021
Source of Installation	Documented
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Inspected
Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Backflow Preventer	Does not Exist
Hot Water Heat Exchanger	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Does not Exist
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
HEATING PLANT	Inspected
Replacement Quantity	8,598
Replacement Uom	MBH Net
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
HEATING PLANT	
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Gordon-Piatt
Burner Model Number	FL12.1 GO-50
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Does not Exist
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room / Boiler #1
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
HEATING PLANT	
Boiler System	
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	4,299
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	Yes
Instance Manufacturer	Burnham
Equipment	108963-01
Capacity/Size Quantity	5,537
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	4,299
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	Yes
Instance Manufacturer	Burnham
Equipment	108963-02
Capacity/Size Quantity	5,537
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
HEATING PLANT	Inspected
Fuel System	
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	Inspected
Instance on Room 323	Inspected
Instance on Room 452	Inspected
Instance on Rooms 155, 252	Inspected
Dedicated A/C Equipment	Inspected
Instance on Rooms 155, 252	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Rooms 155, 252
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Room 452	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Room 452 (No power)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Room 323	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
KITCHEN	Inspected
Instance on 1st Floor	Inspected
CO Detector	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas System	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Grease Trap	Inspected
Instance on 1st Floor	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/CLOGGED

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
KITCHEN	
Grease Trap	
Deficiency Location/Instance	Basement Pipe Space Room - Cracked (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hood	
	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	
	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	
	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hot Water Temperature Booster	
	Inspected
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Kitchen Sink	
	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	
	Inspected
Instance on Room 453	Inspected
Dedicated A/C Equipment	
	Inspected
Instance on Room 453	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	
	Inspected
Instance on Room 315	Inspected
Alternative use	Yes
Acid Waste Neutralizing Tank	
	Inspected
Instance on Room 315	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CO Detector	
	Not Required
Instance on Room 315	Not Required
Emergency Shower	
	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
SCIENCE DEMO ROOM	
Emergency Shower	Does not Exist
Instance on Room 315	Does not Exist
Eye Wash	Inspected
Instance on Room 315	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Does not Exist
Instance on Room 315	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Room 315	Does not Exist
Fixed Laboratory Hood	Does not Exist
Instance on Room 315	Does not Exist
Laboratory Sink	Inspected
Instance on Room 315	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 315	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Inspected
Instance on Room 319	Inspected
Alternative use	Yes
Acid Waste Neutralizing Tank	Inspected
Instance on Room 319	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CO Detector	Not Required
Instance on Room 319	Not Required
Emergency Shower	Does not Exist
Instance on Room 319	Does not Exist
Eye Wash	Inspected
Instance on Room 319	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Does not Exist
Instance on Room 319	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Room 319	Does not Exist
Fixed Laboratory Hood	Does not Exist
Instance on Room 319	Does not Exist
Laboratory Sink	Inspected
Instance on Room 319	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 319	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K024

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Wet Sprinkler Alarm Valve Assembly	Does not Exist
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Basement Corridor
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Standpipe System	Inspected
Hose Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	No deficiencies recorded
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist