

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Asset: P.S. 25 - BROOKLYN, 787 LAFAYETTE AVENUE, New York, 11221

Inspection Id	Inspection Type	Time In	Last Edited
ME : K025	Mechanical	2023-12-20 7:02 AM	2023-12-29 11:48 AM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	10,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	Basement MER, Gymnasium MER, MERs 201, 219, 226, 301, 319, Fan Rooms 320, 321
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Climate Control System - Pneumatic System: Refrigerated Air Dryers, F&T/Steam Drip Traps, Terminal Unit Thermostatic Traps
	Years: 2023
	Systems: Fixtures - Student: Lavatory/Sinks (23%), Toilets (21%), Urinals (23%)
	Years: 2022
	Systems: Climate Control System - Electric System (Heat Timer)
	Years: 2021
	Systems: Fixtures - Student: Lavatory/Sinks (20%), Toilets (20%)
	Years: 2016
	Systems: Fixtures - Student: Lavatory/Sinks (48%), Toilets (44%), Urinals (77%); MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2013

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
Yes	Defective Boiler Safety Auxiliary	Water Column Assembly - Water level sight glass is leaking	HEATING PLANT Boiler System Steam Boiler	Boiler Room (Boiler #1)	Timothy Morgan	Custodian	Sent to DSF	

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	41-60%

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
CLIMATE CONTROL SYSTEM	
Pneumatic System	
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Various locations
Deficiency Quantity	40
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hybrid System	Does not Exist
Electric System	Inspected
Instance	Throughout (Heat Timer)
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Cafeteria Storage Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: DEFECTIVE VALVE
Deficiency Location/Instance	Cafeteria Storage Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Cafeteria Storage Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	PVI
Equipment	Hot Water Heater
Capacity/Size Quantity	399
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	400
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2003
Source of Installation	Documented
Deficiency	DEFECTIVE CONTROLS
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE BURNER
Deficiency Location/Instance	Boiler Room (Rusty)
Deficiency Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Gas Fired Domestic Water Heater	
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Oil Fired Domestic Water Heater	
	Does not Exist
Domestic Water Distribution Piping	
	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room (adjacent to the Water Main, above the Storage Room)
Deficiency Quantity	40
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room - (leak on the Gas Fired Domestic Water Heater), (above the Storage Room, Rusty)
Deficiency Quantity	40
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DRAIN/WASTE/VENT AND STORM SYSTEM	
	Inspected
Interior Storm Piping	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	
	Inspected
Condition	3 - Fair
Deficiency	SEWAGE/WASTE PIPING: CLOGGED
Deficiency Location/Instance	Basement (water flow back during heavy rains through the floor drains)
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	SEWAGE/WASTE PIPING: DEFECTIVE/LEAKS
Deficiency Location/Instance	Basement MER (Rusty)
Deficiency Quantity	50

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Sewage/Waste/Vent Piping	
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Women Toilet Room 127, Men Toilet Room 133A
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Inspected
Instance on 1st Floor	Inaccessible
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2 - Between Good and Fair

**NYC Department of Education
Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K025

Question	Response
FIXTURES	
Student	
Toilet	
Deficiency	DEFECTIVE FLUSHOMETER VALVE
Deficiency Location/Instance	3rd Floor Girls Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Urinal	
Condition	Inspected
Deficiency	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	
Does not Exist	
GAS SERVICE	
Inspected	
Gas Distribution Piping	
Inspected	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	
Inspected	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	
Inspected	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	
Does not Exist	
CO/Gas Leak Detection	
Inspected	
Instance	Boiler Room, Gas Meter Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2003
Source of Installation	Documented
Deficiency	No deficiencies recorded
HEATING	
Inspected	
Heating Coil In Ductwork	
Inspected	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	
Does not Exist	
Radiator/Convactor/Fin Tube	
Inspected	
Condition	3 - Fair
Deficiency	AUXILIARY (VALVE,VENT): DEFECTIVE
Deficiency Location/Instance	MER 201
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
HEATING	
Radiator/Convactor/Fin Tube	Inspected
Violations	No violations recorded.
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement MER (Auditorium BL.)
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	MERs 201, MER 301 (leak)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Basement MER (adjacent to the Play Room Exh. Fan), Gymnasium MER (Gym. Bl.), MER 201 (House 1st Floor Blower), MER 320 (House 3rd F BL)
Deficiency Quantity	50
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement MER, Boiler Room
Deficiency Quantity	50
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
HEATING	
Steam Heating	Inspected
Steam Condensate Return Piping	
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room (adjacent to the Steam Condensate Return Pumping System, adjacent to the Boiler Feedwater Tank)
Deficiency Quantity	40
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Condensate Return Pumping System	
	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room (Flexible hose, leak)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE PUMP
Deficiency Location/Instance	Boiler Room (leak)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE TANK
Deficiency Location/Instance	Boiler Room (Rusty, leak)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Piping	
	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	MER 226, Library Room 230/232
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
HEATING	
Steam Heating	
Steam Piping	Inspected
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Terminal Unit Thermostatic Trap	
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Basement MER (Play Room BL.), MERs 219, 226, 301, Rooms 115, 117 and other rooms (leak)
Deficiency Quantity	50
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Stair A/1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
HEATING PLANT	
Replacement Quantity	12,996
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2(B10)
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	No
Burner Exists?	Yes
Burner Manufacturer	John Zink Company, LLC (Gordon-Piatt)
Burner Model Number	F14-G0-50
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Auxiliary Piping	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE BLOWDOWN PIPING
Deficiency Location/Instance	Boiler Room (Boiler #1, leak)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE RPZ
Deficiency Location/Instance	Boiler Room (minor leak)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
HEATING PLANT	
Boiler Auxiliaries	Inspected
Boiler Safety Valve	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler System	Inspected
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,498
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	27704-01
Capacity/Size Quantity	6,498
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2003
Source of Installation	Documented
Deficiency	DEFECTIVE SAFETY AUXILIARY: LOW-WATER CUT-OFF, WATER COLUMN ASSEMBLY
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	20
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,498
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
HEATING PLANT	
Boiler System	Inspected
Steam Boiler	
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	27704-02
Capacity/Size Quantity	6,498
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2003
Source of Installation	Documented
Deficiency	DEFECTIVE AUXILIARY (GAUGES, GASKETS ETC.)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE ACTUATOR
Deficiency Location/Instance	Boiler Room (Boilers #1, #2)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DUAL FUEL (OIL/GAS) BURNER: DEFECTIVE
Deficiency Location/Instance	Boiler Room (Boiler #2, leak)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	FUEL OIL PIPING: DEFECTIVE/LEAKS

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
HEATING PLANT	
Fuel System	
Fuel Oil Storage/Supply System	
Deficiency Location/Instance	Boiler Room (adjacent to Boilers #1, #2 Burners)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	
Does not Exist	
KITCHEN	
Inspected	
Instance on Basement	Inspected
CO Detector	
Not Required	
Instance on Basement	Not Required
Gas System	
Does not Exist	
Instance on Basement	Does not Exist
Grease Trap	
Inspected	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood	
Inspected	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Inspected	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	
Does not Exist	
Instance on Basement	Does not Exist
Hood Fire Suppression System	
Does not Exist	
Instance on Basement	Does not Exist
Hot Water Temperature Booster	
Does not Exist	
Instance on Basement	Does not Exist
Kitchen Sink	
Inspected	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	MISSING AIR GAP
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 4

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
KITCHEN	Inspected
Kitchen Sink	
Deficiency Photo1	No photo recorded
Violations	SF33002
MDF Room	Inspected
Instance on Room 221A	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 221A	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Does not Exist
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Does not Exist
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	Yes
Condition	3 - Fair
Deficiency	DAMAGED FLEXIBLE CONNECTION
Deficiency Location/Instance	Basement MER (Play Room BL. & Exhaust, Auditorium EX.), Gymnasium MER (2 Gym. Exh), MER 201 (House 1st Floor Blower), MER 301 (House Blower), Fan Rooms 320 (House Exh.)
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K025

Question	Response
VENTILATION	
Metal Ductwork	Inspected
Violations	No violations recorded.
Supply Fan	Inspected
Approximate Total # of Fans	6-10
Condition	3 - Fair
Deficiency	No deficiencies recorded
Unit Ventilator	Does not Exist