

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Asset: P.S. 48 - BROOKLYN, 6015 18 AVENUE, New York, 11205

Inspection Id	Inspection Type	Time In	Last Edited
ME : K048	Mechanical	2024-04-04 8:29 AM	2024-04-23 4:59 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	5,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Basement MER, MERs 108, 111
Are there any spaces with Missing or Defective CO Detectors?	Yes
Location(s)	Kitchen
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	MER 111
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Steam Condensate Return Pumping System (1 of 2); Fixtures - Student: Toilets (40%), Urinals (30%); Fixtures - Staff And Other: Toilets
	Years: 2022
	Systems: Gas Fired Domestic Water Heater
	Years: 2020
	Systems: Climate Control System - BMS; F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps; Unit Heater/Cabinet Heaters (17 of 20); MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2018
	Systems: Water Service (1 of 3)
	Years: 2017
	Systems: Fixtures - Student: Toilets (60%) Urinals (30%)
	Years: 2015
	Systems: Fixtures - Student: Urinals (40%); CO/Gas Leak Detection; Kitchen - Grease Trap
	Years: 2013

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No	Defective Boiler Safety Auxiliary	Leaking Boiler Safety Valve	HEATING PLANT Boiler Auxiliaries Boiler Safety Valve	Boiler Room / Boiler #1 (1 of 4)	Gerard Mosquera	Cleaner	Sent to DSF	
Yes	Defective Sprinkler/Stand pipe System	Painted Sprinkler Heads	SPRINKLERS, STANDPIPE, FIRE SYSTEM Sprinkler Head	Rooms 104, 108	Ralph DelGrosso	Custodian	Sent to DSF	

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
CLIMATE CONTROL SYSTEM	
BMS	Inspected
Instance	Throughout except Auditorium
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	0-20%
Installation Year	2018
Source of Installation	Inspector Estimate
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Rooms 310, 410
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE SYSTEM
Deficiency Location/Instance	Throughout except Auditorium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Pneumatic System	Inspected
Instance	Auditorium
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	0-20%
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Auditorium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	MER 108
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	MER 108
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Room 101
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Room 101
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Room 104
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Room 104
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	A.O. Smith
Equipment	N/A
Capacity/Size Quantity	199
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	81
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2020
Source of Installation	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boys Toilet Room 550
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	Boys Toilet Room 550
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boys Toilet Rooms 257, 550, Girls Toilet Room 457, and other locations.
Deficiency Quantity	200
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Boys Toilet Room 257, 4th Floor - Hallway near Room 410, Girls Toilet Room 457
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	2 - Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
FIXTURES	Inspected
Student	Inspected
Urinal	
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2013
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	AUXILIARY (VALVE, VENT): DEFECTIVE
Deficiency Location/Instance	Staff Toilet Room in Room 257/258 (Principal's Office)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Boiler Room, Cafeteria, Multipurpose Room, MERs 108, 111, and other locations
Deficiency Quantity	25
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
HEATING	
Steam Heating	
F&T/Steam Drip Trap	Inspected
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
MER Steam and Condensate Piping	
Condition	Inspected
Condition	2 - Between Good and Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MERs 108, 111
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Condensate Return Piping	
Condition	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Kitchen, 1st Floor Hallway near Kitchen, Rooms 101, 508, and other locations.
Deficiency Quantity	150
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Condensate Return Pumping System	
Condition	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE PUMP
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Piping	
Condition	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	1st Floor Hallway near Girls Toilet Room 105
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
HEATING	
Steam Heating	
Steam Piping	
Violations	No violations recorded.
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Kitchen, 1st Floor Hallway near Kitchen, Rooms 101, 508, and other locations.
Deficiency Quantity	150
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	Multipurpose Room, Girls Toilet Room 105, Room 309
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Terminal Unit Thermostatic Trap	Inspected
Condition	5 - Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Throughout
Deficiency Quantity	150
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
HEATING PLANT	
Replacement Quantity	6,496
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	Yes
Burner Exists?	Yes
Burner Manufacturer	Gordon-Piatt
Burner Model Number	F12.9-GO-30
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE BLOWDOWN PIPING
Deficiency Location/Instance	Boiler Room / Boiler #1, Boiler #2
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room / Boiler #1 (1 of 4)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
HEATING PLANT	
Boiler System	Inspected
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	3,248
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	8410-1
Capacity/Size Quantity	3,248
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	3,248
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	8410-2
Capacity/Size Quantity	3,248
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2000
Source of Installation	Documented
Deficiency	DAMAGED CASING
Deficiency Quantity	20
Quantity Uom	S.F.
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
HEATING PLANT	
Fuel System	
Boiler Fresh Air Louver/Damper	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE ACTUATOR
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	
Instance on Room 353	Inspected
Dedicated A/C Equipment	
Instance on Room 353	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 353
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/MISSING
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
KITCHEN	
CO Detector	
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Gas System	
Instance on 1st Floor	Does not Exist
Grease Trap	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood	
Instance on 1st Floor	Does not Exist
Hood Exhaust Ductwork	
Instance on 1st Floor	Does not Exist
Hood Exhaust Fan	
Instance on 1st Floor	Does not Exist
Hood Fire Suppression System	
Instance on 1st Floor	Does not Exist
Hot Water Temperature Booster	
Instance on 1st Floor	Does not Exist
Kitchen Sink	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	
Instance on Room B6	Inspected
Dedicated A/C Equipment	
Instance on Room B6	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	
SCIENCE LAB	
SCIENCE PREP ROOM	
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Dry Sprinkler Alarm Valve Assembly	
Wet Sprinkler Alarm Valve Assembly	
Fire Booster Pump Assembly	
Roof Tank	
Siamese Connection	
Sprinkler Head	
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	MER 111
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K048

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Sprinkler Head	
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Rooms 104, 108
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	
Does not Exist	
VENTILATION	
Inspected	
Is the building mechanically ventilated?	Partial
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	DEFECTIVE REGISTER/DIFFUSER
Deficiency Location/Instance	Boys Toilet Rooms 257, 550
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	Inspected
Approximate Total # of Fans	1-5
Condition	3 - Fair
Deficiency	No deficiencies recorded
Unit Ventilator	Does not Exist