

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K105

Asset: P.S. 105 - BROOKLYN, 1031 59 STREET, New York, 11219

Inspection Id	Inspection Type	Time In	Last Edited
ME : K105	Mechanical	2023-10-26 8:02 AM	2024-05-10 1:45 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	10,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Boiler Room MER, Boiler Room Fan Room, 5th Floor Gymnasium Fan Room
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Fixtures - Student: Toilets (30%), Lavatory/Sinks (40%)
	Years: 2022
	Systems: F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps; Boiler Emergency Stop Switches
	Years: 2019
	Systems: Gas Fired Domestic Water Heater; CO/Gas Leak Detection
	Years: 2018
	Systems: Fixtures - Student: Toilets (70%), Urinals, Lavatory/Sinks (50%); Fixtures - Staff And Other: Lavatory/Sinks (60%), Toilets (80%), Urinals; Sprinkler Heads
	Years: 2017
	Systems: DX Split System for Telecom Room 214A; MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2014

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K105

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	
Does not Exist	
CLIMATE CONTROL SYSTEM	
Inspected	
BMS	
Does not Exist	
Pneumatic System	
Inspected	
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	3rd Floor Gymnasium, Room 558 and other locations
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE TERMINAL UNIT CONTROL VALVE
Deficiency Location/Instance	5th Floor Gymnasium
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hybrid System	
Does not Exist	
Electric System	
Does not Exist	
COMPACTOR	
Does not Exist	
CONVEYING	
Does not Exist	
DOMESTIC WATER SYSTEM	
Inspected	
Domestic Cold Water System	
Inspected	
Gravity System	
Does not Exist	
Pressure Booster System	
Inspected	
Electric Pressure Booster System	
Inspected	
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K105

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Pressure Booster System	
Electric Pressure Booster System	
Instance Manufacturer	Federal Pump
Equipment	N/A
Capacity/Size Quantity	3
Capacity/Size UOM	Total # Pumps
Capacity/Size2 Quantity	8
Capacity/Size2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
Hydraulic/Pneumatic Booster System	Does not Exist
Water Service	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Boiler Room MER Crawlspace
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	PVI
Equipment	N/A
Capacity/Size Quantity	399
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	215
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2018
Source of Installation	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K105

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Water Distribution Piping	
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room, Boiler Room MER
Deficiency Quantity	100
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DRAIN/WASTE/VENT AND STORM SYSTEM	
	Inspected
Interior Storm Piping	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	
	Does not Exist
Sump Pump	
	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Boiler Room near Ash Hoist (1 of 3)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	
	Does not Exist
FIXTURES	
	Inspected
Staff And Other	
	Inspected
Janitor Sink	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	
	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Toilet	
	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Urinal	
	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Student	
	Inspected
Drinking Fountain	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K105

Question	Response
FIXTURES	
Student	
Lavatory/Sink	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Locker Room Shower	Inspected
Instance on 3rd Floor	Inspected
Instance Condition	3 - Fair
Alternative use	Yes
Deficiency	No deficiencies recorded
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2018
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	AUXILIARY (VALVE, VENT): DEFECTIVE
Deficiency Location/Instance	Main Entrance Lobby, Room 175, Stair A/2
Deficiency Quantity	4
Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K105

Question	Response
HEATING	
Radiator/Convactor/Fin Tube	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	RADIATOR/CONVECTOR: DAMAGED GUARD/SHIELD
Deficiency Location/Instance	Girls Toilet Room 357
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	RADIATOR/CONVECTOR: MISSING GUARD/SHIELD
Deficiency Location/Instance	Cafeteria, Room 359
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K105

Question	Response
HEATING	
Steam Heating	Inspected
Terminal Unit Thermostatic Trap	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
HEATING PLANT	
Replacement Quantity	15,594
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2(B10)
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	No
Burner Exists?	Yes
Burner Manufacturer	Gordon Piatt
Burner Model Number	F16-GO-75
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	5 - Poor
Deficiency	DEFECTIVE RPZ
Deficiency Location/Instance	Boiler Room (mayor leak)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K105

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Make-up Water Backflow Preventer	
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler System	Inspected
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	7,797
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	7888-01
Capacity/Size Quantity	7,797
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2000
Source of Installation	Documented
Deficiency	DEFECTIVE AUXILIARY (GAUGES, GASKETS ETC.)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	7,797
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K105

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Equipment	7888-02
Capacity/Size Quantity	7,797
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2000
Source of Installation	Documented
Deficiency	DEFECTIVE AUXILIARY (GAUGES, GASKETS ETC.)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	BURNER CONTROL PANEL: MISSING BOILER MAKE-UP AIR INTERLOCK
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 4
Deficiency Photo1	No photo recorded
Violations	39067816M
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	
Instance on Rooms 261, 457	Inspected
Dedicated A/C Equipment	
Instance on Rooms 261, 457	Inspected
Condition	4 - Between Fair and Poor

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K105

Question	Response
Enclosed IDF Room	
Dedicated A/C Equipment	
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Rooms 261, 457
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
KITCHEN	Inspected
Instance on 1st Floor	Inspected
CO Detector	Not Required
Instance on 1st Floor	Not Required
Gas System	Does not Exist
Instance on 1st Floor	Does not Exist
Grease Trap	Inspected
Instance on 1st Floor	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/CLOGGED
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hood	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Exhaust Ductwork	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Fire Suppression System	Does not Exist
Instance on 1st Floor	Does not Exist
Hot Water Temperature Booster	Does not Exist
Instance on 1st Floor	Does not Exist
Kitchen Sink	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room 453	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 453	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K105

Question	Response
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Does not Exist
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Does not Exist
Sprinkler Head	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Partial
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Supply Fan	Inspected
Approximate Total # of Fans	1-5
Condition	3 - Fair
Deficiency	No deficiencies recorded
Unit Ventilator	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Room 111, 5th Floor Gymnasium (electrical issues)
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.