

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Asset: P.S. 120 - BROOKLYN, 18 BEAVER STREET, New York, 11206

Inspection Id	Inspection Type	Time In	Last Edited
ME : K120	Mechanical	2024-02-21 8:44 AM	2024-04-12 6:03 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Boiler Room Fan Room, MER 132, Kitchen Crawlspace - Steam Condensate Return Pumping System Room
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Rooms 101, 119, Gymnasium Office, Kitchen Storage Room, Lamp Storage Room, Paint Storage Room
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: F&T/Steam Drip Traps (80%); MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2021
	Systems: CO/Gas Leak Detection
	Years: 2019
	Systems: Terminal Unit Thermostatic Traps (50%)
	Years: 2018
	Systems: Fixtures - Student: Toilets (50%), Urinals (50%); Kitchen - Grease Trap (1 of 2)
	Years: 2017
	Systems: Gas Fired Domestic Water Heater; Domestic Hot Water Remote Storage Tanks; Kitchen - Hot Water Temperature Booster
	Years: 2016

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	Photo/Image
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE PNEUMATIC PRV STATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Question	Response
CLIMATE CONTROL SYSTEM	
Pneumatic System	
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	PNEUMATIC TUBING:DEFECTIVE/LEAKS AIR
Deficiency Location/Instance	Room 105, 200, 238, 248, 354
Deficiency Quantity	50
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pump
Equipment	N/A
Capacity/Size Quantity	2
Capacity/Size UOM	Total # Pumps
Capacity/Size2 Quantity	15
Capacity/Size2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2008
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Hydraulic/Pneumatic Booster System	Does not Exist
Water Service	Inspected
Instance	Room B33
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Room B33
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room (Domestic)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Boiler Room (Domestic)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room (Sprinkler)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Boiler Room (Sprinkler)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Lochinvar
Equipment	N/A

**NYC Department of Education
Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K120

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Gas Fired Domestic Water Heater	
Capacity/Size Quantity	399
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	0
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2016
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	SEWAGE/WASTE PIPING: CLOGGED
Deficiency Location/Instance	Basement (backs up during heavy rain fall)
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Mens Toilet Room B34
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Question	Response
FIXTURES	
Staff And Other	
Lavatory/Sink	Inspected
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2019
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Question	Response
HEATING	
Heating Coil In Ductwork	
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	MER 132/ Auditorium BL L-1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	AUXILIARY (VALVE, VENT): DEFECTIVE
Deficiency Location/Instance	Nurse's office Room 146
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE TANK
Deficiency Location/Instance	Boiler Room (1 of 2, Leaks)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE PUMP
Deficiency Location/Instance	Boiler Room (Leaks)
Deficiency Quantity	1
Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Question	Response
HEATING	
Steam Heating	
Steam Condensate Return Pumping System	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Piping	
Condition	Inspected
Deficiency	3 - Fair
Terminal Unit Thermostatic Trap	
Condition	Inspected
Deficiency	2 - Between Good and Fair
Steam supplied by External Sources	
Condition	Does not Exist
Unit Heater/Cabinet Heater	
Condition	Inspected
Deficiency	2 - Between Good and Fair
HEATING PLANT	
Replacement Quantity	Inspected
Replacement Uom	10,322
Instance on Basement	MBH Net
Burner Type	Inspected
Heating Plant Oil Number	Gas
Is there a water meter on the boiler make-up water piping?	N/A
Observed Operational?	Yes
Burner Exists?	Yes
Burner Manufacturer	Yes
Burner Model Number	John Zink Company, LLC FL14.9-G-30
Boiler Auxiliaries	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	FEEDWATER PUMP: DEFECTIVE
Deficiency Location/Instance	Boiler Room (Leaks)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Feedwater Treatment(Automatic)	

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler System	Inspected
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	5,161
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Burnham
Equipment	51657-01
Capacity/Size Quantity	6,648
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Installation Year	2010
Source of Installation	Documented
Deficiency	DAMAGED REFRACTORY
Deficiency Quantity	5
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	5,161
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Burnham
Equipment	51657-02
Capacity/Size Quantity	6,648
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	2010
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	BURNER CONTROL PANEL: DEFECTIVE
Deficiency Location/Instance	Boiler Room / Boiler #2 (Programming issue)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel Oil Storage/Supply System	
Instance on Basement	Does not Exist
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Question	Response
HEATING PLANT	Inspected
Fuel System	
Gas Trains And Vent At The Boiler	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	Inspected
Instance on Room 140A	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 140A	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 140A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
KITCHEN	Inspected
Instance on Basement	Inspected
CO Detector	Inspected
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas System	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Grease Trap	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE/CLOGGED
Deficiency Location/Instance	Kitchen (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hood	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Question	Response
KITCHEN	
Hood Exhaust Fan	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hot Water Temperature Booster	Does not Exist
Instance on Basement	Does not Exist
Kitchen Sink	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	MISSING AIR GAP
Deficiency Location/Instance	Kitchen (3 of 5)
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
MDF Room	Inspected
Instance on Room B20	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room B20	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Rooms 101, 119, Gymnasium Office, Kitchen Storage Room, Lamp Storage Room, Paint Storage Room
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Sprinkler Head	
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	
Condition	Inspected
Deficiency	3 - Fair
Deficiency	No deficiencies recorded
Standpipe System	
Condition	Does not Exist
Water Gong	
Condition	Does not Exist
SWIMMING POOL	
Condition	Does not Exist
VENTILATION	
Is the building mechanically ventilated?	Inspected
Is the building mechanically ventilated?	Partial
Exhaust Fan	
Condition	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Main Roof
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Heating And Ventilating Unit	
Condition	Inspected
Condition	3 - Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Main Roof
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Metal Ductwork	
Condition	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER 132
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K120

Question	Response
VENTILATION	
Metal Ductwork	
Violations	No violations recorded.
Deficiency	DAMAGED FLEXIBLE CONNECTION
Deficiency Location/Instance	MER 132
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	
Approximate Total # of Fans	Inspected 1-5
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	MER 132/ Gym BL (defective bearing)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Unit Ventilator	
Condition	Inspected 3 - Fair
Deficiency	No deficiencies recorded