

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Asset: P.S. 151 - BROOKLYN, 763 KNICKERBOCKER AVENUE, New York, 11207

Inspection Id	Inspection Type	Time In	Last Edited
ME : K151	Mechanical	2024-04-08 7:49 AM	2024-04-24 9:04 AM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	7,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	Sub-Basement East, West MERs, 2nd Floor Multipurpose Room Fan Room, Stage MER
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Rooms B2, B10 (at the west end of Building)
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Gas Trains and Vent At The Boilers; F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps
	Years: 2023
	Systems: Gas Fired Domestic Water Heater; Domestic Hot Water Remote Storage Tanks
	Years: 2020
	Systems: CO/Gas Leak Detection System; Kitchen - Gas System
	Years: 2019
	Systems: Fixtures - Student: Lavatory/Sinks (50%), Toilets (50%), Urinals (50%); Unit Heater/Cabinet Heaters
	Years: 2017
	Systems: Electric Pressure Booster System; Water Services; Kitchen - Grease Trap, Hood, Hood Exhaust Fan, Sinks
	Years: 2014
	Systems: MDF Room - Dedicated A/C Equipment (DX Split System, 1 of 2)
	Years: 2013

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No	Defective Boiler Safety Auxiliary	Boiler#1 Safety Valves Defective	HEATING PLANT Boiler Auxiliaries Boiler Safety Valve	Boiler Room/ Boiler #1	Ray Rios	Fireman	Sent to DSF	
Yes	Defective Sprinkler/Stand pipe System	Painted Sprinkler Heads	SPRINKLERS, STANDPIPE, FIRE SYSTEM Sprinkler Head	Room B7	Ray Rios	Fireman	Sent to DSF	
Yes	Defective Emergency Stop Switch	Defective Emergency Stop Switch	HEATING PLANT Boiler Auxiliaries Boiler Emergency Stop Switch	Boiler Room Entrance	Ray Rios	Fireman	Sent to DSF	

Inspection

Question	Response
Mechanical	

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
AIR CONDITIONING	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	4 - Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	21-40%
Deficiency	PNEUMATIC TUBING:DEFECTIVE/LEAKS AIR
Deficiency Location/Instance	Throughout
Deficiency Quantity	1,000
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Throughout
Deficiency Quantity	40
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE REFRIGERATED AIR DRYER
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE AIR COMPRESSOR
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE PNEUMATIC PRV STATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
CLIMATE CONTROL SYSTEM	
Pneumatic System	
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Inspected
Instance	Sub-Basement Pump Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Liquitrol
Equipment	N/A
Capacity/Size Quantity	2
Capacity/Size UOM	Total # Pumps
Capacity/Size2 Quantity	10
Capacity/Size2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2014
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Hydraulic/Pneumatic Booster System	Does not Exist
Water Service	Inspected
Instance	Sub-Basement East MER
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Sub-Basement Pump Room
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Domestic Water Heat Exchanger	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Domestic Water Heat Exchanger	
Condition	3 - Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Electric Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	RayPak
Equipment	N/A
Capacity/Size Quantity	334
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	0
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2020
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE DOMESTIC HOT WATER CIRCULATING PUMP
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
DOMESTIC WATER SYSTEM	Inspected
Domestic Water Distribution Piping	Inspected
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	SEWAGE/WASTE PIPING: DEFECTIVE/LEAKS
Deficiency Location/Instance	Sub-Basement East MER, Sub-Basement Crawlspace
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sewage Ejector Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sump Pump	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Sub-Basement West MER, Boiler Room
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
FIXTURES	
Student	
Drinking Fountain	
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Cafeteria, Near Exit 4
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Lavatory/Sink	
Condition	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Toilet Room inside Room 109
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Locker Room Shower	
	Does not Exist
Sink And Fountain Combo Unit	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	
	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	
	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	
	Does not Exist
GAS SERVICE	
	Inspected
Gas Distribution Piping	
	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	
	Does not Exist
CO/Gas Leak Detection	
	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
GAS SERVICE	
CO/Gas Leak Detection	
Instance Quantity Uom	EACH
Installation Year	2019
Source of Installation	Documented
Deficiency	No deficiencies recorded
HEATING	
Heating Coil In Ductwork	
Condition	Inspected
Condition	5 - Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Sub-Basement East, West MERs, 2nd Floor Multipurpose Room - Stage MER/ Heating Coil Chambers
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hydronic Heating	
Does not Exist	
Radiator/Convactor/Fin Tube	
Condition	Inspected
Condition	3 - Fair
Deficiency	AUXILIARY (VALVE,VENT): DEFECTIVE
Deficiency Location/Instance	Room B02
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	RADIATOR/CONVECTOR: DEFECTIVE
Deficiency Location/Instance	Cafeteria, Room 202
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Heating	
Inspected	
F&T/Steam Drip Trap	
Condition	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	
Condition	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Sub-Basement East, West MERs, 2nd Floor Multipurpose Room Fan Room, 2nd Floor Multipurpose Room - Stage MER
Deficiency Quantity	300

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
HEATING	
Steam Heating	
MER Steam and Condensate Piping	
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Condensate Return Piping	
Condition	Inspected
Deficiency	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	
Condition	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE PUMP
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Piping	
Condition	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement near Exit 3
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Sub-Basement East MER, Boiler Room
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Terminal Unit Thermostatic Trap	
Condition	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Steam supplied by External Sources	
Condition	Does not Exist
Unit Heater/Cabinet Heater	
Condition	Inspected
Condition	2 - Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
HEATING	
Unit Heater/Cabinet Heater	
Deficiency	DEFECTIVE
Deficiency Location/Instance	Kitchen Servery, Student Toilet Rooms 102, 202
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
HEATING PLANT	
	Inspected
Replacement Quantity	9,096
Replacement Uom	MBH Net
Instance on Sub-Basement	Inspected
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Industrial Combustion
Burner Model Number	AN-426,387
Boiler Auxiliaries	
	Inspected
Instance on Sub-Basement	Inspected
Boiler Auxiliary Piping	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room Entrance/ Broken Glass
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Feedwater System	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Sub-Basement	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Feedwater Treatment(Automatic)	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Flue Exhaust	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Safety Valve	
Instance on Sub-Basement	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room/ Boiler #1
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler System	Inspected
Instance on Sub-Basement	Inspected
Coal-fired Boiler	
Instance on Sub-Basement	Does not Exist
Hot Water Boiler	
Instance on Sub-Basement	Does not Exist
Modular Boiler	
Instance on Sub-Basement	Does not Exist
Steam Boiler	
Instance on Sub-Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	4,548
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	13226-01
Capacity/Size Quantity	4,548
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1998
Source of Installation	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED REFRACTORY
Deficiency Quantity	200
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	4,548
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	13226-02
Capacity/Size Quantity	4,548
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1998
Source of Installation	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
HEATING PLANT	
Boiler System	Inspected
Steam Boiler	
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel System	Inspected
Instance on Sub-Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Sub-Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Enclosed IDF Room	Does not Exist
KITCHEN	
Instance on Basement	Inspected
CO Detector	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas System	Inspected
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Grease Trap	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
KITCHEN	
Hood Exhaust Fan	Inspected
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Does not Exist
Instance on Basement	Does not Exist
Hot Water Temperature Booster	Does not Exist
Instance on Basement	Does not Exist
Kitchen Sink	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room B7	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room B7	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Does not Exist
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Does not Exist
Sprinkler Head	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Rooms B2, B10 (at the west end of Building)
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Room B7
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K151

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	No
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	2nd Floor Multipurpose Room Fan Room, Room across B11
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Supply Fan	Inspected
Approximate Total # of Fans	1-5
Condition	5 - Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Sub-Basement East, West MERs, 2nd Floor Multipurpose Stage MER
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Unit Ventilator	Does not Exist