

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Asset: P.S. 186 - BROOKLYN, 7601 19 AVENUE, New York, 11214

Inspection Id	Inspection Type	Time In	Last Edited
ME : K186	Mechanical	2023-11-03 8:05 AM	2024-05-02 2:30 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	10,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Basement North, South MERs, Fan Room above Auditorium, Fan Rooms 604, 605, Penthouse Fan Room
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Basement - Fireman Break Room, Paint Room
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Climate Control System - Electric System (Heat Timer)
	Years: 2024
	Systems: Climate Control System - BMS
	Years: 2023
	Systems: Fixtures - Student: Toilets (50%)
	Years: 2022
	Systems: Gas Fired Domestic Water Heater; F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps
	Years: 2021
	Systems: CO/Gas Leak Detection
	Years: 2020
	Systems: Kitchen - Grease Trap
	Years: 2017
	Systems: Water Services (2 of 3)
	Years: 2016
	Systems: MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2015
	Systems: Boiler #2 Safety Valves (2 of 4)
	Years: 2014

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Under Construction

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
AIR CONDITIONING	
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Under Construction
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	
	Does not Exist
CLIMATE CONTROL SYSTEM	
	Inspected
BMS	Inspected
Instance	Throughout
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Installation Year	2023
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
Pneumatic System	Does not Exist
Hybrid System	Does not Exist
Electric System	Inspected
Instance	Throughout (Heat Timer)
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
COMPACTOR	Does not Exist
CONVEYING	
	Inspected
Dumbwaiter	Does not Exist
Elevator	Does not Exist
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Inspected
Are all the existing ash hoists operable?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	
	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Pressure Booster System	
Electric Pressure Booster System	
Instance Manufacturer	Thrush
Equipment	N/A
Capacity/Size Quantity	2
Capacity/Size UOM	Total # Pumps
Capacity/Size2 Quantity	10
Capacity/Size2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2005
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Hydraulic/Pneumatic Booster System	
Water Service	
Instance	Basement Crawlspace (19th Avenue)
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement Crawlspace (19th Avenue)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Basement North MER (76th Street)
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement North MER (76th Street)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Basement South MER (77th Street)
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement South MER (77th Street)
Deficiency Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	
	Inspected
Domestic Hot Water Remote Storage Tank	
	Does not Exist
Domestic Water Heat Exchanger	
	Does not Exist
Electric Domestic Water Heater	
	Does not Exist
Heat Pump Domestic Water Heater	
	Does not Exist
Gas Fired Domestic Water Heater	
	Inspected
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	A.O. Smith
Equipment	N/A
Capacity/Size Quantity	500
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	85
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2021
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	
	Does not Exist
Domestic Water Distribution Piping	
	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	Boiler Room (mixing valve)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room, Rooms 400, 409, 4th Floor Girls Toilet Room, 4th Floor Hallway
Deficiency Quantity	250
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
DOMESTIC WATER SYSTEM	Inspected
Domestic Water Distribution Piping	Inspected
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	CLOGGED/LEAKING
Deficiency Location/Instance	1st Floor Women's Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Student	Inspected
Drinking Fountain	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
FIXTURES	
Student	
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE FLUSHOMETER VALVE
Deficiency Location/Instance	1st and 4th Floor Girls Toilet Rooms
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Urinal	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2020
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Basement outside Paint Storage Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hydronic Heating	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
HEATING	
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	AUXILIARY (VALVE, VENT): DEFECTIVE
Deficiency Location/Instance	Exit 4 Vestibule
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement North, South MERs
Deficiency Quantity	50
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement North, South MERs
Deficiency Quantity	200
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Condensate Return Pumping System	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE CONTROLS
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
HEATING	
Steam Heating	
Steam Piping	
Condition	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement North, South MERs
Deficiency Quantity	200
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Terminal Unit Thermostatic Trap	
Condition	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Steam supplied by External Sources	
Does not Exist	
Unit Heater/Cabinet Heater	
Inspected	
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
HEATING PLANT	
Inspected	
Replacement Quantity	10,322
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	Yes
Burner Exists?	Yes
Burner Manufacturer	Gordon Piatt
Burner Model Number	FL14.9-GO-30
Boiler Auxiliaries	
Inspected	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Inspected	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE BLOWDOWN PIPING
Deficiency Location/Instance	Boiler Room / Boiler #1 (valves)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 4

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Auxiliary Piping	
Deficiency Photo1	No photo recorded
Violations	39061384K
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	5,161
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	8442-01
Capacity/Size Quantity	5,161
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2000
Source of Installation	Documented
Deficiency	DEFECTIVE AUXILIARY (GAUGES, GASKETS ETC.)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	5,161
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	8442-02
Capacity/Size Quantity	5,161
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2000
Source of Installation	Documented
Deficiency	DEFECTIVE AUXILIARY (GAUGES, GASKETS ETC.)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
HEATING PLANT	
Boiler System	Inspected
Steam Boiler	
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	Inspected
Instance on Room 252	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 252	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 252
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
KITCHEN	Inspected
Instance on 1st Floor	Inspected
CO Detector	Not Required
Instance on 1st Floor	Not Required
Gas System	Does not Exist
Instance on 1st Floor	Does not Exist
Grease Trap	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
KITCHEN	
Hood	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Exhaust Ductwork	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Fire Suppression System	Does not Exist
Instance on 1st Floor	Does not Exist
Hot Water Temperature Booster	Does not Exist
Instance on 1st Floor	Does not Exist
Kitchen Sink	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room inside Room 504B	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room inside Room 504B	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Inspected
Instance on Room 402	Inspected
Alternative use	Yes
Acid Waste Neutralizing Tank	Does not Exist
Instance on Room 402	Does not Exist
CO Detector	Not Required
Instance on Room 402	Not Required
Emergency Shower	Does not Exist
Instance on Room 402	Does not Exist
Eye Wash	Does not Exist
Instance on Room 402	Does not Exist
Hood Exhaust Ductwork	Does not Exist
Instance on Room 402	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Room 402	Does not Exist
Fixed Laboratory Hood	Does not Exist
Instance on Room 402	Does not Exist
Laboratory Sink	Inspected
Instance on Room 402	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 402	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K186

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Does not Exist
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Basement - Fireman Break Room, Paint Room
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Partial
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE MOTOR
Deficiency Location/Instance	Penthouse Fan Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	No
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE REGISTER/DIFFUSER
Deficiency Location/Instance	Auditorium
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K186

Question	Response
VENTILATION	
Supply Fan	Inspected
Approximate Total # of Fans	1-5
Condition	3 - Fair
Deficiency	No deficiencies recorded
Unit Ventilator	Does not Exist