

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

**K214**

**Asset:** P.S. 214 - BROOKLYN, 2944 PITKIN AVENUE, New York, 11208

Inspection Id	Inspection Type	Time In	Last Edited
ME : K214	Mechanical	2023-10-16 7:53 AM	2024-01-17 2:38 PM

**Asset Data**

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	9,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	Basement MER, Boiler Room Fan Room, 5th Floor Fan Room
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Kitchen Storage Room
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Boiler Safety Valves (4 of 4); Fixtures- Students: Drinking Fountains, Toilets (15%)
	Years: 2023
	Systems: Fixtures - Student: Toilets (85%), Urinals (80%); Staff And Other: Toilets
	Years: 2022
	Systems: Climate Control System - Electric System (Heat Timer)
	Years: 2021
	Systems: MDF Room - Dedicated A/C Equipment (DX Split System); DX Split System in Room 215A
	Years: 2018
	Systems: Sump Pumps (2 of 4)
	Years: 2017
	Systems: F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps; Climate Control System - Terminal Unit Control Valves
	Years: 2016
	Systems: Kitchen - Grease Trap
	Years: 2015

**Priority Condition**

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

**Inspection**

Question	Response
<b>Mechanical</b>	
<b>AIR CONDITIONING</b>	Inspected
<b>Chilled Water System</b>	Does not Exist
<b>Condenser Water Distribution: Piping, Pumps and Auxiliaries</b>	Does not Exist
<b>Cooling Coil in Ductwork</b>	Does not Exist
<b>Cooling Tower</b>	Does not Exist
<b>DX Split System</b>	Inspected
<b>Indoor Unit</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K214

Question	Response
<b>AIR CONDITIONING</b>	
<b>DX Split System</b>	
<b>Outdoor Unit</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Dry Cooler</b>	Does not Exist
<b>Packaged / Rooftop Unit</b>	Does not Exist
<b>Packaged Terminal A/C</b>	Does not Exist
<b>Refrigerant Leak Detection System</b>	Does not Exist
<b>Refrigerant Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Return Fan</b>	Does not Exist
<b>CENTRAL ACID WASTE NEUTRALIZING TANK</b>	Does not Exist
<b>CLIMATE CONTROL SYSTEM</b>	Inspected
<b>BMS</b>	Does not Exist
<b>Pneumatic System</b>	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Kitchen Storage Room, Kitchen Toilet Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Hybrid System</b>	Does not Exist
<b>Electric System</b>	Inspected
Instance	Throughout (Heat Timer)
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
<b>COMPACTOR</b>	Does not Exist
<b>CONVEYING</b>	Inspected
<b>Dumbwaiter</b>	Does not Exist
<b>Elevator</b>	Under Construction
<b>Escalator</b>	Does not Exist
<b>Non-auditorium Handicap Lift - Vertical</b>	Does not Exist
<b>Non-auditorium Handicap Lift - Stair</b>	Does not Exist
<b>Ash Hoist</b>	Does not Exist
<b>Sidewalk Elevator</b>	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K214

Question	Response
<b>DOMESTIC WATER SYSTEM</b>	Inspected
<b>Domestic Cold Water System</b>	Inspected
<b>Gravity System</b>	Does not Exist
<b>Pressure Booster System</b>	Does not Exist
<b>Water Service</b>	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Basement MER
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement MER
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Domestic Hot Water System</b>	Inspected
<b>Domestic Hot Water Remote Storage Tank</b>	Does not Exist
<b>Domestic Water Heat Exchanger</b>	Does not Exist
<b>Electric Domestic Water Heater</b>	Does not Exist
<b>Heat Pump Domestic Water Heater</b>	Does not Exist
<b>Gas Fired Domestic Water Heater</b>	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	PVI
Equipment	N/A
Capacity/Size Quantity	399
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	225
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K214

Question	Response
<b>DOMESTIC WATER SYSTEM</b>	
<b>Domestic Hot Water System</b>	Inspected
<b>Gas Fired Domestic Water Heater</b>	Inspected
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Oil Fired Domestic Water Heater</b>	Does not Exist
<b>Domestic Water Distribution Piping</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>DRAIN/WASTE/VENT AND STORM SYSTEM</b>	Inspected
<b>Interior Storm Piping</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Sewage/Waste/Vent Piping</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Sewage Ejector Pump</b>	Does not Exist
<b>Sump Pump</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	Does not Exist
<b>FIXTURES</b>	Inspected
<b>Staff And Other</b>	Inspected
<b>Janitor Sink</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Toilet</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Urinal</b>	Does not Exist
<b>Student</b>	Inspected
<b>Drinking Fountain</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Locker Room Shower</b>	Inspected
Instance on 3rd Floor	Inspected
Instance Condition	3 - Fair
Alternative use	Yes
Deficiency	No deficiencies recorded
<b>Sink And Fountain Combo Unit</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K214

Question	Response
<b>FIXTURES</b>	
<b>Student</b>	
<b>Toilet</b>	Inspected
Condition	1 - Good
Deficiency	CLOGGED/LEAKING
Deficiency Location/Instance	3rd Floor Boys Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Urinal</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	3rd Floor Boys Toilet Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>GAS FIRED FURNACE</b>	Does not Exist
<b>GAS SERVICE</b>	Inspected
<b>Gas Distribution Piping</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Gas Meter Room Exhaust Fan</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Gas Meter Room Vent</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Gas Pressure Booster</b>	Does not Exist
<b>CO/Gas Leak Detection</b>	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>HEATING</b>	Inspected
<b>Heating Coil In Ductwork</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Hydronic Heating</b>	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K214

Question	Response
<b>HEATING</b>	
<b>Radiator/Convactor/Fin Tube</b>	Inspected
Condition	3 - Fair
Deficiency	RADIATOR/CONVECTOR: MISSING GUARD/SHIELD
Deficiency Location/Instance	Main Entrance, Stair H1 Exit Vestibule, Gymnasium Entrance, 3rd Floor - Shower Room, Girls Toilet Room, Room 561
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Steam Heating</b>	Inspected
<b>F&amp;T/Steam Drip Trap</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>MER Steam and Condensate Piping</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Steam Condensate Return Piping</b>	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Room 519
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Steam Condensate Return Pumping System</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Steam Piping</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Terminal Unit Thermostatic Trap</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Steam supplied by External Sources</b>	Does not Exist
<b>Unit Heater/Cabinet Heater</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>HEATING PLANT</b>	
Replacement Quantity	12,996
Replacement Uom	MBH Net
Instance on Basement	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K214

Question	Response
<b>HEATING PLANT</b>	
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2(B10)
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	Yes
Burner Exists?	Yes
Burner Manufacturer	Gordon-Piatt
Burner Model Number	F14-GO-50
<b>Boiler Auxiliaries</b>	Inspected
Instance on Basement	Inspected
<b>Boiler Auxiliary Piping</b>	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE BOILER FEEDWATER PIPING
Deficiency Location/Instance	Boiler Room Under Feedwater Tank
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Boiler Emergency Stop Switch</b>	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Boiler Feedwater System</b>	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Boiler Feedwater Treatment(Automatic)</b>	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Boiler Flue Exhaust</b>	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Boiler Make-up Water Backflow Preventer</b>	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Boiler Room Steam And Condensate Piping</b>	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Boiler Safety Valve</b>	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Boiler System</b>	
Instance on Basement	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K214

Question	Response
<b>HEATING PLANT</b>	
<b>Boiler System</b>	
<b>Coal-fired Boiler</b>	
Instance on Basement	Does not Exist
<b>Hot Water Boiler</b>	
Instance on Basement	Does not Exist
<b>Modular Boiler</b>	
Instance on Basement	Does not Exist
<b>Steam Boiler</b>	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,498
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	7314-2
Capacity/Size Quantity	6,498
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,498
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	7314-1
Capacity/Size Quantity	6,498
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2000
Source of Installation	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Fuel System</b>	
Instance on Basement	Inspected
<b>Boiler Fresh Air Louver/Damper</b>	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	3 - Fair



**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K214

Question	Response
<b>HEATING PLANT</b>	
<b>Fuel System</b>	
<b>Boiler Fresh Air Louver/Damper</b>	
Deficiency	No deficiencies recorded
<b>Burner/Burner Control Panel</b>	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Fuel Oil Storage/Supply System</b>	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Gas Trains And Vent At The Boiler</b>	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Enclosed IDF Room</b>	Does not Exist
<b>KITCHEN</b>	
Instance on 1st Floor	Inspected
<b>CO Detector</b>	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Gas System</b>	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Grease Trap</b>	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood</b>	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Hood Exhaust Ductwork</b>	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Hood Exhaust Fan</b>	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Hood Fire Suppression System</b>	
Instance on 1st Floor	Does not Exist
<b>Hot Water Temperature Booster</b>	
Instance on 1st Floor	Does not Exist
<b>Kitchen Sink</b>	
Instance on 1st Floor	Inspected
Condition	3 - Fair

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K214

Question	Response
<b>KITCHEN</b>	
<b>Kitchen Sink</b>	
Deficiency	MISSING AIR GAP
Deficiency Location/Instance	Kitchen
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>MDF Room</b>	Inspected
Instance on Room 211C	Inspected
<b>Dedicated A/C Equipment</b>	Inspected
Instance on Room 211C	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	Does not Exist
<b>SCIENCE LAB</b>	Does not Exist
<b>SCIENCE PREP ROOM</b>	Does not Exist
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	Inspected
<b>Dry Sprinkler Alarm Valve Assembly</b>	Does not Exist
<b>Wet Sprinkler Alarm Valve Assembly</b>	Does not Exist
<b>Fire Booster Pump Assembly</b>	Does not Exist
<b>Roof Tank</b>	Does not Exist
<b>Siamese Connection</b>	Does not Exist
<b>Sprinkler Head</b>	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Kitchen Storage Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Sprinkler Piping</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Standpipe System</b>	Does not Exist
<b>Water Gong</b>	Does not Exist
<b>SWIMMING POOL</b>	Does not Exist
<b>VENTILATION</b>	Inspected
Is the building mechanically ventilated?	Partial
<b>Exhaust Fan</b>	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K214

Question	Response
<b>VENTILATION</b>	
<b>Heating And Ventilating Unit</b>	Does not Exist
<b>Metal Ductwork</b>	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	Yes
Condition	3 - Fair
Deficiency	DAMAGED FLEXIBLE CONNECTION
Deficiency Location/Instance	Boiler Room Fan Room / House Exhaust 1A, Basement MER/ House Exhaust 2A, Toilet Exhaust, Auditorium Blower 3
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Supply Fan</b>	Inspected
Approximate Total # of Fans	1-5
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Unit Ventilator</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded