

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Asset: P.S. 257 - BROOKLYN, 60 COOK STREET, New York, 11206

Inspection Id	Inspection Type	Time In	Last Edited
ME : K257	Mechanical	2023-10-19 7:35 AM	2023-11-03 4:53 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	2
Total capacity of all above ground tanks in gal.	15,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	Fan Room 118, 3rd Floor MER
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Basement - School Supply Room, Computer Supply Room
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Boiler Make-up Water Backflow Preventer
	Years: 2023
	Systems: Boiler Feedwater Treatment (Automatic)
	Years: 2022
	Systems: Exhaust Fans (85%); MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2021
	Systems: DX Split Systems for Gymnasium
	Years: 2019
	Systems: F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps
	Years: 2018
	Systems: DX Split System - Outdoor Unit (2 of 8); Cooling Coils in Ductwork
	Years: 2014

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
Yes	Defective Boiler Safety Auxiliary	Leaking Boiler Safety Valve	HEATING PLANT Boiler Auxiliaries Boiler Safety Valve	Boiler Room (Boiler #1, 1 of 4)	John Aglio	Fireman	Sent to DSF	

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Question	Response
AIR CONDITIONING	
DX Split System	
Indoor Unit	
Condition	1 - Good
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Return Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Various locations
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Inspected
Dumbwaiter	Does not Exist
Elevator	Inspected
Are all the existing elevators operable?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Question	Response
CONVEYING	
Ash Hoist	Inspected
Are all the existing ash hoists operable?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Gas Meter/Sprinkler Room
Instance Condition	5 - Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: DETERIORATED
Deficiency Location/Instance	Gas Meter/Sprinkler Room (cracked pipe before the main valve)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Gas Meter/Sprinkler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room - Crawlspace
Instance Condition	4 - Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: DEFECTIVE VALVE
Deficiency Location/Instance	Boiler Room - Crawlspace (Main valve, Rusty)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Boiler Room - Crawlspace
Deficiency Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	
	Inspected
Domestic Hot Water Remote Storage Tank	
	Does not Exist
Domestic Water Heat Exchanger	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Electric Domestic Water Heater	
	Does not Exist
Heat Pump Domestic Water Heater	
	Does not Exist
Gas Fired Domestic Water Heater	
	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	RayPak
Equipment	N/A
Capacity/Size Quantity	264
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	0
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2008
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	
	Does not Exist
Domestic Water Distribution Piping	
	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Gas Meter/Sprinkler Room
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Gas Meter/Sprinkler Room
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Water Distribution Piping	
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	Gas Meter/Sprinkler Room (Rusty and leak)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DRAIN/WASTE/VENT AND STORM SYSTEM	
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	SEWAGE/WASTE PIPING: CLOGGED
Deficiency Location/Instance	Various 1st Floor locations (backs up during heavy rain)
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	SEWAGE/WASTE PIPING: DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room - Crawlspace
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sewage Ejector Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sump Pump	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room (2 of 2)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Sump Pump	
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	CLOGGED/LEAKING
Deficiency Location/Instance	2nd Floor Locker Room Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Boys Toilet Room 329, Girls Toilet Rooms 321, 221
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Locker Room Shower	Inspected
Instance on 2nd Floor	Inaccessible
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Room 234
Deficiency Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Question	Response
FIXTURES	
Student	
Sink And Fountain Combo Unit	
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Toilet	
Condition	Inspected
Deficiency	3 - Fair
Urinal	
Condition	Inspected
Deficiency	3 - Fair
GAS FIRED FURNACE	
Does not Exist	
GAS SERVICE	
Inspected	
Gas Distribution Piping	
Condition	Inspected
Deficiency	3 - Fair
Gas Meter Room Exhaust Fan	
Does not Exist	
Gas Meter Room Vent	
Condition	Inspected
Deficiency	2 - Between Good and Fair
Gas Pressure Booster	
Does not Exist	
CO/Gas Leak Detection	
Does not Exist	
HEATING	
Inspected	
Heating Coil In Ductwork	
Condition	Inspected
Deficiency	3 - Fair
Hydronic Heating	
Does not Exist	
Radiator/Convactor/Fin Tube	
Condition	Inspected
Deficiency	3 - Fair
Steam Heating	
Inspected	
F&T/Steam Drip Trap	
Condition	Inspected
Deficiency	2 - Between Good and Fair
MER Steam and Condensate Piping	
Condition	Inspected
Deficiency	3 - Fair
Deficiency Location/Instance	DAMAGED/MISSING INSULATION
Deficiency Quantity	3rd Floor MER
Quantity Uom	20
Potential Action	L.F.
Urgency of Action	MAINTENANCE
Purpose of Action	PRIORITY 3
Deficiency Photo	LEVEL 2
Violations	No photo recorded
	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Question	Response
HEATING	
Steam Heating	
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room, 3rd Floor MER
Deficiency Quantity	120
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Condensate Return Pumping System	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
HEATING PLANT	
Replacement Quantity	72
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Oil
Heating Plant Oil Number	2(B10)
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Preferred Utilities
Burner Model Number	HE7V3A4
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Does not Exist
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Condition	1 - Good

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Feedwater Treatment(Automatic)	
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room (Steam Condensate Return Piping)
Deficiency Quantity	50
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room (Boiler #1, leak, 1 of 4)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler System	Inspected
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	36
Instance Quantity Uom	MBH Net

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Cast Iron Boiler?	No
Instance Manufacturer	National Radiator Corp. (NRC)
Equipment	49729-1
Capacity/Size Quantity	60
Capacity/Size UOM	Burner GPH
Source of Capacity/Size	Documented
Installation Year	1962
Source of Installation	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	36
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	National Radiator Corp. (NRC)
Equipment	49729-2
Capacity/Size Quantity	60
Capacity/Size UOM	Burner GPH
Source of Capacity/Size	Documented
Installation Year	1962
Source of Installation	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair

**NYC Department of Education
Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K257

Question	Response
HEATING PLANT	
Fuel System	
Burner/Burner Control Panel	
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not Exist
Enclosed IDF Room	
Instance on Rooms 109, 315	Inspected
Dedicated A/C Equipment	
Instance on Rooms 109, 315	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Rooms 109, 315
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas System	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Grease Trap	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Question	Response
KITCHEN	
Hood Fire Suppression System	Does not Exist
Instance on 1st Floor	Does not Exist
Hot Water Temperature Booster	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Kitchen Sink	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room 341	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 341	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Does not Exist
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Basement - School Supply Room, Computer Supply Room
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K257

Question	Response
VENTILATION	
Exhaust Fan	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	Yes
Condition	3 - Fair
Deficiency	DEFECTIVE REGISTER/DIFFUSER
Deficiency Location/Instance	Gymnasium, Boys Toilet Room 329
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	Inspected
Approximate Total # of Fans	1-5
Condition	3 - Fair
Deficiency	No deficiencies recorded
Unit Ventilator	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded