

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Asset: P.S. 279 - BROOKLYN, 1070 EAST 104 STREET, New York, 11236

Inspection Id	Inspection Type	Time In	Last Edited
ME : K279	Mechanical	2023-11-29 8:44 AM	2023-12-05 2:18 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	MER B13, Steam Condensate Return Pumping System Room near Basement Staircase C
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Enclosed IDF Room - Dedicated A/C Equipment (DX Split System) (Room 122)
	Years: 2022
	Systems: Elevator (1 of 2)
	Years: 2018
	Systems: Exhaust Fans (7 of 26); MDF Room - Dedicated A/C Equipment (DX Split System); CO/Gas Leak Detection; Steam Condensate Return Pumping System (1 of 2)
	Years: 2017
	Systems: Heating Plant; MER Steam and Condensate Piping; F&T/Steam Drip Traps; Climate Control System - BMS for Original Building; Climate Control System - Electric System (Heat Timer); Heating And Ventilating Units; Exhaust Fans (9 of 26); Domestic Hot Water System; Sump Pumps; Gas Meter Room - Exhaust Fan, Vent; Gas Distribution Piping (50%); Heating Coil In Ductwork
	Years: 2016
	Systems: Terminal Unit Thermostatic Traps
	Years: 2015
	Systems: Sewage Ejector Pumps
	Years: 2013

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
AIR CONDITIONING	
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Inspected
Instance	Building Addition - Roof
Instance Condition	3 - Fair
Instance Quantity	4
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-22
Instance Manufacturer	Trane
Equipment	AC-1, AC-3, AC-6, AC-9
Capacity/Size Quantity	15
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Building Addition - Roof
Instance Condition	3 - Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-22
Instance Manufacturer	Trane
Equipment	AC-4, AC-7
Capacity/Size Quantity	10
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Building Addition - Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-22
Instance Manufacturer	Trane
Equipment	AC-2
Capacity/Size Quantity	24
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Building Addition - Roof
Instance Condition	3 - Fair
Instance Quantity	2
Instance Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	
Source of Heating	Gas
Refrigerant Type	R-22
Instance Manufacturer	Trane
Equipment	AC-5, AC-8
Capacity/Size Quantity	22
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Inspected
Instance	Building Addition - Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Installation Year	2000
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Original Building - Throughout
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Installation Year	2016
Source of Installation	Documented
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Rooms 106, 115, 123, 215, 218, 302B
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Pneumatic System	Does not Exist
Hybrid System	Does not Exist
Electric System	Inspected
Instance	Throughout (Heat Timer)

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
CLIMATE CONTROL SYSTEM	
Electric System	
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
COMPACTOR	Does not Exist
CONVEYING	Inspected
Dumbwaiter	Does not Exist
Elevator	Inspected
Are all the existing elevators operable?	Yes
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Does not Exist
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Under Construction
Hydraulic/Pneumatic Booster System	Does not Exist
Water Service	Inspected
Instance	MER B13 Crawlspace
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	MER B13 Crawlspace
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Original Building - Room B1
Instance Condition	3 - Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Original Building - Room B1
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	Inspected
Water Service	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Lochinvar
Equipment	WH-1
Capacity/Size Quantity	250
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	0
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2016
Source of Installation	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	SEWAGE/WASTE PIPING: DEFECTIVE/LEAKS
Deficiency Location/Instance	Building Addition - Crawl Space
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sewage Ejector Pump	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Sewage Ejector Pump	
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE CONTROLS
Deficiency Location/Instance	Ejector Room B9
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sump Pump	
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE CONTROLS
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	
	Does not Exist
FIXTURES	
	Inspected
Staff And Other	
	Inspected
Janitor Sink	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Student	
	Inspected
Drinking Fountain	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	
Condition	3 - Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Girls Toilet Room 213
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
FIXTURES	
Student	
Lavatory/Sink	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	3rd Floor Boys Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Boys Toilet Room 210
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
GAS FIRED FURNACE	Inspected
Condition	3 - Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Kitchen Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
GAS SERVICE	
Gas Meter Room Exhaust Fan	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Inspected
Instance	Boiler Room, Original Building and Building Addition Gas Meter Rooms
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2017
Source of Installation	Documented
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	MER B13
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
MER Steam and Condensate Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
HEATING	
Steam Heating	Inspected
Terminal Unit Thermostatic Trap	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Exit 9 / Missing Cover
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
HEATING PLANT	
Replacement Quantity	11,032
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Gas
Heating Plant Oil Number	N/A
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	Yes
Burner Exists?	Yes
Burner Manufacturer	Cyclonetic
Burner Model Number	JB3G-75-LMV37-S-M.40VGD-UL/IRI
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Make-up Water Backflow Preventer	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	5,516
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Burnham
Equipment	47164-01
Capacity/Size Quantity	7,105
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	2016
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	5,516
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Burnham
Equipment	47164-02
Capacity/Size Quantity	7,105
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	2016
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fuel System	
	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
HEATING PLANT	
Fuel System	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Does not Exist
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Enclosed IDF Room	
Instance on Room 122	Inspected
Instance on Rooms 214, 314	Inspected
Dedicated A/C Equipment	
Instance on Rooms 214, 314	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Rooms 214, 314
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Room 122	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas System	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Grease Trap	
Instance on 1st Floor	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
KITCHEN	
Grease Trap	Inspected
Deficiency	No deficiencies recorded
Hood	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hot Water Temperature Booster	Does not Exist
Instance on 1st Floor	Does not Exist
Kitchen Sink	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room A103B	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room A103B	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Original Building - Room B1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K279

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Siamese Connection	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Standpipe System	Inspected
Hose Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	26-50
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist