

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Asset: P.S. 811 (OLD P286) - BROOKLYN, 2525 HARING STREET, New York, 11235

Inspection Id	Inspection Type	Time In	Last Edited
ME : K286	Mechanical	2024-02-09 8:46 AM	2024-02-20 3:49 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	10,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Cafeteria Roof Penthouse MER, MER B12
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Rooms B2, B3C (in Boiler Room), B5, B8, B11
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Boiler Feedwater Treatment (Automatic)
	Years: 2023
	Systems: Sump Pump (1 of 2) in Boiler Room; Boiler Safety Valves (2 of 4)
	Years: 2021
	Systems: Chilled Water System - Backflow Preventer
	Years: 2020
	Systems: Climate Control System - BMS; Fan Coil Units
	Years: 2019
	Systems: Electric Domestic Water Heater; Packaged Air Cooled Chiller; Kitchen - Gas System; DX Split System for Elevator Machine Room 101 (1 of 2)
	Years: 2018
	Systems: MDF Room - Dedicated A/C Equipment (DX Split System); DX Split System for Telecom Room 316 (1 of 2)
	Years: 2016
	Systems: F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps
	Years: 2015

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Inspected
Absorption Chiller	Does not Exist
Air Cooled Chiller	Inspected
Instance	Cafeteria Roof Penthouse MER
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-22
Instance Manufacturer	Trane

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
AIR CONDITIONING	
Chilled Water System	
Air Cooled Chiller	
Equipment	Chiller #1
Capacity/Size Quantity	60
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1996
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	Cafeteria Roof Penthouse MER
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-22
Instance Manufacturer	Trane
Equipment	Chiller #1
Capacity/Size Quantity	60
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1996
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Air Cooled Condenser	Inspected
Instance	Cafeteria Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Trane
Equipment	N/A
Capacity/Size Quantity	60
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1996
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	Cafeteria Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Trane
Equipment	N/A
Capacity/Size Quantity	60
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1996
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Chilled Water Distribution: Piping, Pumps and Auxiliaries	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
AIR CONDITIONING	
Chilled Water System	
Chilled Water Distribution: Piping, Pumps and Auxiliaries	
Condition	2 - Between Good and Fair
Deficiency	PIPING: DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER B12, Cafeteria Roof Penthouse MER
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	PIPING: DEFECTIVE/LEAKS
Deficiency Location/Instance	3rd Floor Hallway near Room 307
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Backflow Preventer	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Central Station Air Handler	Inspected
Instance	Cafeteria Roof Penthouse MER
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Trane
Equipment	AHU #1
Capacity/Size Quantity	8
Capacity/Size UOM	Fan Motor HP
Source of Capacity/Size	Documented
Installation Year	1996
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	MER B12
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Trane
Equipment	AHU #2
Capacity/Size Quantity	15
Capacity/Size UOM	Fan Motor HP
Source of Capacity/Size	Inspector Estimate
Installation Year	1996
Source of Installation	Inspector Estimate

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
AIR CONDITIONING	
Chilled Water System	
Central Station Air Handler	
Deficiency	No deficiencies recorded
Instance	MER B12
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Trane
Equipment	AHU #3
Capacity/Size Quantity	10
Capacity/Size UOM	Fan Motor HP
Source of Capacity/Size	Inspector Estimate
Installation Year	1996
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Fan Coil Unit	Inspected
Condition	1 - Good
Deficiency	DEFECTIVE
Deficiency Location/Instance	Room 121
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Packaged Air Cooled Chiller	Inspected
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-410A
Instance Manufacturer	York
Equipment	N/A
Capacity/Size Quantity	150
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2018
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Water Cooled Chiller	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
AIR CONDITIONING	
DX Split System	Inspected
Outdoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Return Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Inspected
Instance	Throughout (Fan Coil Units)
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Installation Year	2019
Source of Installation	Documented
Deficiency	No deficiencies recorded
Pneumatic System	Inspected
Instance	Throughout (Except Fan Coil Units)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	PNEUMATIC TUBING:DEFECTIVE/LEAKS AIR
Deficiency Location/Instance	Room 221B
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Kitchen Storage Room 140G
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
CLIMATE CONTROL SYSTEM	Inspected
Pneumatic System	Inspected
Violations	No violations recorded.
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Inspected
Dumbwaiter	Does not Exist
Elevator	Inspected
Are all the existing elevators operable?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Inspected
Are all the existing ash hoists operable?	No
Condition	4 - Between Fair and Poor
Deficiency	No deficiencies recorded
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	MER B12 Crawlspace
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	MER B12 Crawlspace
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Room B1 (Domestic Main)
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Room B1 (Domestic Main)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Room B1 (Sprinkler Main)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Room B1 (Sprinkler Main)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Inspected
Condition	5 - Poor
Deficiency	DETERIORATED
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Electric Domestic Water Heater	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER B12 Crawlspace, Boiler Room
Deficiency Quantity	100
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sump Pump	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Medical Office Room 115A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Room B4
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
FIXTURES	
Staff And Other	Inspected
Urinal	
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Boys Toilet Room 210
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Girls Toilet Room 313
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Locker Room Shower	Inspected
Instance on 1st Floor - Boys	Inaccessible
Instance on 1st Floor - Girls	Inaccessible
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Girls Toilet Room 213
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Urinal	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
FIXTURES	Inspected
Student	Inspected
Urinal	
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Does not Exist
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	MER B12
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER B12
Deficiency Quantity	220
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
HEATING	
Steam Heating	
Steam Condensate Return Piping	
Deficiency Location/Instance	MER B12 Crawlspace, Basement Vestibule outside Room B1, Rooms B2, B4, B5, B7, B8
Deficiency Quantity	750
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Condensate Return Pumping System	
Condition	Inspected
Deficiency	3 - Fair
Deficiency	No deficiencies recorded
Steam Piping	
Condition	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement Vestibule outside Room B1
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Terminal Unit Thermostatic Trap	
Condition	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	2nd Floor Hallway near Elevator, Room 203, 3rd Floor Hallway near Room 306
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam supplied by External Sources	
Does not Exist	
Unit Heater/Cabinet Heater	
Inspected	
Condition	3 - Fair
Deficiency	No deficiencies recorded
HEATING PLANT	
Inspected	
Replacement Quantity	8,074
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Oil
Heating Plant Oil Number	4
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Preferred Utilities
Burner Model Number	HE6-3A4

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
HEATING PLANT	
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Does not Exist
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Does not Exist
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	50
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler System	Inspected
Instance on Basement	Inspected
Coal-fired Boiler	

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
HEATING PLANT	
Boiler System	
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	4,037
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Fitzgibbons Boiler Company
Equipment	47293-01
Capacity/Size Quantity	5,360
Capacity/Size UOM	Lbs/Hr steam
Source of Capacity/Size	Documented
Installation Year	1959
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	4,037
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Fitzgibbons Boiler Company
Equipment	47293-02
Capacity/Size Quantity	5,360
Capacity/Size UOM	Lbs/Hr steam
Source of Capacity/Size	Documented
Installation Year	1959
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fuel System	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
HEATING PLANT	
Fuel System	
Fuel Oil Storage/Supply System	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not Exist
Enclosed IDF Room	Inspected
Instance on Room 214	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 214	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 214
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
KITCHEN	Inspected
Instance on 1st Floor	Inspected
CO Detector	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas System	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Grease Trap	Does not Exist
Instance on 1st Floor	Does not Exist
Hood	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Does not Exist
Instance on 1st Floor	Does not Exist
Hot Water Temperature Booster	Does not Exist
Instance on 1st Floor	Does not Exist
Kitchen Sink	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
KITCHEN	Inspected
Kitchen Sink	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room inside Main Office 121	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room inside Main Office 121	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Does not Exist
Sprinkler Head	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Rooms B2, B3C (in Boiler Room), B5, B8, B11
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Room B1
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Partial

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K286

Question	Response
VENTILATION	
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED DUCTWORK
Deficiency Location/Instance	MER B12
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE REGISTER/DIFFUSER
Deficiency Location/Instance	Elevator Machine Room 101, Boys Toilet Room 210
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist