

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Asset: P.S. 327 (TANDEM K396-D75)-K, 111 BRISTOL STREET, New York, 11212

Inspection Id	Inspection Type	Time In	Last Edited
ME : K327	Mechanical	2023-11-16 8:03 AM	2024-06-12 12:12 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	2
Total capacity of all above ground tanks in gal.	20,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	MER B36
Are there any spaces with Missing or Defective CO Detectors?	Yes
Location(s)	Science Lab
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Rooms B31, B40, B44
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Heat Pump Domestic Water Heaters; Sump Pumps; Steam Condensate Return Pumping System
	Years: 2023
	Systems: Kitchen - Hood Exhaust Fan; Fixtures - Student: Lavatory/Sinks (18%), Toilets (20%), Urinals (27%)
	Years: 2022
	Systems: Kitchen - Grease Trap (1 of 2)
	Years: 2021
	Systems: Elevator; DX Split Systems for Elevator Machine Room and Camera Room 224 (2 of 2); Climate Control System - Pneumatic System: Refrigerated Air Dryer
	Years: 2020
	Systems: Refrigerant Leak Detection System
	Years: 2019
	Systems: Packaged Air Cooled Chiller; Chilled Water System Backflow Preventer; F&T/Steam Drip Traps (90%); Terminal Unit Thermostatic Traps
	Years: 2017
	Systems: Fixtures - Lavatory/Sinks (50%), Toilets (80%)
	Years: 2016
	Systems: MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2014

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
Yes	Defective Boiler Safety Auxiliary	Leaking Water Column Assembly - Missing Gasket	HEATING PLANT Boiler System Steam Boiler	Boiler Room/ Boiler #1	Stephen Martinez	Handyman	Sent to DSF	

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
AIR CONDITIONING	
Chilled Water System	
Absorption Chiller	Does not Exist
Air Cooled Chiller	Does not Exist
Air Cooled Condenser	Does not Exist
Chilled Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	3 - Fair
Deficiency	PIPING: DEFECTIVE VALVE
Deficiency Location/Instance	Corridor by Rooms 172, 354, 3rd Floor Exist A
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	PIPING: DEFECTIVE/LEAKS
Deficiency Location/Instance	Corridor by Room 367
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Backflow Preventer	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Central Station Air Handler	Does not Exist
Fan Coil Unit	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE MOISTURE DRAINAGE (BASIN & TUBING)
Deficiency Location/Instance	Rooms 162, 274, 354, 364, 365, 378, 374, 373
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Packaged Air Cooled Chiller	Inspected
Instance	K396 Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-410A
Instance Manufacturer	Trane
Equipment	N/A
Capacity/Size Quantity	120

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
AIR CONDITIONING	
Chilled Water System	
Packaged Air Cooled Chiller	
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	2017
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Water Cooled Chiller	
	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	
	Does not Exist
Cooling Coil in Ductwork	
	Does not Exist
Cooling Tower	
	Does not Exist
DX Split System	
	Inspected
Indoor Unit	
	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Outdoor Unit	
	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Dry Cooler	
	Does not Exist
Packaged / Rooftop Unit	
	Inspected
Instance	Auditorium Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	N/A
Refrigerant Type	R-22
Instance Manufacturer	Trane
Equipment	N/A
Capacity/Size Quantity	25
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	1999
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	Auditorium Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	N/A
Refrigerant Type	R-22
Instance Manufacturer	Trane
Equipment	N/A
Capacity/Size Quantity	40
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	1999
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Packaged Terminal A/C	
	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
AIR CONDITIONING	
Refrigerant Leak Detection System	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Refrigerant Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Throughout K327 and K396
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	61-80%
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Various Locations
Deficiency Quantity	40
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Inspected
Dumbwaiter	Inspected
Are all the existing dumbwaiters operable?	No
Condition	4 - Between Fair and Poor
Deficiency	No deficiencies recorded
Elevator	Inspected
Are all the existing elevators operable?	Yes
Condition	1 - Good
Deficiency	No deficiencies recorded
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Does not Exist
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	K396 Basement Crawlspace

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	K396 Basement Crawlspace
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Room B30
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Room B30
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Inspected
Condition	4 - Between Fair and Poor
Deficiency	TANK RUSTY/LEAKS
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	40
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Domestic Water Heat Exchanger	Inspected
Violations	No violations recorded.
Electric Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	2
Instance Quantity Uom	EACH
Instance Manufacturer	State Water Heaters
Equipment	Heater #1, Heater #2
Capacity/Size Quantity	12
Capacity/Size UOM	KW Input
Capacity/Size2 Quantity	119
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2023
Source of Installation	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	SEWAGE/WASTE PIPING: DEFECTIVE/LEAKS
Deficiency Location/Instance	Basement/ Corridor Boiler Room by B49
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sewage Ejector Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sump Pump	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
FIXTURES	
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Room 244
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Toilet	Inspected
Condition	1 - Good
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Room 232
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Room 255, 355
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Locker Room Shower	Inspected
Instance on 1st Floor	Inaccessible
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
FIXTURES	
Student	
Sink And Fountain Combo Unit	Inspected
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	1 - Good
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Room 216
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Urinal	
Condition	2 - Between Good and Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Room 222
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Does not Exist
HEATING	
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	RADIATOR/CONVECTOR: DEFECTIVE
Deficiency Location/Instance	K396 Roof Staircase D
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
HEATING	
Radiator/Convactor/Fin Tube	Inspected
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Does not Exist
HEATING PLANT	
Replacement Quantity	13,320
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Oil
Heating Plant Oil Number	4
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Ray Oil Burner
Burner Model Number	550
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Does not Exist
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Does not Exist
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler System	Inspected
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,750
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Pacific National
Equipment	52782-01
Capacity/Size Quantity	6,750
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1966
Source of Installation	Documented
Deficiency	RUSTED CASING
Deficiency Quantity	10
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	10
Quantity Uom	S.F.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE SAFETY AUXILIARY: LOW-WATER CUT-OFF, WATER COLUMN ASSEMBLY
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE AUXILIARY (GAUGES, GASKETS ETC.)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,570
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Pacific National
Equipment	52782-02
Capacity/Size Quantity	6,570
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1966
Source of Installation	Documented
Deficiency	RUSTED CASING
Deficiency Quantity	10
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	10
Quantity Uom	S.F.
Potential Action	REPLACE

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel System	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	OIL BURNER: DEFECTIVE
Deficiency Location/Instance	Boiler Room/ Boiler #1 - defective Nozzle
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	FUEL OIL LEVEL GAUGE: DEFECTIVE
Deficiency Location/Instance	Boiler Room/ Oil Storage Tank Room entrance
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 4
Deficiency Photo1	No photo recorded
Violations	11706210J
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not Exist
Enclosed IDF Room	
Instance on Room 245	Inspected
Dedicated A/C Equipment	
Instance on Room 245	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 245
Deficiency Quantity	1
Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
Enclosed IDF Room	
Dedicated A/C Equipment	
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas System	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Grease Trap	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Does not Exist
Instance on 1st Floor	Does not Exist
Hot Water Temperature Booster	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Kitchen Sink	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	MISSING AIR GAP
Deficiency Location/Instance	Kitchen
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
KITCHEN	
Kitchen Sink	
Violations	No violations recorded.
Deficiency	MISSING INDIRECT WASTE
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 4
Deficiency Photo1	No photo recorded
Violations	SF93511
MDF Room	Inspected
Instance on Room 218	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 218	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Inspected
Instance on Room 301	Inspected
Alternative use	No
Acid Waste Neutralizing Tank	Inspected
Instance on Room 301	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Inspected
Instance on Room 301	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/MISSING
Deficiency Location/Instance	Room 301
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Emergency Shower	Does not Exist
Instance on Room 301	Does not Exist
Eye Wash	Inspected
Instance on Room 301	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Does not Exist
Instance on Room 301	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Room 301	Does not Exist
Fixed Laboratory Hood	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
SCIENCE LAB	
Fixed Laboratory Hood	Does not Exist
Instance on Room 301	Does not Exist
Laboratory Sink	Inspected
Instance on Room 301	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 301	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Does not Exist
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Rooms B31, B40, B44
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	26-50
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Auditorium Roof, K396 Main Roof
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K327

Question	Response
VENTILATION	
Exhaust Fan	
Deficiency	DEFECTIVE CONTROLS
Deficiency Location/Instance	MER B36/ Auditorium Exhaust #37
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Heating And Ventilating Unit	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Metal Ductwork	
	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	No deficiencies recorded
Supply Fan	
	Inspected
Approximate Total # of Fans	1-5
Condition	3 - Fair
Deficiency	No deficiencies recorded
Unit Ventilator	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded