

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Asset: **P.S./I.S. 30 MARY WHITE OVINGTON - BROOKLYN, 7002 4TH AVENUE, New York, 11209**

Inspection Id	Inspection Type	Time In	Last Edited
ME : K331	Mechanical	2023-09-27 7:00 AM	2024-01-02 9:05 AM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	275
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Fire Booster Pump Assembly Room C01
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
Systems:	Boiler Make-up Water Backflow Preventer
Years:	2021

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No	Defective Kitchen Hood Fire Suppression System	The location of the nozzles of the fire suppression system do not match with the burners of the stove.	KITCHEN Hood Fire Suppression System	Kitchen	Daniel Durocher	Custodian	Sent to DSF	
Yes	Defective Sprinkler/Stand pipe System	Sprinkler heads obstructed and painted over.	SPRINKLERS, STANDPIPE, FIRE SYSTEM Sprinkler Head	Near corridor windows in Gymnasium 310, Auditorium 216 and Staff Lounge 111	Daniel Durocher	Custodian	Sent to DSF	

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	
Instance	Main Roof
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating Refrigerant Type	Gas R-410A
Instance Manufacturer	Seasons4
Equipment	RTU-1
Capacity/Size Quantity	48
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating Refrigerant Type	Gas R-410A
Instance Manufacturer	Seasons4
Equipment	RTU-2
Capacity/Size Quantity	38
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating Refrigerant Type	Gas R-410A
Instance Manufacturer	Seasons4
Equipment	RTU-3
Capacity/Size Quantity	49
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating Refrigerant Type	Gas R-410A
Instance Manufacturer	Seasons4

**NYC Department of Education
Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K331

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	
Equipment	RTU-4
Capacity/Size Quantity	93
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-410A
Instance Manufacturer	Seasons4
Equipment	RTU-5
Capacity/Size Quantity	107
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	OVER 20 TONS: DEFECTIVE CONDENSER FAN
Deficiency Location/Instance	Main Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	OVER 20 TONS: DEFECTIVE COMPRESSOR
Deficiency Location/Instance	Main Roof
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Main Roof
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-410A
Instance Manufacturer	Seasons4
Equipment	RTU- 6
Capacity/Size Quantity	108
Capacity/Size UOM	Tons

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	
Source of Capacity/Size	Inspector Estimate
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	
BMS	Inspected
Instance	Throughout
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Pneumatic System	Does not Exist
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	
Dumbwaiter	Does not Exist
Elevator	
Are all the existing elevators operable?	Yes
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Does not Exist
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Gravity System	Does not Exist
Pressure Booster System	
Electric Pressure Booster System	
Instance	Water Meter Room C24
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Liquitrol

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Pressure Booster System	
Electric Pressure Booster System	
Equipment	N/A
Capacity/Size Quantity	2
Capacity/Size UOM	Total # Pumps
Capacity/Size2 Quantity	20
Capacity/Size2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Hydraulic/Pneumatic Booster System	Does not Exist
Water Service	Inspected
Instance	Water Meter Room C24
Instance Condition	1 - Good
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Valve/Meter Room C16
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Penthouse - Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Laars
Equipment	N/A
Capacity/Size Quantity	300
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	0
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Question	Response
DOMESTIC WATER SYSTEM	Inspected
Domestic Water Distribution Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Sump Pump	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Staff Toilet Rooms 104, 212, 418
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Question	Response
FIXTURES	
Student	
Drinking Fountain	Inspected
Violations	No violations recorded.
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Boys Toilet Rooms C04D, 126A, 224, 310D, Girls Toilet Rooms C04D, 304, 310E
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Question	Response
HEATING	
Hydronic Heating	
Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Backflow Preventer	Does not Exist
Hot Water Heat Exchanger	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Steam Heating	Does not Exist
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
HEATING PLANT	
Replacement Quantity	2,086
Replacement Uom	MBH Net
Instance on Penthouse	Inspected
Burner Type	Gas
Heating Plant Oil Number	N/A
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	No
Boiler Auxiliaries	Inspected
Instance on Penthouse	Inspected
Boiler Auxiliary Piping	
Instance on Penthouse	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Penthouse	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Penthouse	Does not Exist
Boiler Feedwater Treatment(Automatic)	
Instance on Penthouse	Does not Exist
Boiler Flue Exhaust	
Instance on Penthouse	Does not Exist
Boiler Make-up Water Backflow Preventer	
Instance on Penthouse	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Penthouse	Does not Exist
Boiler Safety Valve	
Instance on Penthouse	Does not Exist
Boiler System	Inspected
Instance on Penthouse	Inspected
Coal-fired Boiler	

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Question	Response
HEATING PLANT	
Boiler System	
Coal-fired Boiler	
Instance on Penthouse	Does not Exist
Hot Water Boiler	
Instance on Penthouse	Does not Exist
Modular Boiler	
Instance on Penthouse	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1,043
Instance Quantity Uom	MBH Net
Instance Manufacturer	AERCO
Equipment	164411-01
Capacity/Size Quantity	1,500
Capacity/Size UOM	MBH Input
Source of Capacity/Size	Documented
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1,043
Instance Quantity Uom	MBH Net
Instance Manufacturer	AERCO
Equipment	164411-02
Capacity/Size Quantity	1,500
Capacity/Size UOM	MBH Input
Source of Capacity/Size	Documented
Installation Year	2013
Source of Installation	Documented
Deficiency	No deficiencies recorded
Steam Boiler	
Instance on Penthouse	Does not Exist
Fuel System	
Instance on Penthouse	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Penthouse	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Penthouse	Does not Exist
Fuel Oil Storage/Supply System	
Instance on Penthouse	Does not Exist
Gas Trains And Vent At The Boiler	
Instance on Penthouse	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Question	Response
Enclosed IDF Room	Inspected
Instance on Rooms C10, 108, 312, 410	Inspected
Dedicated A/C Equipment	Inspected
Instance on Rooms C10, 108, 312, 410	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
KITCHEN	Inspected
Instance on Basement	Inspected
CO Detector	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas System	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Grease Trap	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Kitchen (The location of the nozzles of the fire suppression system do not match with the burners of the stove)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hot Water Temperature Booster	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Kitchen Sink	Inspected
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Question	Response
KITCHEN	Inspected
Kitchen Sink	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room 210	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 210	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Inspected
Instance on Room 321	Inspected
Alternative use	No
Acid Waste Neutralizing Tank	Inspected
Instance on Room 321	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Not Required
Instance on Room 321	Not Required
Emergency Shower	Does not Exist
Instance on Room 321	Does not Exist
Eye Wash	Inspected
Instance on Room 321	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Does not Exist
Instance on Room 321	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Room 321	Does not Exist
Fixed Laboratory Hood	Does not Exist
Instance on Room 321	Does not Exist
Laboratory Sink	Inspected
Instance on Room 321	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 321	Does not Exist
SCIENCE PREP ROOM	Inspected
Instance on Room 321A	Inspected
Alternative use	No
Acid Waste Neutralizing Tank	Does not Exist
Instance on Room 321A	Does not Exist
CO Detector	Not Required
Instance on Room 321A	Not Required
Emergency Shower	Does not Exist
Instance on Room 321A	Does not Exist
Eye Wash	Does not Exist
Instance on Room 321A	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Question	Response
SCIENCE PREP ROOM	
Hood Exhaust Ductwork	Does not Exist
Instance on Room 321A	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Room 321A	Does not Exist
Fixed Laboratory Hood	Does not Exist
Instance on Room 321A	Does not Exist
Laboratory Sink	Inspected
Instance on Room 321A	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 321A	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Does not Exist
Fire Booster Pump Assembly	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Roof Tank	Does not Exist
Siamese Connection	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Sprinkler Head	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Near corridor windows in Gymnasium 310, Auditorium 216 and Staff Lounge 111 (sprinkler heads obstructed and painted over)
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Standpipe System	Inspected
Hose Valve Assembly	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Water Gong	Does not Exist
SWIMMING POOL	
Does not Exist	
VENTILATION	
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K331

Question	Response
VENTILATION	
Exhaust Fan	
Approximate Total # of Fans	1-25
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Roof (TEF-3, Balance)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	1 - Good
Deficiency	DEFECTIVE REGISTER/DIFFUSER
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Supply Fan	Inspected
Approximate Total # of Fans	1-5
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Unit Ventilator	Does not Exist