

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Asset: P.S. 516 SUNSET PARK AVENUES ELEMENTARY SCHOOL - BROOKLYN, 4222 4TH AVENUE, New York, 11232

Inspection Id	Inspection Type	Time In	Last Edited
EE : K333	Electrical	2024-01-09 8:25 AM	2024-01-29 1:25 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Fire Alarm System (CO Detectors)
	Years: 2020
	Systems: All Other Electrical Systems and Components
	Years: 2014

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	Yes
Are all dedicated intercoms operational?	Yes

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No	Water Leaks onto Electrical Equipment	N/A	Switchboard	Electrical Room	Robert Meehan	Custodian	Sent to DSF	

Inspection

Question	Response
Electrical	
AUDITORIUM	Does not Exist
CAFETERIA	Inspected
Instance on Basement	Inspected
Lighting	Inspected
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	Does not Exist
Instance on Basement	Does not Exist
Surface Mounted	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	Does not Exist
Instance on Basement	Does not Exist
Lighting Fixture - HID	
Instance on Basement	Does not Exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not Exist
Lighting Fixture - LED	
Instance on Basement	Does not Exist
Local Sound System	
	Inspected
Instance on Basement	Inspected
Installation Year	2014
Source of Installation	Documented
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	
	Does not Exist
Instance on Basement	Does not Exist
Theater Lighting System	
	Does not Exist
Instance on Basement	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
	Inspected
Lighting	
	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	
	Inspected
Pendant Mounted	
	Inspected
Condition	2 - Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Surface Mounted	
	Inspected
Condition	2 - Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Recessed Mounted	
	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
COMPUTER LAB	Does not Exist
GYMNASIUM	Does not Exist
KITCHEN	Inspected
Instance on Basement	Inspected
Lighting	Inspected
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	Does not Exist
Instance on Basement	Does not Exist
Surface Mounted	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Instance on Basement	Does not Exist
Lighting Fixture - HID	
Instance on Basement	Does not Exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not Exist
Lighting Fixture - LED	
Instance on Basement	Does not Exist
LIBRARY	Inspected
Instance on Room 318A	Inspected
Lighting	Inspected
Instance on Room 318A	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 318A	Inspected
Pendant Mounted	Inspected
Instance on Room 318A	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not Exist
Instance on Room 318A	Does not Exist
Recessed Mounted	Does not Exist
Instance on Room 318A	Does not Exist
Lighting Fixture - HID	
Instance on Room 318A	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 318A	Does not Exist
Lighting Fixture - LED	
Instance on Room 318A	Does not Exist
Raceway With Receptacles	Inspected
Instance on Room 318A	Inspected
Condition	2 - Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
LIBRARY	Inspected
Raceway With Receptacles	Inspected
Deficiency	No deficiencies recorded
Projection System	Does not Exist
Instance on Room 318A	Does not Exist
LOCKER ROOM	Does not Exist
MULTIPURPOSE ROOM	Inspected
Instance on 1st Floor	Inspected
Lighting	Inspected
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Surface Mounted	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Lighting Fixture - HID	
Instance on 1st Floor	Inspected
Pendant Mounted	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Surface Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Recessed Mounted	Does not Exist
Instance on 1st Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - LED	

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
MULTIPURPOSE ROOM	
Lighting	Inspected
Lighting Fixture - LED	
Instance on 1st Floor	Does not Exist
Local Sound System	Inspected
Instance on 1st Floor	Inspected
Installation Year	2014
Source of Installation	Documented
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	Inspected
Is the projector on a cart or installed on the ceiling?	Ceiling
Instance on 1st Floor	Inspected
Condition	4 - Between Fair and Poor
Deficiency	VIDEO PROJECTOR IS NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Theater Lighting System	Inspected
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Inspected
Instance on Room 410	Inspected
Power Panel	Yes
Alternative use	No
Lighting	Inspected
Instance on Room 410	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 410	Inspected
Pendant Mounted	Inspected
Instance on Room 410	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Does not Exist
Instance on Room 410	Does not Exist
Recessed Mounted	Does not Exist
Instance on Room 410	Does not Exist
Lighting Fixture - HID	

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - HID	
Instance on Room 410	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 410	Inspected
Pendant Mounted	Does not Exist
Instance on Room 410	Does not Exist
Surface Mounted	Inspected
Instance on Room 410	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Instance on Room 410	Does not Exist
Lighting Fixture - LED	
Instance on Room 410	Does not Exist
Emergency Gas Shut-Off Valve	Does not Exist
Instance on Room 410	Does not Exist
Emergency Shut-Off Power	Inspected
Instance on Room 410	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Power Supply	Does not Exist
Instance on Room 410	Does not Exist
Projection System	Does not Exist
Instance on Room 410	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SWIMMING POOL	Does not Exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Replacement Quantity	62,000
Replacement Uom	S.F.
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	2 - Between Good and Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Multipurpose Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 4
Deficiency Photo1	No photo recorded
Violations	35663153X
Non Battery Pack	Does not Exist
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not Exist
EXIT/EMERGENCY LIGHT	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	62,000
Replacement Uom	S.F.
Bell/Horn	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	2 - Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
FIRE ALARM SYSTEM	
Strobe	Inspected
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Heat Detector	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Fused Cutout Panel	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not Exist
Main Panel	Inspected
Bell At Panel	Does not Exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Edwards System Technology
Equipment	Fire Alarm Control Panel
Model	EST 3
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Exit 6 Vestibule - By Multipurpose Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Edwards System Technology
Equipment	Fire Alarm Control Panel

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Electronic)	Inspected
Model	EST 3
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not Exist
Sub-Panel	Does not Exist
Remote Annunciator	Inspected
Display Monitor	Does not Exist
Panel	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not Exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	
Elevator	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Holding Area	Does not Exist
LAN	
Local Distribution Frame (I/LDF)	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	
MOTOR CONTROLLER	
Motor Control Center	Does not Exist
Motor Starter/Contactor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Does not Exist
PANEL BOARD	
Fused Disconnect Switch Type	Does not Exist
Fused Knife Switch Type	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
PANEL BOARD	
Fused Toggle Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Inspected
Condition	2 - Between Good and Fair
Deficiency	PANEL BOARD COVER IS MISSING
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
PUBLIC ADDRESS SYSTEM	
Replacement Quantity	62,000
Replacement Uom	S.F.
Instance	Telecom Room 211
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland Telecenter
Installation Year	2014
Source of Installation	Documented
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Classrooms and Corridors
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
SECURITY	
	Inspected
IPDVS/CCTV System	
	Inspected
Replacement Quantity	62,000
Replacement Uom	S.F.
Installation Year	2014
Source of Installation	Documented
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Intrusion Alarm System	
	Inspected
Replacement Quantity	62,000
Replacement Uom	S.F.
Central Control Panel	
	Inspected
Instance	Custodian's Office
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista-128BP

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
SECURITY	
Intrusion Alarm System	
Central Control Panel	Inspected
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	2 - Between Good and Fair
Deficiency	SENSOR NOT OPERATIONAL
Deficiency Location/Instance	Corridor by (Principal Office, Room 318A), Telecom Room 211
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Panic Switch	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lighting - Security	Inspected
Replacement Uom	EACH
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Exterior Walls - Building Perimeter
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 3
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Location/Instance	Exterior Walls - Building Perimeter
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 3
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
SERVICE SWITCH	Inspected
Instance	Electrical Room
Instance Condition	2 - Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
SERVICE SWITCH	
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	All City Switchboard
Equipment	Service Switch #2
Capacity/Size Quantity	1,200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Eaton
Equipment	Fire Pump Disconnect
Capacity/Size Quantity	1,200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Electrotech
Equipment	MSS-1
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	All City Switchboard
Equipment	Service Switch #5
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	2 - Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
SERVICE SWITCH	
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Electrotech
Equipment	MSS-3 CHURCH/RECTORY/CONVENT
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	
	Inspected
Number of Spares	14
Fused Disconnect Switch Type	
	Inspected
Instance	Electrical Closet - Room 228 (Inside Telecom Room)
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	All City Switchboard
Equipment	DP-C
Capacity/Size Quantity	800
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Closet - Room 307
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Lincoln Electric Co.
Equipment	MSWB-2
Capacity/Size Quantity	1,200
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Lincoln Electric Co.
Equipment	MSWB-1
Capacity/Size Quantity	600

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K333

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Lincoln Electric Co.
Equipment	MSWB-3
Capacity/Size Quantity	600
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Does not Exist
TELEPHONE SYSTEM	
PBX/Intercom	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not Exist