

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Asset: P.S. 346 - BROOKLYN, 1400 PENNSYLVANIA AVENUE, New York, 11239

Inspection Id	Inspection Type	Time In	Last Edited
ME : K346	Mechanical	2023-12-06 8:17 AM	2023-12-14 4:09 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	2
Total capacity of all above ground tanks in gal.	15,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	MER B1
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps
	Years: 2021
	Systems: Electric Domestic Water Heater in Kitchen (1 of 2)
	Years: 2020
	Systems: Boiler Make-up Water Backflow Preventer
	Years: 2019
	Systems: Elevator
	Years: 2017
	Systems: DX Split System for Elevator Machine Room; Climate Control System - Pneumatic System: Temperature Control Thermostats; Fixtures - Toilets, Urinals
	Years: 2016
	Systems: Climate Control System - Pneumatic System: Air Compressor; Unit Heater/Cabinet Heater
	Years: 2014
	Systems: Electric Domestic Water Heater in Boiler Room (1 of 2); Boiler Safety Valves
	Years: 2013

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
Yes	Defective Boiler Safety Auxiliary	Missing Knob on tricock valve	HEATING PLANT Boiler System Steam Boiler	Boiler Room / Boiler #1	George Donate	Fireman	Sent to DSF	

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Inspected
Absorption Chiller	Does not Exist
Air Cooled Chiller	Inspected
Instance	MER B1
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
AIR CONDITIONING	
Chilled Water System	
Air Cooled Chiller	
Refrigerant Type	R-407C
Instance Manufacturer	York
Equipment	#1
Capacity/Size Quantity	75
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1975
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	MER B1
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-22
Instance Manufacturer	York
Equipment	#2
Capacity/Size Quantity	75
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1975
Source of Installation	Documented
Deficiency	No deficiencies recorded
Air Cooled Condenser	Inspected
Instance	Auditorium Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	N/A
Equipment	N/A
Capacity/Size Quantity	75
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1975
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Auditorium Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	N/A
Equipment	N/A
Capacity/Size Quantity	75
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1975
Source of Installation	Documented

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
AIR CONDITIONING	
Chilled Water System	
Air Cooled Condenser	Inspected
Deficiency	No deficiencies recorded
Chilled Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Backflow Preventer	Does not Exist
Central Station Air Handler	Inspected
Instance	MER B1
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	American Air Filter
Equipment	L. R. & Assy Blower 13
Capacity/Size Quantity	15
Capacity/Size UOM	Fan Motor HP
Source of Capacity/Size	Documented
Installation Year	1975
Source of Installation	Documented
Deficiency	DEFECTIVE COIL
Deficiency Location/Instance	MER B1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	MER B1
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	American Air Filter
Equipment	Blower II
Capacity/Size Quantity	5
Capacity/Size UOM	Fan Motor HP
Source of Capacity/Size	Documented
Installation Year	1975
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fan Coil Unit	Does not Exist
Packaged Air Cooled Chiller	Does not Exist
Water Cooled Chiller	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
AIR CONDITIONING	
DX Split System	
Indoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Return Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	61-80%
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Various Classrooms
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hybrid System	Does not Exist
Electric System	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
COMPACTOR	Inspected
Condition	3 - Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Room B12
Deficiency Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
COMPACTOR	
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
CONVEYING	
	Inspected
Dumbwaiter	Does not Exist
Elevator	Inspected
Are all the existing elevators operable?	Yes
Condition	1 - Good
Deficiency	No deficiencies recorded
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Does not Exist
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	
	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Cafeteria Crawlspace
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Cafeteria Crawlspace
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Room B4
Instance Condition	3 - Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Room B4
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	Inspected
Water Service	Inspected
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Electric Domestic Water Heater	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	SEWAGE/WASTE PIPING: DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room, Corridor outside Room 137, Toilet Rooms 206, 306, 406
Deficiency Quantity	50
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sewage Ejector Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sump Pump	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	
Dual Temperature Distribution: Piping, Pumps and	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Dual Temperature Terminal Fan Coil Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Toilet Room 109
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE FLUSHOMETER VALVE
Deficiency Location/Instance	Toilet Room 109
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Urinal	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Boys Toilet Room 206
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
FIXTURES	
Student	
Lavatory/Sink	Inspected
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Does not Exist
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Does not Exist
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Inspected
Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Backflow Preventer	Does not Exist
Hot Water Heat Exchanger	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
HEATING	
Steam Heating	
Steam Condensate Return Piping	Inspected
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE PUMP
Deficiency Location/Instance	MER B1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Corridor adjacent to Room B4
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Terminal Unit Thermostatic Trap	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
HEATING PLANT	
Replacement Quantity	12,028
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Oil
Heating Plant Oil Number	2
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Preferred Utilities
Burner Model Number	BHE 7 3 4 A
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Emergency Stop Switch	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Does not Exist
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,014
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Federal Boiler Company
Equipment	66088-01
Capacity/Size Quantity	6,014
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1975
Source of Installation	Documented

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Deficiency	DEFECTIVE SAFETY AUXILIARY: LOW-WATER CUT-OFF, WATER COLUMN ASSEMBLY
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED REFRACTORY
Deficiency Quantity	20
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,014
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Federal Boiler Company
Equipment	66088-02
Capacity/Size Quantity	6,014
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1975
Source of Installation	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED REFRACTORY

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Deficiency Quantity	20
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel System	
	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	OIL BURNER: DEFECTIVE
Deficiency Location/Instance	Boiler #2 / Oil Leak
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not Exist
Enclosed IDF Room	
	Inspected
Instance on Rooms 197, 202, 232, 402	Inspected
Dedicated A/C Equipment	
	Inspected
Instance on Rooms 197, 202, 232, 402	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Rooms 197, 202, 232, 402
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
KITCHEN	Inspected
Instance on 1st Floor	Inspected
CO Detector	Not Required
Instance on 1st Floor	Not Required
Gas System	Does not Exist
Instance on 1st Floor	Does not Exist
Grease Trap	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Does not Exist
Instance on 1st Floor	Does not Exist
Hot Water Temperature Booster	Does not Exist
Instance on 1st Floor	Does not Exist
Kitchen Sink	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room 432	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 432	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Inspected
Instance on Room 420	Inspected
Alternative use	No
Acid Waste Neutralizing Tank	Inspected
Instance on Room 420	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	Not Required
Instance on Room 420	Not Required
Emergency Shower	Does not Exist
Instance on Room 420	Does not Exist
Eye Wash	Inspected
Instance on Room 420	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
SCIENCE LAB	
Eye Wash	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Does not Exist
Instance on Room 420	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Room 420	Does not Exist
Fixed Laboratory Hood	Does not Exist
Instance on Room 420	Does not Exist
Laboratory Sink	Inspected
Instance on Room 420	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 420	Does not Exist
SCIENCE PREP ROOM	
Instance on Room 319A	Inspected
Alternative use	No
Acid Waste Neutralizing Tank	Does not Exist
Instance on Room 319A	Does not Exist
CO Detector	Not Required
Instance on Room 319A	Not Required
Emergency Shower	Does not Exist
Instance on Room 319A	Does not Exist
Eye Wash	Does not Exist
Instance on Room 319A	Does not Exist
Hood Exhaust Ductwork	Does not Exist
Instance on Room 319A	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Room 319A	Does not Exist
Fixed Laboratory Hood	Does not Exist
Instance on Room 319A	Does not Exist
Laboratory Sink	Inspected
Instance on Room 319A	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 319A	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K346

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standpipe System	Inspected
Hose Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Partial
Exhaust Fan	Inspected
Approximate Total # of Fans	26-50
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	No deficiencies recorded
Supply Fan	Inspected
Approximate Total # of Fans	1-5
Condition	3 - Fair
Deficiency	No deficiencies recorded
Unit Ventilator	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded