

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K407

Asset: MIDWOOD AF NO. 2 - BROOKLYN, 2839 BEDFORD AVENUE, New York, 11210

Inspection Id	Inspection Type	Time In	Last Edited
EE : K407	Electrical	2024-01-02 8:06 AM	2024-01-16 10:47 AM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	No
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	No
DEDICATED INTERCOMS IN FIRE RESCUE AREAS	
Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	Photo/Image
No condition recorded								

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Inspected
Exterior Lighting	Does not Exist
Local Sound System	Does not Exist
Scoreboard	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Does not Exist
LOCKER ROOM	Does not Exist
TOILET ROOM - STAFF	Does not Exist
TOILET ROOM - STUDENT	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Does not Exist
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Does not Exist
EXIT LIGHT	Does not Exist
EXIT/EMERGENCY LIGHT	Does not Exist
FIRE ALARM SYSTEM	Does not Exist
GROUNDING SYSTEM	Does not Exist
LAN	Does not Exist
LIGHTNING PROTECTION	Does not Exist
MOTOR CONTROLLER	Does not Exist
PANEL BOARD	Does not Exist
PUBLIC ADDRESS SYSTEM	Does not Exist
SECURITY	Does not Exist
SERVICE SWITCH	Does not Exist
SWITCHBOARD	Does not Exist
TELEPHONE SYSTEM	Does not Exist
TRANSFORMER	Does not Exist