

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K672

Asset: **PRE-K CENTER @ 1223 CONEY ISLAND AVENUE - BROOKLYN, 1223 CONEY ISLAND AVENUE, New York, 11230**

Inspection Id	Inspection Type	Time In	Last Edited
ME : K672	Mechanical	2024-03-28 11:48 AM	2024-04-04 4:56 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No	Defective Fire/Smoke Damper	Fire and Smoke Damper Failed in Closed Position	VENTILATION   Metal Ductwork	Room 115	Leon Whitehurst	Handyman	Sent to DSF	

Inspection

Question	Response
<b>Mechanical</b>	
<b>AIR CONDITIONING</b>	Inspected
<b>Chilled Water System</b>	Does not Exist
<b>Condenser Water Distribution: Piping, Pumps and Auxiliaries</b>	Does not Exist
<b>Cooling Coil in Ductwork</b>	Does not Exist
<b>Cooling Tower</b>	Does not Exist
<b>DX Split System</b>	Does not Exist
<b>Dry Cooler</b>	Does not Exist
<b>Packaged / Rooftop Unit</b>	Inspected
Instance	Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating Refrigerant Type	Gas R-410A
Instance Manufacturer	Trane
Equipment	AC-1
Capacity/Size Quantity	25
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	2016
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Packaged Terminal A/C</b>	Does not Exist
<b>Refrigerant Leak Detection System</b>	Does not Exist
<b>Refrigerant Piping</b>	Does not Exist
<b>Return Fan</b>	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K672

<b>Question</b>	<b>Response</b>
<b>CENTRAL ACID WASTE NEUTRALIZING TANK</b>	Does not Exist
<b>CLIMATE CONTROL SYSTEM</b>	Inspected
<b>BMS</b>	Does not Exist
<b>Pneumatic System</b>	Does not Exist
<b>Hybrid System</b>	Does not Exist
<b>Electric System</b>	Inspected
Instance	Offices and Main Entrance
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
<b>COMPACTOR</b>	Does not Exist
<b>CONVEYING</b>	Does not Exist
<b>DOMESTIC WATER SYSTEM</b>	Inspected
<b>Domestic Cold Water System</b>	Inspected
<b>Gravity System</b>	Does not Exist
<b>Pressure Booster System</b>	Does not Exist
<b>Water Service</b>	Inspected
Instance	Gas Meter Room
Instance Condition	1 - Good
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Gas Meter Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
<b>Domestic Hot Water System</b>	Inspected
<b>Domestic Hot Water Remote Storage Tank</b>	Does not Exist
<b>Domestic Water Heat Exchanger</b>	Does not Exist
<b>Electric Domestic Water Heater</b>	Does not Exist
<b>Heat Pump Domestic Water Heater</b>	Does not Exist
<b>Gas Fired Domestic Water Heater</b>	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Laars
Equipment	N/A
Capacity/Size Quantity	125
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	60
Capacity/Size2 UOM	Gallons

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K672

Question	Response
<b>DOMESTIC WATER SYSTEM</b>	
<b>Domestic Hot Water System</b>	
<b>Gas Fired Domestic Water Heater</b>	
Source of Capacity/Size	Documented
Installation Year	2016
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Oil Fired Domestic Water Heater</b>	Does not Exist
<b>Domestic Water Distribution Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>DRAIN/WASTE/VENT AND STORM SYSTEM</b>	
<b>Interior Storm Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Sewage/Waste/Vent Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Sewage Ejector Pump</b>	Does not Exist
<b>Sump Pump</b>	Does not Exist
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	Does not Exist
<b>FIXTURES</b>	Inspected
<b>Staff And Other</b>	Inspected
<b>Janitor Sink</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Toilet</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Urinal</b>	Does not Exist
<b>Student</b>	Inspected
<b>Drinking Fountain</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Toilet Room 122
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Locker Room Shower</b>	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K672

Question	Response
<b>FIXTURES</b>	
<b>Student</b>	
<b>Sink And Fountain Combo Unit</b>	Does not Exist
<b>Toilet</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Urinal</b>	Does not Exist
<b>GAS FIRED FURNACE</b>	Does not Exist
<b>GAS SERVICE</b>	Inspected
<b>Gas Distribution Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Gas Meter Room Exhaust Fan</b>	Does not Exist
<b>Gas Meter Room Vent</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Gas Pressure Booster</b>	Inspected
Instance	Roof
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Accardi
Equipment	N/A
Capacity/Size Quantity	1
Capacity/Size UOM	HP
Source of Capacity/Size	Documented
Installation Year	2016
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>CO/Gas Leak Detection</b>	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2016
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>HEATING</b>	Inspected
<b>Heating Coil In Ductwork</b>	Does not Exist
<b>Hydronic Heating</b>	Inspected
<b>Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Backflow Preventer</b>	Does not Exist
<b>Hot Water Heat Exchanger</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Radiator/Convactor/Fin Tube</b>	Inspected
Condition	1 - Good

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K672

Question	Response
<b>HEATING</b>	
<b>Radiator/Convactor/Fin Tube</b>	Inspected
Deficiency	No deficiencies recorded
<b>Steam Heating</b>	Does not Exist
<b>Steam supplied by External Sources</b>	Does not Exist
<b>Unit Heater/Cabinet Heater</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>HEATING PLANT</b>	
Replacement Quantity	183
Replacement Uom	MBH Net
Instance on 1st Floor	Inspected
Burner Type	Gas
Heating Plant Oil Number	N/A
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	No
<b>Boiler Auxiliaries</b>	Inspected
Instance on 1st Floor	Inspected
<b>Boiler Auxiliary Piping</b>	
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Boiler Emergency Stop Switch</b>	
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Boiler Feedwater System</b>	
Instance on 1st Floor	Does not Exist
<b>Boiler Feedwater Treatment(Automatic)</b>	
Instance on 1st Floor	Does not Exist
<b>Boiler Flue Exhaust</b>	
Instance on 1st Floor	Does not Exist
<b>Boiler Make-up Water Backflow Preventer</b>	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Boiler Room Steam And Condensate Piping</b>	
Instance on 1st Floor	Does not Exist
<b>Boiler Safety Valve</b>	
Instance on 1st Floor	Does not Exist
<b>Boiler System</b>	Inspected
Instance on 1st Floor	Inspected
<b>Coal-fired Boiler</b>	
Instance on 1st Floor	Does not Exist
<b>Hot Water Boiler</b>	
Instance on 1st Floor	Does not Exist
<b>Modular Boiler</b>	
Instance on 1st Floor	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K672

Question	Response
<b>HEATING PLANT</b>	
<b>Boiler System</b>	
<b>Modular Boiler</b>	
Instance Quantity	183
Instance Quantity Uom	MBH Net
Instance Manufacturer	Weil-McLain
Equipment	202996-01
Capacity/Size Quantity	183
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2016
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Steam Boiler</b>	
Instance on 1st Floor	Does not Exist
<b>Fuel System</b>	
Instance on 1st Floor	Inspected
<b>Boiler Fresh Air Louver/Damper</b>	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Fixed Louver
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Burner/Burner Control Panel</b>	
Instance on 1st Floor	Does not Exist
<b>Fuel Oil Storage/Supply System</b>	
Instance on 1st Floor	Does not Exist
<b>Gas Trains And Vent At The Boiler</b>	
Instance on 1st Floor	Does not Exist
<b>Enclosed IDF Room</b>	
	Does not Exist
<b>KITCHEN</b>	
Instance on 1st Floor	Inspected
<b>CO Detector</b>	
Instance on 1st Floor	Not Required
<b>Gas System</b>	
Instance on 1st Floor	Does not Exist
<b>Grease Trap</b>	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood</b>	
Instance on 1st Floor	Does not Exist
<b>Hood Exhaust Ductwork</b>	
Instance on 1st Floor	Does not Exist
<b>Hood Exhaust Fan</b>	
Instance on 1st Floor	Does not Exist
<b>Hood Fire Suppression System</b>	
Instance on 1st Floor	Does not Exist
<b>Hot Water Temperature Booster</b>	
	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K672

Question	Response
<b>KITCHEN</b>	
<b>Hot Water Temperature Booster</b>	Does not Exist
Instance on 1st Floor	Does not Exist
<b>Kitchen Sink</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>MDF Room</b>	Inspected
Instance on Room 124	Inspected
<b>Dedicated A/C Equipment</b>	Inspected
Instance on Room 124	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	Does not Exist
<b>SCIENCE LAB</b>	Does not Exist
<b>SCIENCE PREP ROOM</b>	Does not Exist
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	Inspected
<b>Dry Sprinkler Alarm Valve Assembly</b>	Does not Exist
<b>Wet Sprinkler Alarm Valve Assembly</b>	Does not Exist
<b>Fire Booster Pump Assembly</b>	Does not Exist
<b>Roof Tank</b>	Does not Exist
<b>Siamese Connection</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Sprinkler Head</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Sprinkler Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Standpipe System</b>	Does not Exist
<b>Water Gong</b>	Does not Exist
<b>SWIMMING POOL</b>	Does not Exist
<b>VENTILATION</b>	Inspected
Is the building mechanically ventilated?	Yes
<b>Exhaust Fan</b>	Inspected
Approximate Total # of Fans	1-25
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Heating And Ventilating Unit</b>	Does not Exist
<b>Metal Ductwork</b>	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	1 - Good
Deficiency	DEFECTIVE FIRE/SMOKE DAMPER
Deficiency Location/Instance	Room 115
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K672

Question	Response
<b>VENTILATION</b>	
<b>Metal Ductwork</b>	
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Supply Fan</b>	Does not Exist
<b>Unit Ventilator</b>	Does not Exist