

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K860

Asset: P.S. 219 ANNEX - BROOKLYN, 9517 KINGS HIGHWAY, New York, 11212

Inspection Id	Inspection Type	Time In	Last Edited
ME : K860	Mechanical	2024-04-30 12:48 PM	2024-05-08 12:19 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	Cafeteria MER
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Exhaust Fans
	Years: 2022
	Systems: Water Service
	Years: 2019
	Systems: Unit Heater/Cabinet Heater, MDF Room-Dedicated A/C Equipment (DX Split System)
	Years: 2018
	Systems: Gas Fired Domestic Water Heater
	Years: 2015

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Inspected
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	N/A
Equipment	N/A
Capacity/Size Quantity	40
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1971
Source of Installation	Inspector Estimate
Deficiency	UP TO 150 TONS: NOT IN USE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K860

Question	Response
AIR CONDITIONING	
Cooling Tower	
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DX Split System	
	Inspected
Indoor Unit	
	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Outdoor Unit	
	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Dry Cooler	
	Does not Exist
Packaged / Rooftop Unit	
	Inspected
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-22
Instance Manufacturer	Trane
Equipment	N/A
Capacity/Size Quantity	35
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2005
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-22
Instance Manufacturer	York
Equipment	N/A
Capacity/Size Quantity	10
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2004
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	4 - Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-22
Instance Manufacturer	York
Equipment	N/A
Capacity/Size Quantity	18

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K860

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1999
Source of Installation	Inspector Estimate
Deficiency	UP TO 20 TONS: DEFECTIVE COIL - EVAP
Deficiency Location/Instance	Main Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	N/A
Refrigerant Type	R-22
Instance Manufacturer	Typhoon
Equipment	N/A
Capacity/Size Quantity	10
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1971
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Return Fan	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Basement Water Meter Room
Instance Condition	1 - Good
Instance Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K860

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	Inspected
Water Service	Inspected
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	A.O. Smith
Equipment	N/A
Capacity/Size Quantity	75
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	74
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	SEWAGE/WASTE PIPING: DEFECTIVE/LEAKS
Deficiency Location/Instance	Womens Toilet Room 219
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT)	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K860

Question	Response
WATER)	
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Staff Toilet Room in Room 216
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Basement Mens Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Does not Exist
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K860

Question	Response
GAS SERVICE	
Gas Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Does not Exist
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Under Construction
HEATING	
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Inspected
Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Backflow Preventer	Does not Exist
Hot Water Heat Exchanger	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Does not Exist
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Staff Toilet Room in Room 216
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
HEATING PLANT	
Replacement Uom	MBH Net
Instance on Basement	Under Construction
Enclosed IDF Room	Does not Exist
KITCHEN	
Instance on Basement	Inspected
CO Detector	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas System	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Grease Trap	Inspected
Instance on Basement	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K860

Question	Response
KITCHEN	
Grease Trap	Inspected
Deficiency	No deficiencies recorded
Hood	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Does not Exist
Instance on Basement	Does not Exist
Hot Water Temperature Booster	Does not Exist
Instance on Basement	Does not Exist
Kitchen Sink	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room 100	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 100	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Partial
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	1 - Good
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	DEFECTIVE REGISTER/DIFFUSER
Deficiency Location/Instance	Cafeteria
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K860

Question	Response
VENTILATION	
Metal Ductwork	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Main Roof
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist