

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K891

Asset: P.S. 91 MINISCHOOL - BROOKLYN, 532 ALBANY AVENUE, New York, 11213

Inspection Id	Inspection Type	Time In	Last Edited
ME : K891	Mechanical	2024-05-29 8:00 AM	2024-06-07 1:04 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	MER 114
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Fixtures - Staff And Other: Toilets, Urinals
	Years: 2021
	Systems: Gas Fired Furnace (1 of 2)
	Years: 2016

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER 114 / A/C #1, AC#2
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K891

Question	Response
AIR CONDITIONING	
Refrigerant Piping	
Violations	No violations recorded.
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	MER 114
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	MER 114
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Inspected
Condition	5 - Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Janitor Sink Closet
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Gas Fired Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K891

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Does not Exist
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Student	Does not Exist
GAS FIRED FURNACE	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Does not Exist
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Does not Exist
HEATING	Inspected
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	5 - Poor
Deficiency	RADIATOR/CONVECTOR: DEFECTIVE/DETERIORATED
Deficiency Location/Instance	MER 114
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Heating	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K891

Question	Response
HEATING	Inspected
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Does not Exist
HEATING PLANT	Does not Exist
Enclosed IDF Room	Does not Exist
KITCHEN	Does not Exist
MDF Room	Does not Exist
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Partial
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER 114 / A/C #1, AC#2
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist