

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K932

Asset: HIGH SCHOOL SUSPENSION CENTER - K, 619 BELMONT AVENUE, New York, 11207

Inspection Id	Inspection Type	Time In	Last Edited
ME : K932	Mechanical	2024-03-11 11:55 AM	2024-03-21 5:14 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	3,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	Basement MER adjacent to Stair A
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Exhaust Fans (4 of 5)
	Years: 2023
	Systems: CO/Gas Leak Detection
	Years: 2022
	Systems: Oil Fired Domestic Water Heater
	Years: 2017
	Systems: Climate Control System: Refrigerated Air Dryers, Temperature Control Thermostats, Terminal Unit Control Valves
	Years: 2016
	Systems: MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2015

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
Yes	Defective CO/Gas Leak Detection	Defective System	GAS SERVICE CO/Gas Leak Detection	Boiler Room, Boiler Room Walkway, Rooms 105, 205, 305	Kenneth Van Brunt	Custodian	Sent to DSF	

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K932

Question	Response
CLIMATE CONTROL SYSTEM	
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Oil Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	A.O. Smith
Equipment	N/A
Capacity/Size Quantity	199
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	86
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2017
Source of Installation	Documented
Deficiency	No deficiencies recorded
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K932

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Interior Storm Piping	Does not Exist
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	INTERIOR FLOOR DRAIN: DEFECTIVE/DETERIORATED
Deficiency Location/Instance	2nd Floor Staff Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sewage Ejector Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	
	Does not Exist
FIXTURES	
	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Basement, 1st, 2nd Floor Corridors
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

K932

Question	Response
FIXTURES	
Student	
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Does not Exist
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Does not Exist
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Inspected
Instance	Boiler Room, Boiler Room Walkway, Rooms 105, 205, 305 (CO Leak Detection)
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2022
Source of Installation	Custodial Staff
Deficiency	DEFECTIVE SYSTEM
Deficiency Location/Instance	Boiler Room, Boiler Room Walkway, Rooms 105, 205, 305
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
HEATING	Inspected
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	AUXILIARY (VALVE, VENT): DEFECTIVE
Deficiency Location/Instance	2nd Floor Corridor near Stair D
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	FIN TUBE: DAMAGED GUARD/SHIELD
Deficiency Location/Instance	Room 305
Deficiency Quantity	10
Quantity Uom	L.F.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K932

Question	Response
HEATING	
Radiator/Convactor/Fin Tube	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	RADIATOR/CONVECTOR: DEFECTIVE
Deficiency Location/Instance	Corridor near Room 306A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Does not Exist
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Does not Exist
HEATING PLANT	
Replacement Quantity	2,439
Replacement Uom	MBH Net
Instance on Sub-Basement	Inspected
Burner Type	Oil
Heating Plant Oil Number	2
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Carlin
Burner Model Number	702CRD
Boiler Auxiliaries	Inspected
Instance on Sub-Basement	Inspected
Boiler Auxiliary Piping	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K932

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Emergency Stop Switch	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Sub-Basement	Does not Exist
Boiler Flue Exhaust	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Sub-Basement	Does not Exist
Boiler Room Steam And Condensate Piping	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	40
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Safety Valve	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Sub-Basement	Inspected
Coal-fired Boiler	
Instance on Sub-Basement	Does not Exist
Hot Water Boiler	
Instance on Sub-Basement	Does not Exist
Modular Boiler	
Instance on Sub-Basement	Does not Exist
Steam Boiler	
Instance on Sub-Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	813
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	Yes
Instance Manufacturer	Weil-McLain

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K932

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Equipment	55427-01
Capacity/Size Quantity	813
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1988
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	813
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	Yes
Instance Manufacturer	Weil-McLain
Equipment	55427-02
Capacity/Size Quantity	813
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1988
Source of Installation	Inspector Estimate
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	20
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	813
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	Yes
Instance Manufacturer	Weil-McLain
Equipment	55427-03
Capacity/Size Quantity	813
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1988
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Fuel System	Inspected
Instance on Sub-Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Sub-Basement	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K932

Question	Response
HEATING PLANT	
Fuel System	
Boiler Fresh Air Louver/Damper	
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Sub-Basement	Does not Exist
Enclosed IDF Room	Does not Exist
KITCHEN	Does not Exist
MDF Room	Inspected
Instance on Room 204A	Inspected
Dedicated A/C Equipment	
Instance on Room 204A	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Partial
Exhaust Fan	
Approximate Total # of Fans	1-25
Condition	1 - Good
Deficiency	DEFECTIVE
Deficiency Location/Instance	Library Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Heating And Ventilating Unit	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Metal Ductwork	
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K932

Question	Response
VENTILATION	
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist