

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K941

Asset: P.S. 209 TRANSPORTABLE - K, 2609 EAST 7TH ST, New York, 11215

Inspection Id	Inspection Type	Time In	Last Edited
EE : K941	Electrical	2023-11-01 9:27 AM	2023-11-09 3:47 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Public Address System
	Years: Under construction
	Systems: Exit/Emergency Light
	Years: 2015, 2022
	Systems: Security Lights
	Years: 1997, 2019
	Systems: All Other Electrical Systems and Components
	Years: 1997

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	Photo/Image
No	Exit/Emergency Light - Battery Not Operational	N/A	EXIT/EMERGE NCY LIGHT	T-1	Marco Velez	Fireman	Sent to DSF	

Inspection

Question	Response
Electrical	
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	60
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Recessed Mounted	Does not Exist
Lighting Fixture - LED	Does not Exist
COMPUTER LAB	Does not Exist
TOILET ROOM - STAFF	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K941

Question	Response
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Recessed Mounted	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
EMERGENCY LIGHTING	Does not Exist
EXIT LIGHT	Does not Exist
EXIT/EMERGENCY LIGHT	Inspected
Condition	1 - Good
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	T-1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	2,600
Replacement Uom	S.F.
Bell/Horn	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Does not Exist
Duct Smoke Detector	Does not Exist
Area Smoke Detector	Does not Exist
CO Detector	Does not Exist
Fused Cutout Panel	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K941

Question	Response
FIRE ALARM SYSTEM	
Fused Cutout Panel	Inspected
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not Exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	T-1
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Notifier
Equipment	Fire Alarm Control Panel
Model	N/A
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
Remote Annunciator	Does not Exist
GROUNDING SYSTEM	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Does not Exist
PANEL BOARD	Inspected
Molded Case Circuit Breaker Type	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	Under Construction
SECURITY	Inspected
IPDVS/CCTV System	Does not Exist
Intrusion Alarm System	Does not Exist
Lighting - Security	Inspected
Replacement Uom	EACH
Condition	4 - Between Fair and Poor
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Location/Instance	Exterior walls of TCUs
Deficiency Quantity	21
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 3
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
SERVICE SWITCH	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

K941

Question	Response
SERVICE SWITCH	
Instance	Outdoor Electrical Enclosure
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Siemens
Equipment	Main
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	
Number of Spares	2
Fused Disconnect Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Inspected
Instance	Outdoor Electrical Enclosure
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Siemens
Equipment	N/A
Capacity/Size Quantity	600
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	1997
Source of Installation	Documented
Deficiency	No deficiencies recorded
TELEPHONE SYSTEM	
	Inspected
PBX/Intercom	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standard	Does not Exist