

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K994

Asset: **BEDFORD ACADEMY - BROOKLYN, 1119 BEDFORD AVENUE, New York, 11216**

Inspection Id	Inspection Type	Time In	Last Edited
ME : K994	Mechanical	2023-10-30 8:04 AM	2023-11-06 4:08 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: DX Split System for Elevator Machine Room C06 (1 of 2); Kitchen - Hot Water Temperature Booster
	Years: 2020
	Systems: DX Split System for Kitchen Office Room C09A (1 of 2)
	Years: 2018
	Systems: MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2014

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Inspected
Absorption Chiller	Does not Exist
Air Cooled Chiller	Does not Exist
Air Cooled Condenser	Does not Exist
Chilled Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	2 - Between Good and Fair
Deficiency	PIPING: DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Main Roof
Deficiency Quantity	80
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Backflow Preventer	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Central Station Air Handler	Does not Exist
Fan Coil Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K994

Question	Response
AIR CONDITIONING	
Chilled Water System	
Packaged Air Cooled Chiller	Inspected
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-22
Instance Manufacturer	Carrier
Equipment	CH-1
Capacity/Size Quantity	27
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	2005
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-22
Instance Manufacturer	Carrier
Equipment	CH-2
Capacity/Size Quantity	27
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	2005
Source of Installation	Documented
Deficiency	No deficiencies recorded
Water Cooled Chiller	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Inspected
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-22
Instance Manufacturer	Carrier

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K994

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	
Equipment	RTU-1
Capacity/Size Quantity	16
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	2005
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-22
Instance Manufacturer	Carrier
Equipment	RTU-2
Capacity/Size Quantity	4
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2005
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-22
Instance Manufacturer	Carrier
Equipment	RTU-3
Capacity/Size Quantity	5
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	2005
Source of Installation	Documented
Deficiency	No deficiencies recorded
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Inspected
Instance	Throughout
Instance Condition	4 - Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K994

Question	Response
CLIMATE CONTROL SYSTEM	
BMS	
Building Area Covered by Operational System	0-20%
Installation Year	2005
Source of Installation	Documented
Deficiency	DEFECTIVE SYSTEM
Deficiency Location/Instance	Throughout
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Pneumatic System	Does not Exist
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Inspected
Dumbwaiter	Does not Exist
Elevator	Inspected
Are all the existing elevators operable?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Does not Exist
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Liquitrol
Equipment	N/A
Capacity/Size Quantity	2
Capacity/Size UOM	Total # Pumps
Capacity/Size2 Quantity	10
Capacity/Size2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2005
Source of Installation	Documented
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K994

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Pressure Booster System	Inspected
Hydraulic/Pneumatic Booster System	Does not Exist
Water Service	Inspected
Instance	Room C10C
Instance Condition	2 - Between Good and Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Domestic Water Heat Exchanger	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Electric Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Does not Exist
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	Boiler Room (mixing valve)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K994

Question	Response
FIXTURES	
Staff And Other	
Janitor Sink	Inspected
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Staff Toilet Room (p-trap)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Does not Exist
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Inspected
Instance	Gas Meter Room C10B
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K994

Question	Response
GAS SERVICE	
Gas Pressure Booster	
Instance Manufacturer	Eclipse
Equipment	N/A
Capacity/Size Quantity	5,400
Capacity/Size UOM	SCFH
Source of Capacity/Size	Documented
Installation Year	2005
Source of Installation	Documented
Deficiency	No deficiencies recorded
CO/Gas Leak Detection	Inspected
Instance	Boiler Room, Gas Meter Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2005
Source of Installation	Documented
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Inspected
Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Backflow Preventer	Does not Exist
Hot Water Heat Exchanger	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Steam Heating	Does not Exist
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
HEATING PLANT	Inspected
Replacement Quantity	1,670
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Gas
Heating Plant Oil Number	N/A
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	No
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K994

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Emergency Stop Switch	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Does not Exist
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Does not Exist
Boiler Flue Exhaust	
Instance on Basement	Does not Exist
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Does not Exist
Boiler Safety Valve	
Instance on Basement	Does not Exist
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	4 - Between Fair and Poor
Instance Quantity	1,670
Instance Quantity Uom	MBH Net
Instance Manufacturer	HydroTherm
Equipment	113410-01
Capacity/Size Quantity	1,670
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2005
Source of Installation	Documented
Deficiency	DEFECTIVE CONTROLS
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Boiler	
Instance on Basement	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K994

Question	Response
HEATING PLANT	
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Fixed Louver
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Does not Exist
Fuel Oil Storage/Supply System	
Instance on Basement	Does not Exist
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not Exist
Enclosed IDF Room	Does not Exist
KITCHEN	
Instance on Basement	Inspected
CO Detector	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas System	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Grease Trap	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Inspected
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hot Water Temperature Booster	Inspected
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Kitchen Sink	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K994

Question	Response
KITCHEN	Inspected
Kitchen Sink	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room 103	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 103	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Inspected
Instance on Room 304	Inspected
Alternative use	No
Acid Waste Neutralizing Tank	Inspected
Instance on Room 304	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CO Detector	Inspected
Instance on Room 304	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Emergency Shower	Inspected
Instance on Room 304	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Eye Wash	Inspected
Instance on Room 304	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on Room 304	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on Room 304	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fixed Laboratory Hood	Inspected
Instance on Room 304	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Laboratory Sink	Inspected
Instance on Room 304	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 304	Does not Exist
SCIENCE PREP ROOM	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

K994

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Does not Exist
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Main Roof
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist