

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**M001**


**Asset: P.S. 1 - MANHATTAN, 8 HENRY STREET, MANHATTAN, NY, 10038**

Inspection Id	Inspection Type	Time In	Last Edited
323	MECHANICAL	2023-10-20 08:27AM	2023-11-08 01:57PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Domestic Hot Water Systems Years: 2018 Systems: Water Service; Electric Pressure Booster System; Kitchen - Hood, Hood Fire Suppression System with Gas System Years: 2017 Systems: Student Toilet Room Fixtures (~60%) Years: 2015 Systems: CO/Gas Leak Detection System Years: 2014
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	5,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	Boiler Room Mechanical Area; 1st Floor MER, West Penthouse Fan Room, East Penthouse Fan Room; Penthouse 2 Tank Room
Are there any spaces with Missing or Defective CO Detectors?	Yes
Location(s)	Kitchen
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Basement - Supply Room near Gas Meter Room (painted, 4)
Are there any Emergency Stop Switches with Missing Hammers?	No components

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
Yes	Defective Boiler Safety Auxiliary	Water Column's try cock lever is broken	Steam Boiler	Boiler Room / Boiler #2	Diego Pedroza	Fireman	

**Inspection**

Question	Response
<b>Mechanical</b>	
<b>AIR CONDITIONING</b>	Does not exist
<b>CENTRAL ACID WASTE NEUTRALIZING TANK</b>	Does not exist
<b>CLIMATE CONTROL SYSTEM</b>	Inspected
<b>BMS</b>	Does not exist
<b>Pneumatic System</b>	Inspected
Instance	Throughout except Cafeteria, Multipurpose Room and Gymnasium
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE TERMINAL UNIT CONTROL VALVE
Deficiency Location/Instance	Rooms 501, 507, 511 and other locations
Deficiency Quantity	6
Quantity Uom	EACH

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**M001**

Question	Response
<b>CLIMATE CONTROL SYSTEM</b>	
<b>Pneumatic System</b>	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Room 312
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Hybrid System</b>	Does not exist
<b>Electric System</b>	Does not exist
<b>COMPACTOR</b>	Does not exist
<b>CONVEYING</b>	Does not exist
<b>DOMESTIC WATER SYSTEM</b>	Inspected
<b>Domestic Cold Water System</b>	Inspected
<b>Gravity System</b>	Inspected
<b>Supply Pump</b>	Does not exist
<b>Roof Tank</b>	Inspected
Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Penthouse 2 Tank Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>Pressure Booster System</b>	Inspected
<b>Electric Pressure Booster System</b>	Inspected
Instance	Basement - Pump Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Ketcham Pump Company
EquipmentId	N/A
Capacity/Size Quantity	2
Capacity/Size UOM	Total # Pumps
Capacity/Size 2 Quantity	10
Capacity/Size 2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2017
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
<b>Hydraulic/Pneumatic Booster System</b>	Inspected
<b>Water Pressure Booster - Compressor</b>	Inspected
Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Boiler Room Mechanical Area
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

***Mechanical Inspection***

**M001**

Question	Response
<b>DOMESTIC WATER SYSTEM</b>	
<b>Domestic Cold Water System</b>	
<b>Pressure Booster System</b>	
<b>Hydraulic/Pneumatic Booster System</b>	
<b>Water Pressure Booster - Compressor</b>	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>Pressure Booster Pump</b>	
Condition	Inspected
Deficiency	NOT IN USE
Deficiency Location/Instance	Boiler Room Mechanical Area
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>Domestic Cold Water Tank</b>	
Condition	Inspected
Deficiency	NOT IN USE
Deficiency Location/Instance	Boiler Room Mechanical Area
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>Water Service</b>	
Instance	Inspected
Instance Condition	Basement - Pump Room, Boiler Room Mechanical Area
Instance Quantity	1- Good
Instance Quantity Uom	2
Deficiency	EACH
Deficiency	No deficiencies recorded
<b>Domestic Hot Water System</b>	
<b>Domestic Hot Water Remote Storage Tank</b>	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
<b>Domestic Water Heat Exchanger</b>	
<b>Electric Domestic Water Heater</b>	
Condition	Does not exist
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Kitchen (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
<b>Gas Fired Domestic Water Heater</b>	
<b>Oil Fired Domestic Water Heater</b>	
<b>Heat Pump Domestic Water Heater</b>	
<b>Domestic Water Distribution Piping</b>	
Condition	Does not exist
Condition	Does not exist
Condition	Does not exist
Condition	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**M001**

<b>Question</b>	<b>Response</b>
<b>DRAIN/WASTE/VENT AND STORM SYSTEM</b>	Inspected
<b>Interior Storm Piping</b>	Does not exist
<b>Sewage/Waste/Vent Piping</b>	Inspected
Condition	3- Fair
Deficiency	INTERIOR FLOOR DRAIN:DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Sewage Ejector Pump</b>	Does not exist
<b>Sump Pump</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	Does not exist
<b>FIXTURES</b>	Inspected
<b>Staff And Other</b>	Inspected
<b>Janitor Sink</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Toilet</b>	Inspected
Condition	3- Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	3rd Floor Staff Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Urinal</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Student</b>	Inspected
<b>Drinking Fountain</b>	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Multipurpose Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Lavatory/Sink</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Multipurpose Room, 1st and 2nd Floor Girls Toilet Room

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**M001**

Question	Response
<b>FIXTURES</b>	
<b>Student</b>	
<b>Lavatory/Sink</b>	
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Locker Room Shower</b>	Does not exist
<b>Sink And Fountain Combo Unit</b>	Does not exist
<b>Toilet</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Urinal</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>GAS FIRED FURNACE</b>	Does not exist
<b>GAS SERVICE</b>	Inspected
<b>Gas Distribution Piping</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Gas Meter Room Exhaust Fan</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Gas Meter Room Vent</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Gas Pressure Booster</b>	Inspected
Instance	Basement - Gas Meter Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Eclipse
EquipmentId	N/A
Capacity/Size Quantity	12000
Capacity/Size UOM	SCFH
Source of Capacity/Size	Documented
Installation Year	1995
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>CO/Gas Leak Detection</b>	Inspected
Instance	Basement - Boiler Room, Boiler Room Mechanical Area, Gas Meter Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2014
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
<b>HEATING</b>	Inspected
<b>Heating Coil In Ductwork</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Hydronic Heating</b>	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

***Mechanical Inspection***

**M001**

<b>Question</b>	<b>Response</b>
<b>HEATING</b>	
<b>Radiator/Convactor/Fin Tube</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Steam Heating</b>	Inspected
<b>F&amp;T/Steam Drip Trap</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>MER Steam and Condensate Piping</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Steam Condensate Return Piping</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Steam Condensate Return Pumping System</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Steam Piping</b>	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room Mechanical Area near Exit
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Terminal Unit Thermostatic Trap</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Steam supplied by External Sources</b>	Does not exist
<b>Unit Heater/Cabinet Heater</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Basement - Supply Room near Gas Meter Room, Multipurpose Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>HEATING PLANT</b>	Inspected
Instance on Basement	Inspected
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	Yes
Burner Manufacturer	Iron Fireman

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**M001**

Question	Response
<b>HEATING PLANT</b>	
Burner Model	AG0-2-6 3-RK
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2
<b>Boiler Auxiliaries</b>	
Instance on Basement	Inspected
<b>Boiler Auxiliary Piping</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Emergency Stop Switch</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Feedwater System</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Feedwater Treatment(Automatic)</b>	
Instance on Basement	Does not exist
<b>Boiler Flue Exhaust</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Make-up Water Backflow Preventer</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Room Steam And Condensate Piping</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler Safety Valve</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Boiler System</b>	
Instance on Basement	Inspected
<b>Coal-fired Boiler</b>	
Instance on Basement	Does not exist
<b>Hot Water Boiler</b>	
Instance on Basement	Does not exist
<b>Modular Boiler</b>	
Instance on Basement	Does not exist
<b>Steam Boiler</b>	
Instance on Basement	Inspected
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	2,927
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	Kewanee Boiler Corporation
EquipmentId	6739-1

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**M001**

Question	Response
<b>HEATING PLANT</b>	
<b>Boiler System</b>	
<b>Steam Boiler</b>	
Capacity/Size Quantity	3770
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	1995
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	2,927
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	Kewanee Boiler Corporation
EquipmentId	6739-2
Capacity/Size Quantity	3770
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	1995
Source of Installation Year	Inspector Estimate
Deficiency	DEFECTIVE SAFETY AUXILIARY: LOW-WATER CUT-OFF, WATER COLUMN ASSEMBLY
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>Fuel System</b>	
Instance on Basement	Inspected
<b>Boiler Fresh Air Louver/Damper</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Type	Automatic
Deficiency	No deficiencies recorded
<b>Burner/Burner Control Panel</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Fuel Oil Storage/Supply System</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Gas Trains And Vent At The Boiler</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Enclosed IDF Room</b>	Does not exist
<b>KITCHEN</b>	
Instance on 1st Floor	Inspected
<b>CO Detector</b>	
Instance on 1st Floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE/MISSING



**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Mechanical Inspection**

**M001**

Question	Response
<b>KITCHEN</b>	
<b>CO Detector</b>	
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>Gas System</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Grease Trap</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Hood</b>	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
<b>Hood Exhaust Ductwork</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Hood Exhaust Fan</b>	
Instance on 1st Floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE MOTOR
Deficiency Location/Instance	West Penthouse Fan Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Hood Fire Suppression System</b>	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hot Water Temperature Booster</b>	
Instance on 1st Floor	Does not exist
<b>Kitchen Sink</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>MDF Room</b>	
Instance on Room 409	Inspected
<b>Dedicated A/C Equipment</b>	
Instance on Room 409	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	
	Does not exist
<b>SCIENCE LAB</b>	
	Does not exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

***Mechanical Inspection***

**M001**

<b>Question</b>	<b>Response</b>
<b>SCIENCE PREP ROOM</b>	Does not exist
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	Inspected
<b>Dry Sprinkler Alarm Valve Assembly</b>	Does not exist
<b>Wet Sprinkler Alarm Valve Assembly</b>	Does not exist
<b>Fire Booster Pump Assembly</b>	Does not exist
<b>Roof Tank</b>	Does not exist
<b>Siamese Connection</b>	Does not exist
<b>Sprinkler Head</b>	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Basement - Supply Room near Gas Meter Room (painted, 4)
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
<b>Sprinkler Piping</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Standpipe System</b>	Does not exist
<b>Water Gong</b>	Does not exist
<b>SWIMMING POOL</b>	Does not exist
<b>VENTILATION</b>	Inspected
Is the building Mechanically ventilated?	Partial
<b>Exhaust Fan</b>	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-25
Deficiency	No deficiencies recorded
<b>Heating And Ventilating Unit</b>	Does not exist
<b>Metal Ductwork</b>	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	Yes
Are there chain operated dampers?	No
Deficiency	DAMAGED FLEXIBLE CONNECTION
Deficiency Location/Instance	East Penthouse Fan Room @ Auditorium EF, East Wing House EF
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Supply Fan</b>	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-5
Deficiency	No deficiencies recorded
<b>Unit Ventilator</b>	Does not exist