

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M020

Asset: P.S. 20 - MANHATTAN, 166 ESSEX STREET, MANHATTAN, NY, 10002

Inspection Id	Inspection Type	Time In	Last Edited
618	MECHANICAL	2023-11-01 08:08AM	2023-11-28 03:40PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Boiler Safety Valves for Boiler #1 (2 of 4); Student Fixtures - Toilets (~30%) Years: 2022 Systems: Kitchen - Grease Traps; Sump Pumps Years: 2019 Systems: Staff Fixtures - Toilets; Student Fixtures - Toilets (~70%); Kitchen - Hood Fire Suppression System Years: 2018
Are there fuel tanks?	Yes
Total # of above ground tanks	2
Total capacity of all above ground tanks in gal.	15,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	MER B2
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Auditorium Stage, Auditorium Dressing Rooms, Paint Room in Gymnasium, Storage Room in Gymnasium, Storage Room in Cafeteria, Rooms B23,108, 219, 342 (painted, 28)
Are there any Emergency Stop Switches with Missing Hammers?	No components

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image	
		No condition recorded						

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not exist
Cooling Coil in Ductwork	Does not exist
Cooling Tower	Does not exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	3- Fair
Deficiency	UP TO 5 TONS:DEFECTIVE
Deficiency Location/Instance	Kitchen, Telephone Room 260
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Outdoor Unit	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Dry Cooler	Does not exist
Packaged / Rooftop Unit	Does not exist
Packaged Terminal A/C	Does not exist
Refrigerant Leak Detection System	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M020

Question	Response
AIR CONDITIONING	
Refrigerant Piping	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Return Fan	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	
	Does not exist
CLIMATE CONTROL SYSTEM	
	Inspected
BMS	Inspected
Instance	Throughout except Auditorium, Cafeteria and Gymnasium (WPT System)
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Installation Year	2011
Source of Installation Year	Documented
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Rooms 302, 320, 346, 348 and Other Locations
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Pneumatic System	Inspected
Instance	Auditorium, Gymnasium and Cafeteria
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
Hybrid System	Does not exist
Electric System	Does not exist
COMPACTOR	
	Does not exist
CONVEYING	
	Does not exist
DOMESTIC WATER SYSTEM	
	Inspected
Domestic Cold Water System	
	Inspected
Gravity System	
	Does not exist
Pressure Booster System	
	Does not exist
Water Service	
Instance	Basement - Water Meter Room B7, Crawlspace
Instance Condition	3- Fair
Instance Quantity	3
Instance Quantity Uom	EACH
Deficiency	WATER MAIN:MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement - Water Meter Room B7, Crawlspace
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Domestic Hot Water System	
	Inspected
Domestic Hot Water Remote Storage Tank	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M020

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Domestic Hot Water Remote Storage Tank	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Domestic Water Heat Exchanger	Does not exist
Electric Domestic Water Heater	Does not exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lochinvar
EquipmentId	N/A
Capacity/Size Quantity	200
Capacity/Size UOM	MBH Input
Capacity/Size 2 Quantity	0
Capacity/Size 2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2008
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not exist
Heat Pump Domestic Water Heater	Does not exist
Domestic Water Distribution Piping	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	MER B2
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not exist
Sump Pump	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M020

Question	Response
FIXTURES	
Staff And Other	
Lavatory/Sink	
Deficiency Location/Instance	Gymnasium Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Toilet	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Student	Inspected
Drinking Fountain	
Condition	3- Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Locker Room Shower	
Instance on Inside Room B29	Inspected
Instance Condition	3- Fair
Alternative Use	Yes
Deficiency	No deficiencies recorded
Sink And Fountain Combo Unit	
Condition	3- Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Rooms 220, 312, 316, 340
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Toilet	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	2- Between Good and Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Boy's Toilet Room 334
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
GAS FIRED FURNACE	Does not exist
GAS SERVICE	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M020

Question	Response
GAS SERVICE	
Gas Distribution Piping	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not exist
Gas Meter Room Vent	Does not exist
Gas Pressure Booster	Inaccessible
CO/Gas Leak Detection	Inspected
Instance	Basement - Boiler Room, Crawlspace
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2008
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
HEATING	
Heating Coil In Ductwork	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3- Fair
Deficiency	FIN TUBE:DAMAGED GUARD/SHIELD
Deficiency Location/Instance	Auditorium Stage
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3- Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER B2
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Condensate Return Piping	Inspected
Condition	3- Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Room B9, Crawlspace
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Condensate Return Pumping System	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M020

Question	Response
HEATING	
Steam Heating	
Steam Condensate Return Pumping System	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Steam Piping	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
Steam supplied by External Sources	
Condition	Does not exist
Unit Heater/Cabinet Heater	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
HEATING PLANT	
Condition	Inspected
Instance on Basement	Inspected
Is there a water meter on the boiler make-up water piping? Observed Operational?	Yes Yes
Burner Manufacturer	John Zink Company
Burner Model	F12.1-G0-50
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2
Boiler Auxiliaries	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M020

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Room Steam And Condensate Piping	
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not exist
Hot Water Boiler	
Instance on Basement	Does not exist
Modular Boiler	
Instance on Basement	Does not exist
Steam Boiler	
Instance on Basement	Inspected
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	3,899
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	York - Shipley Global
EquipmentId	50172-01
Capacity/Size Quantity	6277
Capacity/Size UOM	MBH Input
Source of Capacity/Size	Documented
Installation Year	2008
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	2- Between Good and Fair
Instance Quantity	3,899
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	York - Shipley Global
EquipmentId	50172-02
Capacity/Size Quantity	6277
Capacity/Size UOM	MBH Input
Source of Capacity/Size	Documented
Installation Year	2008
Source of Installation Year	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M020

Question	Response
HEATING PLANT	
Fuel System	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Type	Automatic
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	
Instance on Room 222	Inspected
Dedicated A/C Equipment	
Instance on Room 222	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 222
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Gas System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Grease Trap	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Hood	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M020

Question	Response
KITCHEN	
Hood Exhaust Ductwork	
Deficiency	No deficiencies recorded
Hood Exhaust Fan	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hot Water Temperature Booster	
Instance on 1st Floor	Does not exist
Kitchen Sink	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room 350	Inspected
Dedicated A/C Equipment	
Instance on Room 350	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Booster Pump Assembly	Does not exist
Roof Tank	Does not exist
Siamese Connection	Does not exist
Sprinkler Head	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Auditorium Stage, Auditorium Dressing Rooms, Paint Room in Gymnasium, Storage Room in Gymnasium, Storage Room in Cafeteria, Rooms B23, 108, 219, 342 (painted, 28)
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Sprinkler Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not exist
Water Gong	Does not exist
SWIMMING POOL	Does not exist
VENTILATION	Inspected
Is the building Mechanically ventilated?	Partial

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M020

Question	Response
VENTILATION	
Exhaust Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-25
Deficiency	DEFECTIVE MOTOR
Deficiency Location/Instance	Upper Roof / EF-5, EF-7
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Heating And Ventilating Unit	Inspected
Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE MOTOR
Deficiency Location/Instance	Basement - Crawlspace
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Metal Ductwork	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	Yes
Are there chain operated dampers?	No
Deficiency	DAMAGED FLEXIBLE CONNECTION
Deficiency Location/Instance	MER B2 @ Gymnasium Supply S-2, Lunch Playroom S-3
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Supply Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-5
Deficiency	DEFECTIVE
Deficiency Location/Instance	MER B2 / Auditorium SF (bearing)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Unit Ventilator	Does not exist