

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M042


Asset: P.S. 42 - MANHATTAN, 71 HESTER STREET, MANHATTAN, NY, 10002

Inspection Id	Inspection Type	Time In	Last Edited
1983	MECHANICAL	2023-12-28 09:10AM	2024-02-12 01:47PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Drinking Fountains (7 of 8); Gas Fired Domestic Water Heater Years: 2022 Systems: Student Fixtures - Lavatory/Sinks (~90%), Toilets (~80%), Urinals Years: 2018 Systems: Boiler Make-up Backflow Preventer Years: 2017 Systems: MDF Room - Dedicated A/C Equipment (DX Split System) Years: 2015 Systems: Climate Control System - Electric System; Boiler Safety Valves (2 of 4) Years: 2014
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	5,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Boiler Room Mechanical Area
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	1st Floor Supply Room (painted, 6)
Are there any Emergency Stop Switches with Missing Hammers?	No components

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	Defective Boiler Safety Auxiliary	(1)	Boiler Safety Valve	Boiler Room @ Boiler #1	THERESA DICRISTI	Custodian	

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not exist
Cooling Coil in Ductwork	Does not exist
Cooling Tower	Does not exist
DX Split System	Inspected
Indoor Unit	Inaccessible
Outdoor Unit	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Dry Cooler	Does not exist
Packaged / Rooftop Unit	Does not exist
Packaged Terminal A/C	Does not exist
Refrigerant Leak Detection System	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M042

Question	Response
AIR CONDITIONING	
Refrigerant Piping	Inspected
Condition	3- Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Return Fan	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
Hybrid System	Does not exist
Electric System	Inspected
Instance	Throughout (Energy Management System)
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
COMPACTOR	Does not exist
CONVEYING	Does not exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Does not exist
Hydraulic/Pneumatic Booster System	Inspected
Water Pressure Booster - Compressor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Pressure Booster Pump	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Domestic Cold Water Tank	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Water Service	Inspected
Instance	Basement - Orchard Street Side, Hester Street Side, Ludlow Street Side
Instance Condition	3- Fair
Instance Quantity	3
Instance Quantity Uom	EACH
Deficiency	WATER MAIN:DEFECTIVE VALVE

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M042

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Deficiency Location/Instance	Basement - Hester Street Side
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	WATER MAIN:MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement - Orchard Street Side, Hester Street Side, Ludlow Street Side
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not exist
Domestic Water Heat Exchanger	Does not exist
Electric Domestic Water Heater	Does not exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	A.O. Smith
EquipmentId	N/A
Capacity/Size Quantity	390
Capacity/Size UOM	MBH Input
Capacity/Size 2 Quantity	100
Capacity/Size 2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2022
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not exist
Heat Pump Domestic Water Heater	Does not exist
Domestic Water Distribution Piping	Inspected
Condition	3- Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement - Orchard Street Side, Hester Street Side, Ludlow Street Side
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M042

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Sewage/Waste/Vent Piping	Inspected
Condition	3- Fair
Deficiency	VENT PIPING:DETERIORATED
Deficiency Location/Instance	5th Floor Boy's Toilet Room
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SEWAGE/WASTE PIPING:DEFECTIVE/LEAKS
Deficiency Location/Instance	Basement Entrance, Basement Corridor
Deficiency Quantity	50
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Sewage Ejector Pump	Does not exist
Sump Pump	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	
	Does not exist
FIXTURES	
	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	5th Floor Men's Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Toilet	Inspected
Condition	3- Fair
Deficiency	CLOGGED/LEAKING
Deficiency Location/Instance	Basement Toilet Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Urinal	Does not exist
Student	Inspected
Drinking Fountain	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M042

Question	Response
FIXTURES	
Student	
Lavatory/Sink	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Locker Room Shower	Does not exist
Sink And Fountain Combo Unit	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Inspected
Instance	Basement - Gas Meter Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Eclipse
EquipmentId	N/A
Capacity/Size Quantity	1
Capacity/Size UOM	HP
Source of Capacity/Size	Documented
Installation Year	1996
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
CO/Gas Leak Detection	Inspected
Instance	Basement - Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	1996
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	Basement - Boiler Room, Gas Meter Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2009
Source of Installation Year	Documented
Deficiency	No deficiencies recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M042

Question	Response
HEATING	Inspected
Heating Coil In Ductwork	Does not exist
Hydronic Heating	Does not exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3- Fair
Deficiency	AUXILIARY (VALVE,VENT):DEFECTIVE
Deficiency Location/Instance	Corridors, Stairs, Toilet Rooms
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	RADIATOR/CONVECTOR:MISSING GUARD/SHIELD
Deficiency Location/Instance	Main Lobby, Auditorium, Rooms 201A, 210, 301A, 401A, 501A
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	5- Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Basement
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
MER Steam and Condensate Piping	Does not exist
Steam Condensate Return Piping	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Basement Corridor
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	Basement Corridor, Basement Mechanical Area
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Condensate Return Pumping System	Inspected
Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room (1 of 1)
Deficiency Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M042

Question	Response
HEATING	
Steam Heating	
Steam Condensate Return Pumping System	
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Piping	
Condition	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Basement Supply Room; Stair "I/5"
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	Basement Supply Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Terminal Unit Thermostatic Trap	
Condition	Inspected
Condition	5- Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Throughout
Deficiency Quantity	150
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam supplied by External Sources	
Does not exist	
Unit Heater/Cabinet Heater	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
HEATING PLANT	
Inspected	
Instance on Basement	Inspected
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	Yes
Burner Manufacturer	Gordon-Piatt
Burner Model	F10.1-G0-30
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2(B10)
Boiler Auxiliaries	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M042

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Emergency Stop Switch	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	FEEDWATER TANK:DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	40
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room @ Boiler #1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not exist
Hot Water Boiler	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M042

Question	Response
HEATING PLANT	
Boiler System	
Hot Water Boiler	
Instance on Basement	Does not exist
Modular Boiler	
Instance on Basement	Does not exist
Steam Boiler	
Instance on Basement	Inspected
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	2,599
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	A. L. Eastmond & Sons Inc.
EquipmentId	7123-01
Capacity/Size Quantity	2599
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1996
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	2,599
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	A. L. Eastmond & Sons Inc.
EquipmentId	7123-02
Capacity/Size Quantity	2599
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1996
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fuel System	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Instance on Basement	Inspected
Instance Condition	3- Fair
Type	Automatic
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M042

Question	Response
KITCHEN	Inspected
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Not required
Gas System	
Instance on 1st Floor	Does not exist
Grease Trap	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hood	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	
Instance on 1st Floor	Does not exist
Hot Water Temperature Booster	
Instance on 1st Floor	Does not exist
Kitchen Sink	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	Missing Air Gap
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
MDF Room	Inspected
Instance on Room 312	Inspected
Dedicated A/C Equipment	
Instance on Room 312	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Room 312
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M042

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Dry Sprinkler Alarm Valve Assembly	Does not exist
Wet Sprinkler Alarm Valve Assembly	Does not exist
Fire Booster Pump Assembly	Does not exist
Roof Tank	Does not exist
Siamese Connection	Does not exist
Sprinkler Head	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	1st Floor Supply Room (painted, 6)
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Sprinkler Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not exist
Water Gong	Does not exist
SWIMMING POOL	Does not exist
VENTILATION	Inspected
Is the building Mechanically ventilated?	Partial
Exhaust Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-25
Deficiency	DEFECTIVE
Deficiency Location/Instance	Basement - Paint Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	NOT IN USE
Deficiency Location/Instance	Boiler Room Mechanical Area
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Heating And Ventilating Unit	Does not exist
Metal Ductwork	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	Yes
Are there chain operated dampers?	Yes
Deficiency	DEFECTIVE DUCTWORK
Deficiency Location/Instance	Toilet Rooms
Deficiency Quantity	200
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M042

Question	Response
VENTILATION	
Supply Fan	Inspected
Condition	5- Poor
Approximate Total # of Fans	1-5
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Boiler Room Mechanical Area (2 of 2)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Unit Ventilator	Does not exist