

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

**Asset:** P.S. 35 (OLD 58/MNHT HS) - MANHATTAN, 317 WEST 52 STREET, MANHATTAN, NY, 10019

Inspection Id	Inspection Type	Time In	Last Edited
1474	ELECTRICAL	2023-12-05 09:14AM	2023-12-06 12:18PM

**Asset Data**

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Most Exit Lights (Battery Pack) Years: 2022 Systems: Gymnasium (Retrofitted LED Lighting) Years: 2021 Systems: IPDVS/CCTV System Years: 2020 Systems: Intrusion Alarm System (Central Control Panel, Partial Remote Annunciator) Years: 2017 Systems: Lighting - Security Years: 2016, 2007 Systems: Partial Molded Case Circuit Breaker Panel Board Years: 2014, 2010, 1993 Systems: Science Rooms Years: 2010 Systems: Interior Fluorescent Lighting, Gymnasium (HID Lighting) Years: 2008 Systems: Fire Alarm System, Local Sound System Years: 2007 Systems: Public Address System Years: 2005 Systems: Intrusion Alarm System Years: 1999 Systems: Emergency Light/Exit Light Panel Years: 1992
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

**Priority Condition**

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
		No condition recorded					

**Inspection**

Question	Response
<b>Electrical</b>	
<b>ATHLETIC FIELD</b>	Does not exist
<b>AUDITORIUM</b>	Inspected
Instance on 1st Floor	Inspected
<b>House Lighting</b>	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

Question	Response
<b>AUDITORIUM</b>	
<b>House Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on 1st Floor	Inspected
Instance Condition	5- Poor
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	VIDEO PROJECTOR IS NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Theater Lighting System</b>	
Instance on 1st Floor	Inspected
<b>Dimming System</b>	
Instance on 1st Floor	Does not exist
<b>Theater Lighting</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	41
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>CAFETERIA</b>	
Instance on 1st Floor - Students	Inspected
Instance on 1st Floor - Staff	Inspected
<b>Lighting</b>	
Instance on 1st Floor - Students	Inspected
Instance on 1st Floor - Staff	Inspected
<b>Lighting Fixture - Fluorescent</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

Question	Response
<b>CAFETERIA</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor - Staff	Inspected
Instance on 1st Floor - Students	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor - Staff	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor - Students	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor - Staff	Does not exist
Instance on 1st Floor - Students	Does not exist
<b>Local Sound System</b>	
Instance on 1st Floor - Students	Inspected
Instance Condition	3- Fair
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance on 1st Floor - Staff	Does not exist
<b>Projection System</b>	
Instance on 1st Floor - Students	Does not exist
Instance on 1st Floor - Staff	Does not exist
<b>Theater Lighting System</b>	
Instance on 1st Floor - Students	Does not exist
Instance on 1st Floor - Staff	Does not exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	Inspected
Does a Chandelier Exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 4
Violations	35672392H
<b>Surface Mounted</b>	Inspected

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

Question	Response
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>COMPUTER LAB</b>	Does not exist
<b>GYMNASIUM</b>	Inspected
Instance on Basement	Inspected
<b>Lighting</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
<b>Surface Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	LIGHTING FIXTURE NOT OPERATIONAL
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Surface Mounted</b>	
Instance on Basement	Does not exist
<b>Recessed Mounted</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Basement	Does not exist
<b>Recessed Mounted</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

Question	Response
<b>GYMNASIUM</b>	
<b>Lighting</b>	
<b>Lighting Fixture - LED</b>	
<b>Recessed Mounted</b>	
Instance on Basement	Does not exist
<b>Local Sound System</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Instance on Basement	Does not exist
<b>Scoreboard</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Theater Lighting System</b>	
Instance on Basement	Does not exist
<b>KITCHEN</b>	
Instance on 1st Floor	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Does not exist
<b>Recessed Mounted</b>	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Does not exist
<b>LIBRARY</b>	
Instance on Room 310	Inspected
<b>Lighting</b>	
Instance on Room 310	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 310	Inspected
<b>Pendant Mounted</b>	
Instance on Room 310	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 310	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 310	Does not exist
<b>Lighting Fixture - HID</b>	

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

Question	Response
<b>LIBRARY</b>	
<b>Lighting</b>	
<b>Lighting Fixture - HID</b>	
Instance on Room 310	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 310	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 310	Does not exist
<b>Raceway With Receptacles</b>	
Instance on Room 310	Does not exist
<b>Projection System</b>	
Instance on Room 310	Does not exist
<b>LOCKER ROOM</b>	
	Inspected
Instance on Basement	Inspected
Alternative Use	No
<b>Lighting</b>	
Instance on Basement	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Basement	Inspected
<b>Pendant Mounted</b>	
Instance on Basement	Does not exist
<b>Surface Mounted</b>	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Basement	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Basement	Does not exist
<b>MULTIPURPOSE ROOM</b>	
	Does not exist
<b>SCIENCE DEMO ROOM</b>	
	Does not exist
<b>SCIENCE LAB</b>	
	Inspected
Instance on Room 215	Inspected
Power Panel?	Yes
Alternative Use	No
<b>Lighting</b>	
Instance on Room 215	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 215	Inspected
<b>Pendant Mounted</b>	
Instance on Room 215	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	
Instance on Room 215	Does not exist
<b>Recessed Mounted</b>	
Instance on Room 215	Does not exist
<b>Lighting Fixture - HID</b>	
Instance on Room 215	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

Question	Response
<b>SCIENCE LAB</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 215	Inspected
<b>Pendant Mounted</b>	
Instance on Room 215	Does not exist
<b>Surface Mounted</b>	
Instance on Room 215	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on Room 215	Does not exist
<b>Lighting Fixture - LED</b>	
Instance on Room 215	Does not exist
<b>Emergency Gas Shut-Off Valve</b>	
Instance on Room 215	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	
Instance on Room 215	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Power Supply</b>	
Instance on Room 215	Inspected
<b>Instructor Unit</b>	
Instance on Room 215	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Meter Demonstration Unit</b>	
Instance on Room 215	Does not exist
<b>Student Unit</b>	
Instance on Room 215	Does not exist
<b>Projection System</b>	
Instance on Room 215	Inspected
Instance Condition	5- Poor
Deficiency	VIDEO PROJECTOR IS NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SCIENCE PREP ROOM</b>	
Instance on Room 213	Inspected
Instance on Room 213	Inaccessible
<b>SWIMMING POOL</b>	
	Does not exist
<b>TOILET ROOM - STAFF</b>	
	Inspected
<b>Lighting</b>	
	Inspected
<b>Lighting Fixture - Fluorescent</b>	
	Inspected
<b>Pendant Mounted</b>	
	Does not exist
<b>Surface Mounted</b>	
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
	Does not exist
<b>Lighting Fixture - HID</b>	
	Does not exist

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

Question	Response
<b>TOILET ROOM - STAFF</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not exist
<b>Surface Mounted</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not exist
<b>Lighting Fixture - HID</b>	Does not exist
<b>Lighting Fixture - Incandescent</b>	Does not exist
<b>Lighting Fixture - LED</b>	Does not exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	DOOR PUSH BUTTON NOT OPERATIONAL
Deficiency Location/Instance	By Kitchen Entrance
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not exist
<b>EMERGENCY GENERATOR SET</b>	Does not exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Corridor near Room B12
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Non Battery Pack</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	1- Good
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Corridor near Room 301
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2



**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

<b>Question</b>	<b>Response</b>
<b>EXIT LIGHT</b>	
<b>Battery Pack</b>	
Violations	No violations recorded
<b>Non Battery Pack</b>	Does not exist
<b>EXIT/EMERGENCY LIGHT</b>	Does not exist
<b>FIRE ALARM SYSTEM</b>	Inspected
<b>Bell/Horn</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Manual Pull Station</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Duct Smoke Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Area Smoke Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>CO Detector</b>	Does not exist
<b>Heat Detector</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Elevator Recall</b>	Does not exist
<b>Magnetic Door Holder/Contactor</b>	Does not exist
<b>Fused Cutout Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	Does not exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Main Entrance Lobby
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 2
EquipmentId	N/A
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Sub-Panel</b>	Inspected
<b>Bell At Panel</b>	Does not exist
<b>Fire Alarm Control Panel (Electronic)</b>	Inspected
Instance	Main Entrance Lobby

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

Question	Response
<b>FIRE ALARM SYSTEM</b>	
<b>Sub-Panel</b>	
<b>Fire Alarm Control Panel (Electronic)</b>	
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 2
EquipmentId	Strobe Panel
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Standard)</b>	Does not exist
<b>Remote Annunciator</b>	Inspected
<b>Display Monitor</b>	Does not exist
<b>Panel</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Printer</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Punch Register</b>	Does not exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>INTERCOM SYSTEM</b>	Does not exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not exist
<b>MOTOR CONTROLLER</b>	Inspected
<b>MOTOR CONTROL CENTER</b>	Does not exist
<b>MOTOR STARTER/CONTACTOR</b>	Inspected
Condition	3- Fair
Deficiency	MOTOR STARTER NOT OPERATIONAL
Deficiency Location/Instance	Room 106 (Exh.22)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Variable Frequency Drive</b>	Inspected
Condition	3- Fair

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

Question	Response
<b>MOTOR CONTROLLER</b>	
<b>Variable Frequency Drive</b>	
Deficiency	No deficiencies recorded
<b>PANEL BOARD</b>	
	Inspected
<b>Fused Disconnect Switch Type</b>	
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Mechanical Room 117, Corridor near Room B9
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	
	Does not exist
<b>Fused Toggle Switch Type</b>	
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Molded Case Circuit Breaker Type</b>	
	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	NO SPARE
Deficiency Location/Instance	Cafeteria, Corridor near Rooms 413, 106
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>PUBLIC ADDRESS SYSTEM</b>	
	Inspected
Instance	General Office - Room 204
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Biamp MPA250
Installation Year	2005
Source of Installation Year	Documented
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Classrooms and Corridors
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

<b>Question</b>	<b>Response</b>
<b>PUBLIC ADDRESS SYSTEM</b>	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SECURITY</b>	
	Inspected
<b>IPDVS/CCTV System</b>	
	Inspected
Condition	1- Good
Installation Year	2020
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
<b>Intrusion Alarm System</b>	
	Inspected
<b>Central Control Panel</b>	
	Inspected
Instance	Custodian's Office - Room 101
Instance Condition	4- Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista 128BPT
Installation Year	2017
Source of Installation Year	Documented
Deficiency	PANEL NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Violations	No violations recorded
<b>Infrared Sensor</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Lighting - Security</b>	
	Inspected
Condition	2- Between Good and Fair
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Location/Instance	Building Perimeters
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 3
Violations	No violations recorded
Deficiency	TIME CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 3

**NYC Department of Education  
Building Condition Assessment Survey 2023-2024**

**Electrical Inspection**

**M058**

Question	Response
<b>SECURITY</b>	
<b>Lighting - Security</b>	
Violations	No violations recorded
<b>SERVICE SWITCH</b>	Inspected
Instance	Electrical Room B1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard Switchboard
EquipmentId	Power Switch
Capacity/Size Quantity	1600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1968
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>SWITCHBOARD</b>	Inspected
Number of Spares	0
<b>Fused Disconnect Switch Type</b>	Inspected
Instance	Electrical Room B1
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Standard Switchboard
EquipmentId	Main Switchboard
Capacity/Size Quantity	1600
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1968
Source of Installation Year	Documented
Deficiency	FUSED DISCONNECT NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
<b>Fused Knife Switch Type</b>	Does not exist
<b>Molded Case Circuit Breaker Type</b>	Does not exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023-2024**

***Electrical Inspection***

**M058**

<b>Question</b>	<b>Response</b>
<b>TELEPHONE SYSTEM</b>	Inspected
<b>PBX/Intercom</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	Does not exist