

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M152

Asset: P.S. 152 - MANHATTAN, 93 NAGLE AVENUE, MANHATTAN, NY, 10040

Inspection Id	Inspection Type	Time In	Last Edited
2759	MECHANICAL	2024-01-26 07:12AM	2024-03-06 08:56PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Boiler #2 re-tubed; Water Gong Years: 2022 Systems: F&T/Steam Drip Traps (~90%); Terminal Unit Thermostatic Traps (~75%); Boiler Safety Valves (2 of 4); Gas Fired Domestic Water Heater (1of 2) Years: 2021 Systems: MDF Room - Dedicated A/C Equipment (1 of 2, DX Split System); Sump Pumps (4 of 5); Boiler Safety Valves (2 of 4) Years: 2018 Systems: Climate Control System: Temperature Control Thermostats (~50%); MDF Room - Dedicated A/C Equipment (1 of 2, DX Split System); Gas Fired Domestic Water Heater (1 of 2); Domestic Hot Water Remote Storage Tank (1 of 2); Fixtures - Toilets, Urinals Years: 2016
Are there fuel tanks?	Yes
Total # of above ground tanks	3
Total capacity of all above ground tanks in gal.	15,250
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Original Building - Basement Mechanical Area, Basement Fan Room, Basement Steam Condensate Return Pump Room; 2nd Building Addition - Basement MER
Are there any spaces with Missing or Defective CO Detectors?	Yes
Location(s)	2nd Building Addition - Basement MER, Kitchen
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Corridor by Room B22 (painted, 3)
Are there any Emergency Stop Switches with Missing Hammers?	No components

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
		No condition recorded					

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not exist
Pneumatic System	Inspected
Instance	Original and 1st Addition Buildings - Throughout
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	61-80%
Deficiency	DEFECTIVE PNEUMATIC PRV STATION
Deficiency Location/Instance	Boiler Room Mechanical Area
Deficiency Quantity	1
Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M152

Question	Response
CLIMATE CONTROL SYSTEM	
Pneumatic System	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	PNEUMATIC TUBING: DEFECTIVE/LEAKS AIR
Deficiency Location/Instance	Boy's Toilet Room 262, Library, Rooms 213, 224 and other locations
Deficiency Quantity	60
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Corridor near Room 303, Rooms 213, 224 and other locations
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	2nd Building Addition Cafeteria and Kitchen
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE AIR COMPRESSOR
Deficiency Location/Instance	2nd Building Addition - Basement MER
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE PNEUMATIC PRV STATION
Deficiency Location/Instance	2nd Building Addition - Basement MER
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Hybrid System	Does not exist
Electric System	Does not exist
COMPACTOR	Does not exist
CONVEYING	Inspected
Dumbwaiter	Does not exist
Elevator	Inspected
Condition	3- Fair
Are all the existing elevators operable?	Yes
Deficiency	No deficiencies recorded
Escalator	Does not exist
Non-auditorium Handicap Lift - Vertical	Does not exist
Non-auditorium Handicap Lift - Stair	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M152

Question	Response
CONVEYING	
Ash Hoist	Does not exist
Sidewalk Elevator	Does not exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Does not exist
Hydraulic/Pneumatic Booster System	Inspected
Water Pressure Booster - Compressor	Inspected
Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Original Building - Basement Mechanical Area
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Pressure Booster Pump	Inspected
Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Original Building - Basement Mechanical Area
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Domestic Cold Water Tank	Inspected
Condition	3- Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Original Building - Basement Mechanical Area
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Water Service	Inspected
Instance	Original Building - Boiler Room, Basement Mechanical Area; 2nd Building Addition Sprinkler/Gas Meter Room
Instance Condition	2- Between Good and Fair
Instance Quantity	3
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Domestic Water Heat Exchanger	Does not exist
Electric Domestic Water Heater	Does not exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M152

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Gas Fired Domestic Water Heater	
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	PVI
EquipmentId	N/A
Capacity/Size Quantity	300
Capacity/Size UOM	MBH Input
Capacity/Size 2 Quantity	300
Capacity/Size 2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	1991
Source of Installation Year	Custodial Staff
Deficiency	NOT IN USE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lochinvar
EquipmentId	N/A
Capacity/Size Quantity	315
Capacity/Size UOM	MBH Input
Capacity/Size 2 Quantity	0
Capacity/Size 2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2021
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Instance	2nd Building Addition - Basement MER
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Lochinvar
EquipmentId	N/A
Capacity/Size Quantity	150
Capacity/Size UOM	MBH Input
Capacity/Size 2 Quantity	0
Capacity/Size 2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2016
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not exist
Heat Pump Domestic Water Heater	Does not exist
Domestic Water Distribution Piping	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE DOMESTIC HOT WATER CIRCULATING PUMP
Deficiency Location/Instance	2nd Building Addition - Basement MER

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M152

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Water Distribution Piping	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	
Inspected	
Interior Storm Piping	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	
Inspected	
Condition	3- Fair
Deficiency	SEWAGE/WASTE PIPING:CLOGGED
Deficiency Location/Instance	Exit "7", Original Building Basement, 2nd Building Addition - Basement MER (backs-up during heavy rain)
Deficiency Quantity	300
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Sewage Ejector Pump	
Does not exist	
Sump Pump	
Inspected	
Condition	2- Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	2nd Building Addition - Elevator Pit
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	
Does not exist	
FIXTURES	
Inspected	
Staff And Other	
Inspected	
Janitor Sink	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	
Inspected	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	
Does not exist	
Student	
Inspected	
Drinking Fountain	
Inspected	
Condition	3- Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Corridor near 461
Deficiency Quantity	1
Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M152

Question	Response
FIXTURES	
Student	
Drinking Fountain	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lavatory/Sink	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Locker Room Shower	
	Inspected
Instance on Inside Room 452	Inaccessible
Sink And Fountain Combo Unit	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	
	Does not exist
GAS SERVICE	
	Inspected
Gas Distribution Piping	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	
	Does not exist
Gas Meter Room Vent	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	
	Inspected
Instance	2nd Building Addition - Basement MER
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Eclipse
EquipmentId	N/A
Capacity/Size Quantity	15000
Capacity/Size UOM	SCFH
Source of Capacity/Size	Documented
Installation Year	1991
Source of Installation Year	Documented
Deficiency	NOT IN USE
Deficiency Location/Instance	2nd Building Addition - Basement MER
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Violations	No violations recorded
CO/Gas Leak Detection	
	Does not exist
HEATING	
	Inspected
Heating Coil In Ductwork	
	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M152

Question	Response
HEATING	
Heating Coil In Ductwork	
Deficiency	No deficiencies recorded
Hydronic Heating	Does not exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3- Fair
Deficiency	RADIATOR/CONVECTOR:MISSING GUARD/SHIELD
Deficiency Location/Instance	Room 261
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	AUXILIARY (VALVE,VENT):DEFECTIVE
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE PUMP
Deficiency Location/Instance	2nd Building Addition - Basement MER
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Piping	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	2nd Building Addition near Sprinkler/Gas Meter Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Room 263
Deficiency Quantity	10

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M152

Question	Response
HEATING	
Steam Heating	
Steam Piping	
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Terminal Unit Thermostatic Trap	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Steam supplied by External Sources	
	Does not exist
Unit Heater/Cabinet Heater	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
HEATING PLANT	
	Inspected
Instance on Basement	Inspected
Is there a water meter on the boiler make-up water piping?	No
Burner Manufacturer	Dunham-Bush
Burner Model	EED-GO -4-12.5RL
Burner Type	Oil
Heating Plant Oil Number	2(B10)
Boiler Auxiliaries	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE BOILER AUTOMATIC FEEDWATER VALVE
Deficiency Location/Instance	Boiler Room @ Boilers #1, #2
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Does not exist
Boiler Flue Exhaust	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M152

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Room Steam And Condensate Piping	
Instance Condition	3- Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room (flange)
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not exist
Hot Water Boiler	
Instance on Basement	Does not exist
Modular Boiler	
Instance on Basement	Does not exist
Steam Boiler	
Instance on Basement	Inspected
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	6,879
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	Kewanee Boiler Corporation
EquipmentId	5652-1
Capacity/Size Quantity	8860
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	1991
Source of Installation Year	Custodial Staff
Deficiency	DAMAGED REFRACTORY
Deficiency Quantity	10
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	30
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M152

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Instance Quantity	6,879
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	Kewanee Boiler Corporation
EquipmentId	5652-2
Capacity/Size Quantity	8860
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	1991
Source of Installation Year	Custodial Staff
Deficiency	DAMAGED REFRACTORY
Deficiency Quantity	20
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	30
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fuel System	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Type	Automatic
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not exist
Enclosed IDF Room	Does not exist
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE/MISSING
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M152

Question	Response
KITCHEN	
CO Detector	
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Gas System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Grease Trap	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hot Water Temperature Booster	
Instance on 1st Floor	Does not exist
Kitchen Sink	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	Missing Air Gap
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 4
Violations	SF22829
MDF Room	
	Inspected
Instance on 1st Building Addition - Room 163	Inspected
Dedicated A/C Equipment	
Instance on 1st Building Addition - Room 163	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	
	Does not exist
SCIENCE LAB	
	Does not exist
SCIENCE PREP ROOM	
	Does not exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not exist
Wet Sprinkler Alarm Valve Assembly	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M152

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Wet Sprinkler Alarm Valve Assembly	
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Booster Pump Assembly	
	Does not exist
Roof Tank	
	Does not exist
Siamese Connection	
Condition	3- Fair
Deficiency	No deficiencies recorded
Sprinkler Head	
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Corridor by Room B22 (painted, 3)
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Sprinkler Piping	
Condition	3- Fair
Deficiency	No deficiencies recorded
Standpipe System	
	Does not exist
Water Gong	
Condition	1- Good
Deficiency	No deficiencies recorded
SWIMMING POOL	
	Does not exist
VENTILATION	
Is the building Mechanically ventilated?	Inspected
	Partial
Exhaust Fan	
Condition	Inspected
Approximate Total # of Fans	3- Fair
Deficiency	1-25
Deficiency	DEFECTIVE
Deficiency Location/Instance	Main Roof/ TX-1 (bearing)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Heating And Ventilating Unit	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
Metal Ductwork	
Condition	Inspected
Are there any uninsulated ductwork by design in Mechanical rooms?	3- Fair
Are there chain operated dampers?	Yes
Deficiency	No
Deficiency	DAMAGED FLEXIBLE CONNECTION
Deficiency Location/Instance	Basement Mechanical Area @ 3rd Floor Gymnasium BL, Playroom EF
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M152

Question	Response
VENTILATION	
Metal Ductwork	
Deficiency	DEFECTIVE DUCTWORK
Deficiency Location/Instance	Main Roof / TX-1 (EF Cover)
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Supply Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-5
Deficiency	No deficiencies recorded
Unit Ventilator	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Rooms 121, 125, 317, 319
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DAMAGED GUARD/SHIELD
Deficiency Location/Instance	Room 413
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded