

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M155

Asset: P.S. 155 - MANHATTAN, 319 EAST 117 STREET, MANHATTAN, NY, 10035

Inspection Id	Inspection Type	Time In	Last Edited
907	MECHANICAL	2023-11-10 09:06AM	2023-12-15 07:19AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Water Service (1 of 3) Years: 2023 Systems: Steam Condensate Return Pumping System Years: 2022 Systems: Kitchen - Gas System Years: 2021 Systems: Heat Pump Domestic Water Heaters; Drinking Fountains (3 of 5) Years: 2019 Systems: Kitchen - Hood Exhaust Fan Years: 2018 Systems: Kitchen - Grease Trap (1 of 2) Years: 2015 Systems: Science Lab; Electric Domestic Water Heater for Science Lab (in Crawlspace below Cafeteria) Years: 2014 Systems: MDF Room - Dedicated A/C Equipment (1 of 2, DX Split System) Years: 2013
Are there fuel tanks?	Yes
Total # of above ground tanks	2
Total capacity of all above ground tanks in gal.	15,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Boiler Room Mechanical Area, Basement MER
Are there any spaces with Missing or Defective CO Detectors?	Yes
Location(s)	Science Lab
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Room 402 (painted, 2)
Are there any Emergency Stop Switches with Missing Hammers?	Component: Boiler Room Entrances (2) Location: Boiler Emergency Stop Switch

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
		No condition recorded					

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not exist
Pneumatic System	Does not exist
Hybrid System	Does not exist
Electric System	Inspected
Instance	Throughout
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M155

Question	Response
CLIMATE CONTROL SYSTEM	
Electric System	
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Custodian's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE TEMPERATURE CONTROL ZONE VALVE
Deficiency Location/Instance	Kitchen Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
COMPACTOR	Does not exist
CONVEYING	Inspected
Dumbwaiter	Inspected
Condition	3- Fair
Are all the existing dumbwaiters operable?	Yes
Deficiency	No deficiencies recorded
Elevator	Does not exist
Escalator	Does not exist
Non-auditorium Handicap Lift - Vertical	Does not exist
Non-auditorium Handicap Lift - Stair	Does not exist
Ash Hoist	Does not exist
Sidewalk Elevator	Does not exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not exist
Pressure Booster System	Does not exist
Water Service	Inspected
Instance	Basement - Gas/Water/Sprinkler Room B8
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN:MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement - Gas/Water/Sprinkler Room B8
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Crawlspace below Cafeteria
Instance Condition	4- Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN:MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Crawlspace below Cafeteria

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M155

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	WATER MAIN:DEFECTIVE VALVE
Deficiency Location/Instance	Crawlspace below Cafeteria
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Basement - Gas/Water/Sprinkler Room B8
Instance Condition	1- Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not exist
Domestic Water Heat Exchanger	Inspected
Condition	3- Fair
Deficiency	Flange Leaks
Deficiency Location/Instance	Boiler Room Mechanical Area
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE AUXILIARIES(RELIEF VALVE, GAUGE, TEMPERATURE REGULATOR, ETC)
Deficiency Location/Instance	Boiler Room Mechanical Area
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Electric Domestic Water Heater	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not exist
Oil Fired Domestic Water Heater	Does not exist
Heat Pump Domestic Water Heater	Inspected
Instance	Boiler Room Mechanical Area
Instance Condition	1- Good
Instance Quantity	2
Instance Quantity Uom	EACH
Manufacturer	A.O. Smith
EquipmentId	N/A

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M155

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Heat Pump Domestic Water Heater	
Capacity/Size Quantity	5
Capacity/Size UOM	KW Input
Capacity/Size 2 Quantity	80
Capacity/Size 2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2019
Source of Installation Year	Inspector Estimate
Deficiency	No deficiencies recorded
Domestic Water Distribution Piping	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room Mechanical Area, Room 315 - Crawlspace
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3- Fair
Deficiency	SEWAGE/WASTE PIPING:CLOGGED
Deficiency Location/Instance	Boiler Room, Boiler Room Mechanical Area
Deficiency Quantity	50
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	SEWAGE/WASTE PIPING:DEFECTIVE/LEAKS
Deficiency Location/Instance	Ejector Pump Room; Cafeteria - Supply Storage Room; Room 315 - Crawlspace
Deficiency Quantity	40
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	HOUSE TRAP:DETERIORATED/LEAKS
Deficiency Location/Instance	Ejector Pump Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	VENT PIPING:CLOGGED
Deficiency Location/Instance	Room 118 - Toilet Room
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M155

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Sewage/Waste/Vent Piping	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Sewage Ejector Pump	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sump Pump	Inspected
Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Boiler Room (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3- Fair
Deficiency	CLOGGED/LEAKING
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Student	Inspected
Drinking Fountain	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Inspected
Instance on 2nd Floor - Boys	Inaccessible
Instance on 2nd Floor - Girls	Inaccessible
Sink And Fountain Combo Unit	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M155

Question	Response
FIXTURES	
Student	
Toilet	
Condition	3- Fair
Deficiency	No deficiencies recorded
Urinal	
Condition	3- Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Toilet Rooms 219, 319, 419
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	CLOGGED/LEAKING
Deficiency Location/Instance	Toilet Room 319
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
GAS FIRED FURNACE	Does not exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not exist
Gas Meter Room Vent	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not exist
CO/Gas Leak Detection	Does not exist
HEATING	
Heating Coil In Ductwork	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Hydronic Heating	
Radiator/Convactor/Fin Tube	Inspected
Condition	3- Fair
Deficiency	RADIATOR/CONVECTOR:DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Room 231 - Toilet Room, Corridor near Room 413
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	AUXILIARY (VALVE, VENT):DEFECTIVE
Deficiency Location/Instance	Custodian's Locker Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M155

Question	Response
HEATING	
Radiator/Convactor/Fin Tube	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3- Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Basement MER
Deficiency Quantity	80
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Condensate Return Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Steam Piping	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room Mechanical Area, Corridor near Room 418
Deficiency Quantity	30
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	5- Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Throughout
Deficiency Quantity	110
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam supplied by External Sources	Does not exist
Unit Heater/Cabinet Heater	Does not exist
HEATING PLANT	
Instance on Basement	Inspected
Is there a water meter on the boiler make-up water piping?	No
Burner Manufacturer	Preferred Utilities
Burner Model	HE6V3A4
Burner Type	Oil
Heating Plant Oil Number	4
Boiler Auxiliaries	
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M155

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE BOILER MAKE-UP WATER PIPING
Deficiency Location/Instance	Boiler Room @ Boiler #1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	MISSING HAMMER
Deficiency Location/Instance	Boiler Room Entrances (2)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Boiler Feedwater System	
Instance on Basement	Does not exist
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Does not exist
Boiler Flue Exhaust	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Does not exist
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not exist
Hot Water Boiler	
Instance on Basement	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M155

Question	Response
HEATING PLANT	
Boiler System	
Modular Boiler	
Instance on Basement	Does not exist
Steam Boiler	
Instance on Basement	Inspected
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	4- Between Fair and Poor
Instance Quantity	4,053
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	Burnham
EquipmentId	49346-1
Capacity/Size Quantity	45
Capacity/Size UOM	Burner GPH
Source of Capacity/Size	Documented
Installation Year	1961
Source of Installation Year	Documented
Deficiency	DEFECTIVE STRUCTURAL ELEMENTS(TUBE SHEETS, STAY BOLTS, ETC.
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE AUXILIARY (GAUGES, GASKETS ETC.)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	30
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	4- Between Fair and Poor
Instance Quantity	4,053
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	Burnham
EquipmentId	49346-2
Capacity/Size Quantity	45
Capacity/Size UOM	Burner GPH
Source of Capacity/Size	Documented
Installation Year	1961
Source of Installation Year	Documented
Deficiency	DEFECTIVE STRUCTURAL ELEMENTS(TUBE SHEETS, STAY BOLTS, ETC.
Deficiency Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M155

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE AUXILIARY (GAUGES, GASKETS ETC.)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	60
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fuel System	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Instance on Basement	Inspected
Instance Condition	3- Fair
Type	Automatic
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	OIL BURNER:DEFECTIVE
Deficiency Location/Instance	Boiler Room @ Boiler #1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	FUEL OIL TRANSFER PUMP:DEFECTIVE
Deficiency Location/Instance	Boiler Room Mechanical Area
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not exist
Enclosed IDF Room	
Instance on Rooms 213, 313	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M155

Question	Response
Enclosed IDF Room	
Dedicated A/C Equipment	
Instance on Rooms 213, 313	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Rooms 213, 313
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Gas System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Grease Trap	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE/CLOGGED
Deficiency Location/Instance	Kitchen (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Hood	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Hood Fire Suppression System	
Instance on 1st Floor	Does not exist
Hot Water Temperature Booster	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Kitchen Sink	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	Missing Air Gap

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M155

Question	Response
KITCHEN	
Kitchen Sink	
Deficiency Location/Instance	Kitchen
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 4
Violations	SF86797
MDF Room	Inspected
Instance on Room 414B	Inspected
Dedicated A/C Equipment	
Instance on Room 414B	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	
Instance on Room 404	Inspected
Alternative Use	No
Acid Waste Neutralizing Tank	
Instance on Room 404	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
CO Detector	
Instance on Room 404	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE/MISSING
Deficiency Location/Instance	Room 404
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Emergency Shower	
Instance on Room 404	Does not exist
Eye Wash	
Instance on Room 404	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on Room 404	Does not exist
Hood Exhaust Fan	
Instance on Room 404	Does not exist
Fixed Laboratory Hood	
Instance on Room 404	Does not exist
Laboratory Sink	
Instance on Room 404	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	
Instance on Room 404	Does not exist
SCIENCE PREP ROOM	Does not exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M155

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Dry Sprinkler Alarm Valve Assembly	Does not exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Booster Pump Assembly	Does not exist
Roof Tank	Does not exist
Siamese Connection	Does not exist
Sprinkler Head	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Room 402 (painted, 2)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Sprinkler Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not exist
Water Gong	Does not exist
SWIMMING POOL	Does not exist
VENTILATION	Inspected
Is the building Mechanically ventilated?	Partial
Exhaust Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-25
Deficiency	DEFECTIVE
Deficiency Location/Instance	Upper Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Heating And Ventilating Unit	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Metal Ductwork	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	Yes
Are there chain operated dampers?	Yes
Deficiency	No deficiencies recorded
Supply Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-5
Deficiency	No deficiencies recorded
Unit Ventilator	Does not exist