

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M390

Asset: P.S. 183 GYM - MANHATTAN, 408 EAST 67 STREET, MANHATTAN, NY, 10065

Inspection Id	Inspection Type	Time In	Last Edited
2304	ELECTRICAL	2024-01-10 09:03AM	2024-01-10 02:04PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: LED Lighting Years: 2022 Systems: All Electrical Systems and Components Years: 2006
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Does not exist
CAFETERIA	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
COMPUTER LAB	Does not exist
GYMNASIUM	Inspected
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M390

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2006
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
Scoreboard	
Instance on 1st Floor	Inspected
Instance Condition	5- Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Does not exist
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
KITCHEN	Does not exist
LIBRARY	Does not exist
LOCKER ROOM	Does not exist
MULTIPURPOSE ROOM	Does not exist
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Does not exist
Recessed Mounted	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M390

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Deficiency	ALARM INDICATOR AT THE INDICATOR PANEL NOT OPERATIONAL
Deficiency Location/Instance	Gymnasium Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not exist
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not exist
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Bell/Horn	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M390

Question	Response
FIRE ALARM SYSTEM	
Area Smoke Detector	
Deficiency	No deficiencies recorded
CO Detector	Does not exist
Heat Detector	Does not exist
Elevator Recall	Does not exist
Magnetic Door Holder/Contactor	Does not exist
Fused Cutout Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Street Entrance Area
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards System Technology
Model	EST 2
EquipmentId	Fire Alarm Control Panel
Installation Year	2006
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not exist
Sub-Panel	Does not exist
Remote Annunciator	Does not exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Does not exist
LIGHTNING PROTECTION	Does not exist
MOTOR CONTROLLER	Inspected
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PANEL BOARD	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M390

Question	Response
PANEL BOARD	
Fused Disconnect Switch Type	Does not exist
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	
	Inspected
Instance	Connected to Main Asset M183
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	2006
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SECURITY	
	Inspected
IPDVS/CCTV System	
	Does not exist
Intrusion Alarm System	
	Inspected
Central Control Panel	
	Does not exist
Infrared Sensor	
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting - Security	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	
	Inspected
Instance	Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	Main Service SW
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2006
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	
	Inspected
Number of Spares	5
Fused Disconnect Switch Type	
	Inspected
Instance	Electrical Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M390

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Instance Quantity Uom	EACH
Manufacturer	All City Switchboard
EquipmentId	MSB Section #1, MSB Section #2
Capacity/Size Quantity	600
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	2006
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not exist