

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Asset: STUYVESANT HS (NEW) - MANHATTAN, 345 CHAMBERS STREET, MANHATTAN, NY, 10282

Inspection Id	Inspection Type	Time In	Last Edited
4836	ELECTRICAL	2024-04-17 09:06AM	2024-05-22 08:34AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Auditorium (LED Lighting, Projection System, Theater Lighting System), Swimming Pool (LED Lighting) Years: 2023 Systems: LED Lighting (Escalators Area, Robotics Lab Room 453) Years: 2022 Systems: Partial Lighting Security (Retrofitted), Intrusion Alarm System (Panic Switch) Years: 2021 Systems: LED Lighting - Recessed Mounted (Room 250), Emergency Generator Set (Battery Charger) Years: 2017 Systems: Students Cafeteria (Projection System) Years: 2016 Systems: Intrusion Alarm System (Most Remote Annunciator, Partial Infrared Sensors) Years: 2015 Systems: Computer Lab - Room 351, Exit Light (Battery Pack) Years: 2014 Systems: Lightning Protection Years: 2013 Systems: Library Years: 2012 Systems: IPDVS/CCTV System, Intrusion Alarm System (Central Control Panel) Years: 2010 Systems: All Other Electrical Systems and Components Years: 1992
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	No
Which spaces do not have dedicated intercoms?	Rooms 1004, 1033, 902, 931, 801, 701, 736, 627, C682, 503, K531, 404, 433, 303

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No	condition recorded						

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance on 1st Floor	Inspected
House Lighting	
Instance on 1st Floor	Inspected
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
AUDITORIUM	
House Lighting	
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Local Sound System	
Instance on 1st Floor	Under construction
Projection System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
CAFETERIA	
Instance on 5th Floor - Staff	Inspected
Instance on 5th Floor - Students	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
CAFETERIA	
Lighting	
Instance on 5th Floor - Staff	Inspected
Instance on 5th Floor - Students	Inspected
Lighting Fixture - Fluorescent	
Instance on 5th Floor - Staff	Inspected
Instance on 5th Floor - Students	Inspected
Pendant Mounted	
Instance on 5th Floor - Staff	Does not exist
Instance on 5th Floor - Students	Does not exist
Surface Mounted	
Instance on 5th Floor - Staff	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 5th Floor - Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	100
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 5th Floor - Staff	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	33
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 5th Floor - Students	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	114
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 5th Floor - Staff	Does not exist
Instance on 5th Floor - Students	Does not exist
Lighting Fixture - Incandescent	
Instance on 5th Floor - Staff	Does not exist
Instance on 5th Floor - Students	Does not exist
Lighting Fixture - LED	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - LED	
Instance on 5th Floor - Staff	Does not exist
Instance on 5th Floor - Students	Does not exist
Local Sound System	
Instance on 5th Floor - Staff	Does not exist
Instance on 5th Floor - Students	Under construction
Projection System	
Instance on 5th Floor - Staff	Does not exist
Instance on 5th Floor - Students	Inspected
Instance Condition	2- Between Good and Fair
Is the projector on a cart or installed on the ceiling?	Ceiling
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 5th Floor - Staff	Does not exist
Instance on 5th Floor - Students	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	Inspected
Does a Chandelier Exist?	Yes
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	580
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	460
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Deficiency Quantity	2,900
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	LIGHTING FIXTURE BALLAST DEFECTIVE
Deficiency Quantity	50
Quantity Uom	EACH
Potential Action	REPLACE BALLAST
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	28
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	100
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - LED	Inspected
Pendant Mounted	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - LED	
Pendant Mounted	
Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Condition	Inspected
Deficiency	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
COMPUTER LAB	
Instance on Room 1001	Inspected
Power Panel?	Inspected
Instance on Rooms 307, 325, 1007	No
Power Panel?	Inspected
Instance on Room 251	Yes
Power Panel?	Inspected
Instance on Room 413	No
Power Panel?	Inspected
Instance on Room 411	No
Power Panel?	Inspected
Instance on Room 351	Yes
Power Panel?	Inspected
Instance on Room 351	No
Power Panel?	No
Lighting	
Instance on Room 1001	Inspected
Instance on Rooms 307, 325, 1007	Inspected
Instance on Room 251	Inspected
Instance on Room 413	Inspected
Instance on Room 411	Inspected
Instance on Room 351	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 1001	Inspected
Instance on Rooms 307, 325, 1007	Inspected
Instance on Room 413	Inspected
Instance on Room 251	Inspected
Instance on Room 351	Inspected
Instance on Room 411	Inspected
Pendant Mounted	
Instance on Room 1001	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 307, 325, 1007	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	56
Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

M477

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 413	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 251	Does not exist
Instance on Room 351	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 411	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Room 1001	Does not exist
Instance on Rooms 307, 325, 1007	Does not exist
Instance on Room 413	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 251	Does not exist
Instance on Room 351	Does not exist
Instance on Room 411	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room 1001	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
COMPUTER LAB	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on Rooms 307, 325, 1007	Does not exist
Instance on Room 413	Does not exist
Instance on Room 251	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 351	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Instance on Room 411	Does not exist
Lighting Fixture - HID	
Instance on Room 1001	Does not exist
Instance on Rooms 307, 325, 1007	Does not exist
Instance on Room 413	Does not exist
Instance on Room 251	Does not exist
Instance on Room 351	Does not exist
Instance on Room 411	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 1001	Does not exist
Instance on Rooms 307, 325, 1007	Does not exist
Instance on Room 413	Does not exist
Instance on Room 251	Does not exist
Instance on Room 351	Does not exist
Instance on Room 411	Does not exist
Lighting Fixture - LED	
Instance on Room 1001	Does not exist
Instance on Rooms 307, 325, 1007	Does not exist
Instance on Room 413	Does not exist
Instance on Room 251	Does not exist
Instance on Room 351	Does not exist
Instance on Room 411	Does not exist
Raceway With Receptacles	
Instance on Room 1001	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 307, 325, 1007	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 251	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 413	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 411	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
COMPUTER LAB	
Raceway With Receptacles	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 351	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
GYMNASIUM	
Instance on 3rd Floor	Inspected
Instance on 6th Floor	Inspected
Lighting	
Instance on 3rd Floor	Inspected
Instance on 6th Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 3rd Floor	Inspected
Instance on 6th Floor	Inspected
Pendant Mounted	
Instance on 3rd Floor	Does not exist
Instance on 6th Floor	Does not exist
Surface Mounted	
Instance on 3rd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 6th Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 3rd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 6th Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 3rd Floor	Inspected
Instance on 6th Floor	Inspected
Pendant Mounted	
Instance on 3rd Floor	Does not exist
Instance on 6th Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 3rd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 6th Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on 3rd Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	24
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on 6th Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 3rd Floor	Does not exist
Instance on 6th Floor	Does not exist
Lighting Fixture - LED	
Instance on 3rd Floor	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - LED	
Instance on 6th Floor	Does not exist
Local Sound System	
Instance on 3rd Floor	Under construction
Instance on 6th Floor	Under construction
Projection System	
Instance on 3rd Floor	Does not exist
Instance on 6th Floor	Does not exist
Scoreboard	
Instance on 3rd Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on 6th Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 3rd Floor	Does not exist
Instance on 6th Floor	Does not exist
KITCHEN	
	Inspected
Instance on 5th Floor	Inspected
Lighting	
Instance on 5th Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 5th Floor	Inspected
Pendant Mounted	
Instance on 5th Floor	Does not exist
Surface Mounted	
Instance on 5th Floor	Does not exist
Recessed Mounted	
Instance on 5th Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	53
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on 5th Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 5th Floor	Does not exist
Lighting Fixture - LED	
Instance on 5th Floor	Does not exist
LIBRARY	
	Inspected
Instance on Room 615	Inspected
Lighting	
Instance on Room 615	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 615	Inspected
Pendant Mounted	
Instance on Room 615	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
LIBRARY	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 615	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 615	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 615	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 615	Does not exist
Lighting Fixture - LED	
Instance on Room 615	Does not exist
Raceway With Receptacles	
Instance on Room 615	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Room 615	Does not exist
LOCKER ROOM	
Instance on Rooms G182 - Boys, G184 - Girls, G581 - Boys Visitors, G582 - Girls Visitors, G583 - Boys, G584 - Girls	Inspected
Alternative Use	No
Lighting	
Instance on Rooms G182 - Boys, G184 - Girls, G581 - Boys Visitors, G582 - Girls Visitors, G583 - Boys, G584 - Girls	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms G182 - Boys, G184 - Girls, G581 - Boys Visitors, G582 - Girls Visitors, G583 - Boys, G584 - Girls	Inspected
Pendant Mounted	
Instance on Rooms G182 - Boys, G184 - Girls, G581 - Boys Visitors, G582 - Girls Visitors, G583 - Boys, G584 - Girls	Does not exist
Surface Mounted	
Instance on Rooms G182 - Boys, G184 - Girls, G581 - Boys Visitors, G582 - Girls Visitors, G583 - Boys, G584 - Girls	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	69
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Rooms G182 - Boys, G184 - Girls, G581 - Boys Visitors, G582 - Girls Visitors, G583 - Boys, G584 - Girls	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
LOCKER ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Deficiency Quantity	66
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Rooms G182 - Boys, G184 - Girls, G581 - Boys Visitors, G582 - Girls Visitors, G583 - Boys, G584 - Girls	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms G182 - Boys, G184 - Girls, G581 - Boys Visitors, G582 - Girls Visitors, G583 - Boys, G584 - Girls	Does not exist
Lighting Fixture - LED	
Instance on Rooms G182 - Boys, G184 - Girls, G581 - Boys Visitors, G582 - Girls Visitors, G583 - Boys, G584 - Girls	Does not exist
MULTIPURPOSE ROOM	Inspected
Instance on Room G382	Inspected
Lighting	
Instance on Room G382	Inspected
Lighting Fixture - Fluorescent	
Instance on Room G382	Inspected
Pendant Mounted	
Instance on Room G382	Does not exist
Surface Mounted	
Instance on Room G382	Does not exist
Recessed Mounted	
Instance on Room G382	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	10
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room G382	Inspected
Pendant Mounted	
Instance on Room G382	Does not exist
Surface Mounted	
Instance on Room G382	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	
Instance on Room G382	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
MULTIPURPOSE ROOM	
Lighting	
Lighting Fixture - Incandescent	
Instance on Room G382	Does not exist
Lighting Fixture - LED	
Instance on Room G382	Does not exist
Local Sound System	
Instance on Room G382	Under construction
Projection System	
Instance on Room G382	Does not exist
Theater Lighting System	
Instance on Room G382	Does not exist
SCIENCE DEMO ROOM	
Instance on Rooms 715, 735, 833, 837, 935, 936	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Inspected
Power Panel?	No
Alternative Use	No
Lighting	
Instance on Rooms 715, 735, 833, 837, 935, 936	Inspected
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 715, 735, 833, 837, 935, 936	Inspected
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Inspected
Pendant Mounted	
Instance on Rooms 715, 735, 833, 837, 935, 936	Does not exist
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Does not exist
Surface Mounted	
Instance on Rooms 715, 735, 833, 837, 935, 936	Does not exist
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Does not exist
Recessed Mounted	
Instance on Rooms 715, 735, 833, 837, 935, 936	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	73
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	92
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Rooms 715, 735, 833, 837, 935, 936	Does not exist
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Does not exist
Lighting Fixture - Incandescent	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - Incandescent	
Instance on Rooms 715, 735, 833, 837, 935, 936	Inspected
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Inspected
Pendant Mounted	
Instance on Rooms 715, 735, 833, 837, 935, 936	Does not exist
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Does not exist
Surface Mounted	
Instance on Rooms 715, 735, 833, 837, 935, 936	Does not exist
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Does not exist
Recessed Mounted	
Instance on Rooms 715, 735, 833, 837, 935, 936	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	18
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - LED	
Instance on Rooms 715, 735, 833, 837, 935, 936	Does not exist
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Rooms 715, 735, 833, 837, 935, 936	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Rooms 715, 735, 833, 837, 935, 936	Does not exist
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Does not exist
Power Supply	
Instance on Rooms 715, 735, 833, 837, 935, 936	Inspected
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Inspected
Instructor Unit	
Instance on Rooms 715, 735, 833, 837, 935, 936	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SCIENCE DEMO ROOM	
Power Supply	
Meter Demonstration Unit	
Instance on Rooms 715, 735, 833, 837, 935, 936	Does not exist
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Does not exist
Projection System	
Instance on Rooms 715, 735, 833, 837, 935, 936	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 717, 737, 739, 829, 835, 839, 902, 939, 940	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SCIENCE LAB	
Instance on Room 903	Inspected
Power Panel?	No
Alternative Use	No
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Inspected
Power Panel?	No
Alternative Use	No
Instance on Rooms 803, 811, 913, 927	Inspected
Power Panel?	No
Alternative Use	No
Lighting	
Instance on Room 903	Inspected
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Inspected
Instance on Rooms 803, 811, 913, 927	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 903	Inspected
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Inspected
Instance on Rooms 803, 811, 913, 927	Inspected
Pendant Mounted	
Instance on Room 903	Does not exist
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Does not exist
Instance on Rooms 803, 811, 913, 927	Does not exist
Surface Mounted	
Instance on Room 903	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Does not exist
Instance on Rooms 803, 811, 913, 927	Does not exist
Recessed Mounted	
Instance on Room 903	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	14
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	88
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 803, 811, 913, 927	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	61
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Room 903	Does not exist
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Does not exist
Instance on Rooms 803, 811, 913, 927	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 903	Inspected
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Inspected
Instance on Rooms 803, 811, 913, 927	Inspected
Pendant Mounted	
Instance on Room 903	Does not exist
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Does not exist
Instance on Rooms 803, 811, 913, 927	Does not exist
Surface Mounted	
Instance on Room 903	Does not exist
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Does not exist
Instance on Rooms 803, 811, 913, 927	Does not exist
Recessed Mounted	
Instance on Room 903	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	14
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Incandescent	
Recessed Mounted	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 803, 811, 913, 927	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - LED	
Instance on Room 903	Does not exist
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Does not exist
Instance on Rooms 803, 811, 913, 927	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Room 903	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 803, 811, 913, 927	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 903	Does not exist
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Does not exist
Instance on Rooms 803, 811, 913, 927	Does not exist
Power Supply	
Instance on Room 903	Inspected
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Inspected
Instance on Rooms 803, 811, 913, 927	Inspected
Instructor Unit	
Instance on Room 903	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 803, 811, 913, 927	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 903	Does not exist
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Does not exist
Instance on Rooms 803, 811, 913, 927	Does not exist
Student Unit	

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SCIENCE LAB	
Power Supply	
Student Unit	
Instance on Room 903	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 803, 811, 913, 927	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Room 903	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 703, 709, 727, 731, 815, 827, 911	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 803, 811, 913, 927	Does not exist
SCIENCE PREP ROOM	Inspected
Instance on Room 807	Inspected
Power Panel?	Yes
Alternative Use	No
Instance on Room 809	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 817	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 907	Inspected
Power Panel?	No
Alternative Use	No
Instance on Room 707	Inspected
Power Panel?	No
Alternative Use	No
Instance on Rooms 702, 704, 729	Inspected
Power Panel?	No
Alternative Use	No
Instance on Rooms 705, 925	Inspected
Power Panel?	No
Alternative Use	No
Lighting	
Instance on Room 807	Inspected
Instance on Room 809	Inspected
Instance on Room 817	Inspected
Instance on Room 907	Inspected
Instance on Room 707	Inspected
Instance on Rooms 702, 704, 729	Inspected
Instance on Rooms 705, 925	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 705, 925	Inspected
Instance on Room 807	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Instance on Room 809	Inspected
Instance on Room 817	Inspected
Instance on Room 907	Inspected
Instance on Room 707	Inspected
Instance on Rooms 702, 704, 729	Inspected
Pendant Mounted	
Instance on Rooms 705, 925	Does not exist
Instance on Room 807	Does not exist
Instance on Room 809	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 817	Does not exist
Instance on Room 907	Does not exist
Instance on Room 707	Does not exist
Instance on Rooms 702, 704, 729	Does not exist
Surface Mounted	
Instance on Rooms 705, 925	Does not exist
Instance on Room 807	Does not exist
Instance on Room 809	Does not exist
Instance on Room 817	Does not exist
Instance on Room 907	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 707	Does not exist
Instance on Rooms 702, 704, 729	Does not exist
Recessed Mounted	
Instance on Rooms 705, 925	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	16
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 807	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	6
Quantity Uom	EACH

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 809	Does not exist
Instance on Room 817	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 907	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	6
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Room 707	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance on Rooms 702, 704, 729	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	12
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - HID	
Instance on Rooms 705, 925	Does not exist
Instance on Room 807	Does not exist
Instance on Room 809	Does not exist
Instance on Room 817	Does not exist
Instance on Room 907	Does not exist
Instance on Room 707	Does not exist
Instance on Rooms 702, 704, 729	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms 705, 925	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - Incandescent	
Instance on Room 807	Does not exist
Instance on Room 809	Does not exist
Instance on Room 817	Inspected
Instance on Room 907	Does not exist
Instance on Room 707	Does not exist
Instance on Rooms 702, 704, 729	Does not exist
Pendant Mounted	
Instance on Room 817	Does not exist
Surface Mounted	
Instance on Room 817	Does not exist
Recessed Mounted	
Instance on Room 817	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lighting Fixture - LED	
Instance on Rooms 705, 925	Does not exist
Instance on Room 807	Does not exist
Instance on Room 809	Does not exist
Instance on Room 817	Does not exist
Instance on Room 907	Does not exist
Instance on Room 707	Does not exist
Instance on Rooms 702, 704, 729	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Room 807	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 809	Does not exist
Instance on Room 817	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 907	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 707	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms 702, 704, 729	Does not exist
Instance on Rooms 705, 925	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 807	Does not exist
Instance on Room 809	Does not exist
Instance on Room 817	Does not exist
Instance on Room 907	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

M477

Question	Response
SCIENCE PREP ROOM	
Emergency Shut-Off Power	
Instance on Room 707	Does not exist
Instance on Rooms 702, 704, 729	Does not exist
Instance on Rooms 705, 925	Does not exist
Power Supply	
Instance on Room 807	Inspected
Instance on Room 809	Inspected
Instance on Room 817	Does not exist
Instance on Room 907	Inspected
Instance on Room 707	Does not exist
Instance on Rooms 702, 704, 729	Does not exist
Instance on Rooms 705, 925	Inspected
Instructor Unit	
Instance on Rooms 705, 925	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 807	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 809	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Room 907	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
SWIMMING POOL	Inspected
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Local Sound System	
Instance on 1st Floor	Under construction
Scoreboard	
Instance on 1st Floor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SWIMMING POOL	
Scoreboard	
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
TOILET ROOM - STAFF	
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	62
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	190
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	
Does not exist	
EMERGENCY GENERATOR SET	
Inspected	
Automatic Transfer Switch (ATS)	
Inspected	
Instance	Fire Pump Room C100K
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Firetrol
EquipmentId	Power Transfer Switch
Capacity/Size Quantity	100
Capacity/Size UOM	HP
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
EMERGENCY GENERATOR SET	
Automatic Transfer Switch (ATS)	
Deficiency	No deficiencies recorded
Instance	Penthouse
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	N/A
Capacity/Size Quantity	1200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Penthouse - Elevator Machine Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	N/A
Capacity/Size Quantity	800
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Room C023
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	ASCO
EquipmentId	PPEC Transfer SW.
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Battery Charger	Inspected
Instance	Penthouse - Emergency Generator Room
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	SENS
EquipmentId	Battery Charger
Capacity/Size Quantity	20
Capacity/Size UOM	AmpsDC
Capacity/Size 2 Quantity	24
Capacity/Size 2 UOM	VDC
Source of Capacity/Size	Nameplate
Installation Year	2017
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Emergency Distribution Board	Inspected
Number of Spares	2

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
EMERGENCY GENERATOR SET	
Emergency Distribution Board	
Fused Disconnect Switch Type	Inspected
Instance	Penthouse - Emergency Generator Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	N/A
Capacity/Size Quantity	1500
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Molded Case Circuit Breaker Type	Does not exist
Diesel	Inspected
Instance	Penthouse - Emergency Generator Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cummins Onan
EquipmentId	Emergency Generator
Capacity/Size Quantity	1000
Capacity/Size UOM	kVA
Capacity/Size 2 Quantity	800
Capacity/Size 2 UOM	kW
Capacity/Size 3 Quantity	2,777
Capacity/Size 3 UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Natural Gas	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Does not exist
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	FIXTURE LAMP NOT OPERATIONAL
Deficiency Location/Instance	Auditorium Mechanical Room, Corridor near Room 371
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
EXIT LIGHT	
Non Battery Pack	
Deficiency	FIXTURE LENS MISSING
Deficiency Location/Instance	Corridor near Room C027
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL LENS
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Under construction
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Inspected
Elevator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Holding Area	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MOTOR CONTROLLER	Inspected
MOTOR CONTROL CENTER	Inspected
Instance	Penthouse
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cutler Hammer
EquipmentId	MCC-R-1
Capacity/Size Quantity	1600
Capacity/Size UOM	Amps
Capacity/Size 2 Quantity	8
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Penthouse
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Cutler Hammer
EquipmentId	MCC-R-2
Capacity/Size Quantity	1600
Capacity/Size UOM	Amps
Capacity/Size 2 Quantity	9

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
MOTOR CONTROLLER	
MOTOR CONTROL CENTER	
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Does not exist
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD DOOR LOCK IS MISSING
Deficiency Location/Instance	Room 1007
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	NO SPARE
Deficiency Location/Instance	7th Floor Electrical Closet
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Under construction
SECURITY	Inspected
IPDVS/CCTV System	Inspected
Condition	3- Fair
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Room C121
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 50P
Installation Year	2010
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SECURITY	
Intrusion Alarm System	
Infrared Sensor	
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	
Condition	Inspected
Deficiency	No deficiencies recorded
Remote Annunciator	
Condition	Inspected
Deficiency	2- Between Good and Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
Condition	Inspected
Deficiency	3- Fair
Deficiency	No deficiencies recorded
Lighting - Security	
Condition	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Location/Instance	Building Perimeters
Deficiency Quantity	40
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 3
Violations	No violations recorded
SERVICE SWITCH	
Instance	Inspected
Instance	Electrical Room C153
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	Main Service Switch #1 Switchboard A
Capacity/Size Quantity	5000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room C153
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	Main Service Switch #2 Switchboard B
Capacity/Size Quantity	5000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room C153
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	Main Service Switch #1 Switchboard D

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SERVICE SWITCH	
Capacity/Size Quantity	5000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room C153
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	Main Service Switch #1 Switchboard C
Capacity/Size Quantity	5000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	Inspected
Number of Spares	2
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room C153
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	N/A
Capacity/Size Quantity	1500
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room C153
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	Switchboard D
Capacity/Size Quantity	5000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	3
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room C153
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	Switchboard C

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Capacity/Size Quantity	5000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	3
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room C153
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	Switchboard B
Capacity/Size Quantity	5000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	3
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room C153
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	Switchboard A
Capacity/Size Quantity	5000
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	3
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room C153
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	American Switchboard Co.
EquipmentId	N/A
Capacity/Size Quantity	1500
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Nameplate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	3- Fair

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Electrical Inspection

M477

Question	Response
TELEPHONE SYSTEM	
PBX/Intercom	
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TRANSFORMER	
	Inspected
Instance	Electrical Room C153
Instance Condition	3- Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Manufacturer	Power Guard
EquipmentId	Power Shield 2
Capacity/Size Quantity	150
Capacity/Size UOM	kVA
Source of Capacity/Size	Inspector Estimate
Installation Year	1992
Source of Installation Year	Documented
Deficiency	No deficiencies recorded