

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M751

Asset: P.S. 751 (CAR.DEV/OLD 25) - MANHATTAN, 113 EAST 4 STREET, MANHATTAN, NY, 10003

Inspection Id	Inspection Type	Time In	Last Edited
1265	MECHANICAL	2023-11-28 12:42PM	2024-01-10 10:04AM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Fixtures - Drinking Fountains Years: 2023 Systems: Steam Condensate Return Pumping System Years: 2022 Systems: Student Fixtures - Lavatory/Sinks (~60%), Toilets (~90%), Urinals (~90%) Years: 2019
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	3,500
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	Yes
Location(s)	Home Economics Room 405
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Closet inside Room 406 (painted, 2)
Are there any Emergency Stop Switches with Missing Hammers?	No components

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
Yes	Defective Emergency Stop Switch	Broken Glass	Boiler Emergency Stop Switch	Boiler Room Entrance	Anna Purpura	Custodian	No Photo Taken

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not exist
Pneumatic System	Inspected
Instance	Throughout except Cafeteria and Multipurpose Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Custodian's Official
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Hybrid System	Does not exist
Electric System	Does not exist
COMPACTOR	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M751

Question	Response
CONVEYING	Does not exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Does not exist
Hydraulic/Pneumatic Booster System	Inspected
Water Pressure Booster - Compressor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Pressure Booster Pump	Inspected
Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Domestic Cold Water Tank	Inspected
Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Water Service	Inspected
Instance	Boiler Room, Boiler Room - Vault
Instance Condition	3- Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	WATER MAIN:MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Boiler Room, Boiler Room - Vault
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not exist
Domestic Water Heat Exchanger	Does not exist
Electric Domestic Water Heater	Does not exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Precision
EquipmentId	N/A

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M751

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Gas Fired Domestic Water Heater	
Capacity/Size Quantity	400
Capacity/Size UOM	MBH Input
Capacity/Size 2 Quantity	425
Capacity/Size 2 UOM	Gallons
Source of Capacity/Size	Inspector Estimate
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	
Does not exist	
Heat Pump Domestic Water Heater	
Does not exist	
Domestic Water Distribution Piping	
Inspected	
Condition	3- Fair
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	
Inspected	
Interior Storm Piping	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	
Inspected	
Condition	3- Fair
Deficiency	SEWAGE/WASTE PIPING:DEFECTIVE/LEAKS
Deficiency Location/Instance	Crawlspace
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Sewage Ejector Pump	
Does not exist	
Sump Pump	
Inspected	
Condition	3- Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	
Does not exist	
FIXTURES	
Inspected	
Staff And Other	
Inspected	
Janitor Sink	
Inspected	
Condition	3- Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M751

Question	Response
FIXTURES	
Staff And Other	
Janitor Sink	
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lavatory/Sink	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Urinal	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Student	
	Inspected
Drinking Fountain	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Lavatory/Sink	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Locker Room Shower	
	Does not exist
Sink And Fountain Combo Unit	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Urinal	
	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	
	Does not exist
GAS SERVICE	
	Inspected
Gas Distribution Piping	
	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	
	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	
	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Eclipse

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M751

Question	Response
GAS SERVICE	
Gas Pressure Booster	
EquipmentId	N/A
Capacity/Size Quantity	5400
Capacity/Size UOM	SCFH
Source of Capacity/Size	Documented
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
CO/Gas Leak Detection	Inspected
Instance	Basement - Boiler Room, Gas Meter Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2001
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Does not exist
Hydronic Heating	Does not exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3- Fair
Deficiency	RADIATOR/CONVECTOR:DAMAGED GUARD/SHIELD
Deficiency Location/Instance	Auditorium, Corridor near Room 206
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	RADIATOR/CONVECTOR:MISSING GUARD/SHIELD
Deficiency Location/Instance	Rooms 405, 409
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	AUXILIARY (VALVE,VENT):DEFECTIVE
Deficiency Location/Instance	Corridors near Rooms 308, 508
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Does not exist
Steam Condensate Return Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	1- Good

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M751

Question	Response
HEATING	
Steam Heating	
Steam Condensate Return Pumping System	
Deficiency	No deficiencies recorded
Steam Piping	
Condition	3- Fair
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	Gas Meter Room, Crawlspace
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Terminal Unit Thermostatic Trap	
Condition	3- Fair
Deficiency	No deficiencies recorded
Steam supplied by External Sources	
Condition	Does not exist
Unit Heater/Cabinet Heater	
Condition	3- Fair
Deficiency	No deficiencies recorded
HEATING PLANT	
Instance on Basement	Inspected
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	Yes
Burner Manufacturer	Gordon-Piatt
Burner Model	S8.2-G0-15
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2
Boiler Auxiliaries	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room Entrance
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	FEEDWATER PUMP:DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Boiler Room (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M751

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Feedwater System	
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not exist
Hot Water Boiler	
Instance on Basement	Does not exist
Modular Boiler	
Instance on Basement	Does not exist
Steam Boiler	
Instance on Basement	Inspected
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1,560
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	A. L. Eastmond & Sons Inc.
EquipmentId	47820-01
Capacity/Size Quantity	1560
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2001
Source of Installation Year	Documented

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M751

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1,560
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	A. L. Eastmond & Sons Inc.
EquipmentId	47820-02
Capacity/Size Quantity	1560
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2001
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Fuel System	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Instance on Basement	Inspected
Instance Condition	3- Fair
Type	Automatic
Deficiency	DEFECTIVE ACTUATOR
Deficiency Location/Instance	Boiler Room @ Boiler #2
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	DUAL FUEL (OIL/GAS) BURNER:DEFECTIVE
Deficiency Location/Instance	Boiler Room @ Boiler #1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	Does not exist
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Not required

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M751

Question	Response
KITCHEN	
Gas System	
Instance on 1st Floor	Does not exist
Grease Trap	
Instance on 1st Floor	Does not exist
Hood	
Instance on 1st Floor	Does not exist
Hood Exhaust Ductwork	
Instance on 1st Floor	Does not exist
Hood Exhaust Fan	
Instance on 1st Floor	Does not exist
Hood Fire Suppression System	
Instance on 1st Floor	Does not exist
Hot Water Temperature Booster	
Instance on 1st Floor	Does not exist
Kitchen Sink	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	MISSING INDIRECT WASTE
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 4
Violations	SF101859
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
MDF Room	Inspected
Instance on Room 511	Inspected
Dedicated A/C Equipment	
Instance on Room 511	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Room 511
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Does not exist
SCIENCE PREP ROOM	Does not exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not exist
Wet Sprinkler Alarm Valve Assembly	Does not exist
Fire Booster Pump Assembly	Does not exist

**NYC Department of Education
Building Condition Assessment Survey 2023-2024**

Mechanical Inspection

M751

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Roof Tank	Does not exist
Siamese Connection	Does not exist
Sprinkler Head	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Closet inside Room 406 (painted, 2)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Sprinkler Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not exist
Water Gong	Does not exist
SWIMMING POOL	Does not exist
VENTILATION	Inspected
Is the building Mechanically ventilated?	No
Exhaust Fan	Inspected
Condition	4- Between Fair and Poor
Approximate Total # of Fans	1-25
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Boiler Room (1 of 3)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Heating And Ventilating Unit	Does not exist
Metal Ductwork	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	No
Are there chain operated dampers?	No
Deficiency	No deficiencies recorded
Supply Fan	Does not exist
Unit Ventilator	Does not exist