

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Asset: P.S. 82 - QUEENS, 88-02 144 STREET, New York, 11435

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q082	Electrical	2024-03-27 8:32 AM	2024-04-05 10:47 AM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Retrofitted LED Lighting - Except (Gymnasium)
	Years: 2024
	Systems: LAN
	Years: 2022
	Systems: Telephone System
	Years: 2018
	Systems: Most Exit Lights (Battery Pack), Partial Emergency Lighting (Battery Pack), Gymnasium (LED Lighting), Public Address System (Amplifier)
	Years: 2016
	Systems: Emergency Generator Set (Battery Charger)
	Years: 2014
	Systems: Intrusion Alarm System (Central Control Panel)
	Years: 2002
	Systems: Security Lights
	Years: 1995, 2024
	Systems: Public Address System, Fire Alarm System, Emergency Generator Set, Service Switch
	Years: 1995
	Systems: Most Molded Case Circuit Breaker Type Panel Board, Fused Disconnect Switch Type Panel Board
	Years: 1983, 1995, 2021
	Systems: Switchboard
	Years: 1983, 1995
	Systems: Fused Toggle Switch Type Panel Board
	Years: 1983

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	Yes
Are all dedicated intercoms operational?	Yes

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No	Water Leaks onto Electrical Equipment	N/A	Lighting Fixture	Stair B at Third Floor	Travis Balfour	Fireman	Sent to DSF	

Inspection

Question	Response
Electrical	
AUDITORIUM	Inspected
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
AUDITORIUM	
House Lighting	Inspected
Does a Chandelier exist?	No
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Does not Exist
Lighting Fixture - HID	
Instance on Basement	Does not Exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not Exist
Lighting Fixture - LED	
Instance on Basement	Inspected
Pendant Mounted	Does not Exist
Instance on Basement	Does not Exist
Surface Mounted	Does not Exist
Instance on Basement	Does not Exist
Recessed Mounted	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Local Sound System	Inspected
Instance on Basement	Inspected
Installation Year	1995
Source of Installation	Documented
Condition	5 - Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE SYSTEM
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Projection System	Inspected
Is the projector on a cart or installed on the ceiling?	Ceiling
Instance on Basement	Inspected
Condition	5 - Poor
Deficiency	VIDEO PROJECTOR IS NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Theater Lighting System	Inspected
Instance on Basement	Inspected
Dimming System	
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
AUDITORIUM	
Theater Lighting System	
Dimming System	
Condition	3 - Fair
Deficiency	DIMMING RACK/LIGHT CONSOLE BEYOND USEFUL LIFE
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Theater Lighting	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	196
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
CAFETERIA	
Instance on Basement	Inspected
Lighting	Inspected
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Does not Exist
Lighting Fixture - HID	
Instance on Basement	Does not Exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not Exist
Lighting Fixture - LED	
Instance on Basement	Inspected
Pendant Mounted	Does not Exist
Instance on Basement	Does not Exist
Surface Mounted	Does not Exist
Instance on Basement	Does not Exist
Recessed Mounted	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Local Sound System	Inspected
Instance on Basement	Inspected
Installation Year	1995
Source of Installation	Documented
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
CAFETERIA	Inspected
Projection System	Does not Exist
Instance on Basement	Does not Exist
Theater Lighting System	Does not Exist
Instance on Basement	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
COMPUTER LAB	Inspected
Instance on Room 215	Inspected
Power Panel	Yes
Lighting	Inspected
Instance on Room 215	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 215	Does not Exist
Lighting Fixture - HID	
Instance on Room 215	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 215	Does not Exist
Lighting Fixture - LED	
Instance on Room 215	Inspected
Pendant Mounted	Does not Exist
Instance on Room 215	Does not Exist
Surface Mounted	Does not Exist
Instance on Room 215	Does not Exist
Recessed Mounted	Inspected
Instance on Room 215	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Raceway With Receptacles	Inspected
Instance on Room 215	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance on 1st Floor	Inspected
Lighting	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
GYMNASIUM	
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not Exist
Surface Mounted	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not Exist
Local Sound System	
Instance on 1st Floor	Inspected
Installation Year	1995
Source of Installation	Documented
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not Exist
Scoreboard	
Instance on 1st Floor	Does not Exist
Theater Lighting System	
Instance on 1st Floor	Does not Exist
KITCHEN	
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Does not Exist
Lighting Fixture - HID	
Instance on Basement	Does not Exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not Exist
Lighting Fixture - LED	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not Exist
Surface Mounted	
Instance on Basement	Does not Exist
Recessed Mounted	
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
KITCHEN	Inspected
Lighting	
Lighting Fixture - LED	
Recessed Mounted	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
LIBRARY	Inspected
Instance on Room 214	Inspected
Lighting	Inspected
Instance on Room 214	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 214	Does not Exist
Lighting Fixture - HID	
Instance on Room 214	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 214	Does not Exist
Lighting Fixture - LED	
Instance on Room 214	Inspected
Pendant Mounted	Does not Exist
Instance on Room 214	Does not Exist
Surface Mounted	Does not Exist
Instance on Room 214	Does not Exist
Recessed Mounted	Inspected
Instance on Room 214	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Raceway With Receptacles	Does not Exist
Instance on Room 214	Does not Exist
Projection System	Does not Exist
Instance on Room 214	Does not Exist
LOCKER ROOM	Does not Exist
MULTIPURPOSE ROOM	Does not Exist
SCIENCE DEMO ROOM	Inspected
Instance on Room 119	Inspected
Power Panel	No
Alternative use	No
Lighting	Inspected
Instance on Room 119	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 119	Does not Exist
Lighting Fixture - HID	
Instance on Room 119	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 119	Does not Exist
Lighting Fixture - LED	
Instance on Room 119	Inspected
Pendant Mounted	Does not Exist
Instance on Room 119	Does not Exist
Surface Mounted	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - LED	
Surface Mounted	Does not Exist
Instance on Room 119	Does not Exist
Recessed Mounted	Inspected
Instance on Room 119	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Emergency Gas Shut-Off Valve	Inspected
Instance on Room 119	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	Does not Exist
Instance on Room 119	Does not Exist
Power Supply	Inspected
Instance on Room 119	Inspected
Instructor Unit	
Instance on Room 119	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 119	Does not Exist
Projection System	Does not Exist
Instance on Room 119	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SWIMMING POOL	Does not Exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Inspected
Condition	2 - Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - LED	
Pendant Mounted	Inspected
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Replacement Quantity	57,000
Replacement Uom	S.F.
Condition	3 - Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Inspected
Automatic Transfer Switch (ATS)	Inspected
Instance	Electrical Room (Sub-Basement)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Cummins Onan
Equipment	ATS #1
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1995
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room (Sub-Basement)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Cummins Onan
Equipment	ATS #2
Capacity/Size Quantity	40
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1995
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room (Sub-Basement)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Cummins Onan
Equipment	Fire Alarm A.T.S. /ATS #3

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
EMERGENCY GENERATOR SET	
Automatic Transfer Switch (ATS)	
Capacity/Size Quantity	40
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1995
Source of Installation	Documented
Deficiency	No deficiencies recorded
Battery Charger	
	Inspected
Instance	Electrical Room (Sub-Basement)
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	SENS
Equipment	Battery Charger
Capacity/Size Quantity	10
Capacity/Size UOM	AmpsDC
Capacity/Size2 Quantity	24
Capacity/Size2 UOM	VDC
Source of Capacity/Size	Nameplate
Installation Year	2014
Source of Installation	Documented
Deficiency	No deficiencies recorded
Emergency Distribution Board	
	Inspected
Number of Spares	1
Fused Disconnect Switch Type	
	Inspected
Instance	Electrical Room (Sub-Basement)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Siemens
Equipment	EM-MDP
Capacity/Size Quantity	400
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	1995
Source of Installation	Documented
Deficiency	No deficiencies recorded
Molded Case Circuit Breaker Type	
	Does not Exist
Diesel	
	Inspected
Instance	Electrical Room (Sub-Basement)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Cummins Onan
Equipment	Emergency Generator
Capacity/Size Quantity	125

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
EMERGENCY GENERATOR SET	
Diesel	
Capacity/Size UOM	KVA
Capacity/Size2 Quantity	100
Capacity/Size2 UOM	KW
Capacity/Size3Quantity	347
Capacity/Size3 UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1995
Source of Installation	Documented
Deficiency	No deficiencies recorded
Natural Gas	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	2 - Between Good and Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Kitchen near Exit 7
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 4
Deficiency Photo1	No photo recorded
Violations	35663358J
Non Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
EXIT/EMERGENCY LIGHT	Does not Exist
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	57,000
Replacement Uom	S.F.
Bell/Horn	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
FIRE ALARM SYSTEM	
Fan Shutdown Control	Inspected
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CO Detector	Does not Exist
Heat Detector	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Does not Exist
Fused Cutout Panel	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not Exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Edwards System Technology
Equipment	Fire Alarm Control Panel
Model	EST
Installation Year	1995
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not Exist
Sub-Panel	Inspected
Bell At Panel	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Auditorium Stage
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Edwards System Technology
Equipment	Deluge Valve Control Panel
Model	EST
Installation Year	1995

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
FIRE ALARM SYSTEM	
Sub-Panel	
Fire Alarm Control Panel (Electronic)	
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Auditorium Stage
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Edwards GS
Equipment	Emergency Control Panel
Model	5800
Installation Year	1995
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Entrance Lobby
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Edwards System Technology
Equipment	Purge Panel
Model	EST
Installation Year	1995
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not Exist
Remote Annunciator	Inspected
Display Monitor	Does not Exist
Panel	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Punch Register	Does not Exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	3 - Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	
Elevator	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Holding Area	Does not Exist
LAN	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
LAN	
Local Distribution Frame (I/LDF)	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not Exist
MOTOR CONTROLLER	Inspected
Motor Control Center	Does not Exist
Motor Starter/Contactor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Does not Exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not Exist
Fused Toggle Switch Type	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Molded Case Circuit Breaker Type	Inspected
Condition	3 - Fair
Deficiency	NO SPARE
Deficiency Location/Instance	Corridor by Rooms (102, 111, 313), Boiler Room
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Corridor by Room 305
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	57,000
Replacement Uom	S.F.
Instance	General Office
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
PUBLIC ADDRESS SYSTEM	
Model	Bogen Multicom - 2000
Installation Year	1995
Source of Installation	Documented
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Classrooms and Corridors
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
SECURITY	Inspected
IPDVS/CCTV System	Does not Exist
Intrusion Alarm System	Inspected
Replacement Quantity	57,000
Replacement Uom	S.F.
Central Control Panel	Inspected
Instance	Custodian's Office
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista-128B
Installation Year	2002
Source of Installation	Inspector Estimate
Deficiency	PANEL NOT CONNECTED TO DOE CENTRAL STATION
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL CONNECTION
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Infrared Sensor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting - Security	Inspected
Replacement Uom	EACH
Condition	1 - Good

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
SECURITY	Inspected
Lighting - Security	
Deficiency	No deficiencies recorded
SERVICE SWITCH	Inspected
Instance	Electrical Room (Sub-Basement)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Siemens
Equipment	Main Switch
Capacity/Size Quantity	2,000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1995
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room (Sub-Basement)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Siemens
Equipment	Exist. Main Switch
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1995
Source of Installation	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	Inspected
Number of Spares	1
Fused Disconnect Switch Type	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Metropolitan Electric
Equipment	Main Switch Board
Capacity/Size Quantity	600
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	1983
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Instance	Electrical Room (Sub-Basement)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q082

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Instance Manufacturer	Siemens
Equipment	N/A
Capacity/Size Quantity	2,000
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	2
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	1995
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Does not Exist
TELEPHONE SYSTEM	
PBX/Intercom	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
TRANSFORMER	Does not Exist