

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Asset: P.S. 108 - QUEENS, 108-10 109 AVENUE, New York, 11420

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q108	Mechanical	2023-12-05 7:36 AM	2024-05-02 6:50 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	2
Total capacity of all above ground tanks in gal.	10,275
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	4
MERs/Fan Rooms Locations	Sub-Basement East and West MERs, Sub-Basement Steam Condensate Return Pumping System MER, Fire Booster Pump Assembly Room B01, MER 546, Roof 1 - Tank Room
Are there any spaces with Missing or Defective CO Detectors?	Yes
Location(s)	Kitchen
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Sub Basement - Storage Room
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Gas Fired Domestic Water Heater; Domestic Hot Water Remote Storage Tank; Steam Condensate Return Pumping System
	Years: 2023
	Systems: Boiler #1 Retubed; Unit Heater/Cabinet Heater
	Years: 2022
	Systems: Boiler Safety Valves (2 of 4)
	Years: 2021
	Systems: F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps
	Years: 2020
	Systems: Chilled Water System - Backflow preventer; Refrigerant Leak Detection System
	Years: 2019
	Systems: Fixtures - Student: Toilets, Urinals; Fixtures - Staff and Other: Toilets
	Years: 2017

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Inspected
Absorption Chiller	Does not Exist
Air Cooled Chiller	Inspected
Instance	MER 546
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-22

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
AIR CONDITIONING	
Chilled Water System	
Air Cooled Chiller	
Instance Manufacturer	McQuay
Equipment	CH-1
Capacity/Size Quantity	112
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	MER 546
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-422B(NU-22B)
Instance Manufacturer	McQuay
Equipment	CH-2
Capacity/Size Quantity	112
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation	Documented
Deficiency	No deficiencies recorded
Air Cooled Condenser	Inspected
Instance	Building Addition - Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	C-1
Capacity/Size Quantity	112
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Building Addition - Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	C-2
Capacity/Size Quantity	112
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation	Documented
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
AIR CONDITIONING	
Chilled Water System	
Chilled Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Backflow Preventer	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	MER 546
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Central Station Air Handler	Inspected
Instance	MER 546
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	AHU-1
Capacity/Size Quantity	19,500
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	MER 546
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	AHU-2
Capacity/Size Quantity	11,200
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	MER 546
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	AHU-3
Capacity/Size Quantity	14,500
Capacity/Size UOM	CFM

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
AIR CONDITIONING	
Chilled Water System	
Central Station Air Handler	
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	MER 546
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	AHU-4
Capacity/Size Quantity	3,250
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	MER 546
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	McQuay
Equipment	AHU-5
Capacity/Size Quantity	4,030
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fan Coil Unit	Does not Exist
Packaged Air Cooled Chiller	Does not Exist
Water Cooled Chiller	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	3 - Fair
Deficiency	UP TO 5 TONS: DEFECTIVE
Deficiency Location/Instance	Kitchen Storage Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
AIR CONDITIONING	
DX Split System	Inspected
Outdoor Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Refrigerant Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Return Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Building Addition - Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	61-80%
Deficiency	DEFECTIVE VAV BOX
Deficiency Location/Instance	Throughout
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Original Building- Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Room 303, Staff Toilet Room 360
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
CLIMATE CONTROL SYSTEM	Inspected
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Inspected
Dumbwaiter	Does not Exist
Elevator	Inspected
Are all the existing elevators operable?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Inspected
Are all the existing ash hoists operable?	No
Condition	4 - Between Fair and Poor
Deficiency	No deficiencies recorded
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Inspected
Supply Pump	Does not Exist
Roof Tank	Inspected
Condition	3 - Fair
Deficiency	NOT IN USE
Deficiency Location/Instance	Roof - 1 Tank Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	NO ACTION
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 1
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Pressure Booster System	Inspected
Electric Pressure Booster System	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Canariis
Equipment	N/A
Capacity/Size Quantity	3
Capacity/Size UOM	Total # Pumps
Capacity/Size2 Quantity	20
Capacity/Size2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2000
Source of Installation	Inspector Estimate

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Pressure Booster System	Inspected
Electric Pressure Booster System	Inspected
Deficiency	No deficiencies recorded
Hydraulic/Pneumatic Booster System	Does not Exist
Water Service	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Fire Booster Pump Assembly Room B01
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Sub Basement near Gas Meter Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Laars
Equipment	N/A
Capacity/Size Quantity	199
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	0
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2023
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Boiler Room Entrance
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Sub-Basement Steam Condensate Return Pumping System Room, Fire Booster Assembly Room B01
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE CONTROLS
Deficiency Location/Instance	Sub-Basement Steam Condensate Return Pumping System Room, Fire Booster Pump Assembly Room B01
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	1 - Good

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
FIXTURES	
Staff And Other	Inspected
Toilet	Inspected
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Inspected
Instance	Boiler Room , Gas Meter Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2000
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
HEATING	
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE CONTROLS
Deficiency Location/Instance	Sub-Basement Steam Condensate Return Pumping System Room, Sub-Basement East MER
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE
Deficiency Location/Instance	Sub-Basement Steam Condensate Return Pumping System Room, Sub-Basement East MER
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
HEATING PLANT	
Replacement Quantity	12,996
Replacement Uom	MBH Net
Instance on Sub-Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
HEATING PLANT	
Burner Type	Dual Fuel (Gas/Oil)
Heating Plant Oil Number	2
Is there a water meter on the boiler make-up water piping?	Yes
Observed Operational?	No
Burner Exists?	Yes
Burner Manufacturer	Gordon Piatt
Burner Model Number	F14-GO-50
Boiler Auxiliaries	Inspected
Instance on Sub-Basement	Inspected
Boiler Auxiliary Piping	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Sub-Basement	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Flue Exhaust	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Sub-Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Sub-Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
HEATING PLANT	
Boiler System	
Coal-fired Boiler	
Instance on Sub-Basement	Does not Exist
Hot Water Boiler	
Instance on Sub-Basement	Does not Exist
Modular Boiler	
Instance on Sub-Basement	Does not Exist
Steam Boiler	
Instance on Sub-Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,498
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	7208-01
Capacity/Size Quantity	6,498
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,498
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	A. L. Eastmond & Sons Inc.
Equipment	7208-02
Capacity/Size Quantity	6,498
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2002
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fuel System	
Instance on Sub-Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist? Type	Yes Automatic
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Sub-Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
HEATING PLANT	
Fuel System	
Fuel Oil Storage/Supply System	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	
Instance on Closets Adjacent to Rooms 207, 307, 407, 507	Inspected
Dedicated A/C Equipment	
Instance on Closets Adjacent to Rooms 207, 307, 407, 507	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Closets Adjacent to Rooms 207, 307, 407, 507
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/MISSING
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Gas System	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Grease Trap	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
	Inspected

**NYC Department of Education
Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q108

Question	Response
KITCHEN	
Hood Exhaust Ductwork	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hot Water Temperature Booster	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Kitchen Sink	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Original Building- Cafeteria Closet	Inspected
Dedicated A/C Equipment	Inspected
Instance on Original Building- Cafeteria Closet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Does not Exist
Fire Booster Pump Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Roof Tank	Does not Exist
Siamese Connection	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Sub - Basement Storage Room
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Sprinkler Head	Inspected
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Standpipe System	Inspected
Hose Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Piping	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	DEFECTIVE MOTOR
Deficiency Location/Instance	Original Building Roof/ 5th Floor Boys Bathroom Exhaust
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	Yes
Condition	3 - Fair
Deficiency	DAMAGED FLEXIBLE CONNECTION
Deficiency Location/Instance	Sub-Basement West MER, MER 546/AHU-1, Boiler Room Entrance / Auditorium Exhaust , RF-4, Toilet Exhaust
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	Inspected
Approximate Total # of Fans	1-5
Condition	3 - Fair
Deficiency	No deficiencies recorded
Unit Ventilator	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q108

Question	Response
VENTILATION	
Unit Ventilator	
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE FRESH AIR INTAKE
Deficiency Location/Instance	Throughout
Deficiency Quantity	20
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.