

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

**Asset:** P.S. 127 - QUEENS, 98-01 25 AVENUE, New York, 11369

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q127	Electrical	2023-11-08 8:14 AM	2023-11-17 1:19 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	Yes
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: IPDVS/CCTV System
	Years: Under Construction
	Systems: Auditorium - Except (Projection System), Intrusion Alarm System - Except (Siren/Strobe), LAN, Retrofitted LED Lighting, Security Lights
	Years: 2023
	Systems: Most Emergency Lighting (Battery Pack), Partial Emergency Lighting (Non Battery Pack), Most Exit Lights (Battery Pack), Public Address System (Most Clocks)
	Years: 2020
	Systems: Gymnasium (Partial LED Lighting)
	Years: 2016
	Systems: Public Address System (Amplifier)
	Years: 2014
	Systems: Cafeteria (Local Sound System)
	Years: 2011
	Systems: Partial Fused Disconnect Switch Type Panel Board, Partial Service Switch
	Years: 1998
	Systems: Emergency Light/Exit Light Panel
	Years: 1995
	Systems: Molded Case Circuit Breaker Type Panel Board
	Years: 1992, 1998, 2009, 2020

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
Yes	Water Penetration in Electrical Room	N/A	Electrical Equipment	Main Electrical Switch Room	Shemar Williams	Fireman	Sent to DSF	

Inspection

Question	Response
<b>Electrical</b>	
<b>AUDITORIUM</b>	Inspected
Instance on 1st Floor	Inspected
<b>House Lighting</b>	Inspected
Does a Chandelier exist?	No
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

Question	Response
<b>AUDITORIUM</b>	
<b>House Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	
Instance on 1st Floor	Does not Exist
<b>Surface Mounted</b>	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	
Instance on 1st Floor	Does not Exist
<b>Local Sound System</b>	
Instance on 1st Floor	Inspected
Installation Year	2023
Source of Installation	Custodial Staff
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Projection System</b>	
Is the projector on a cart or installed on the ceiling?	Ceiling
Instance on 1st Floor	Inspected
Condition	5 - Poor
Deficiency	VIDEO PROJECTOR IS NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Theater Lighting System</b>	
Instance on 1st Floor	Inspected
<b>Dimming System</b>	
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Theater Lighting</b>	
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>CAFETERIA</b>	
Instance on 1st Floor	Inspected
<b>Lighting</b>	
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

Question	Response
<b>CAFETERIA</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	Does not Exist
Instance on 1st Floor	Does not Exist
<b>Surface Mounted</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Local Sound System</b>	Inspected
Instance on 1st Floor	Inspected
Installation Year	2011
Source of Installation	Inspector Estimate
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Projection System</b>	Does not Exist
Instance on 1st Floor	Does not Exist
<b>Theater Lighting System</b>	Does not Exist
Instance on 1st Floor	Does not Exist
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>Lighting</b>	Inspected
Does a Chandelier exist?	No
<b>Lighting Fixture - Fluorescent</b>	Does not Exist
<b>Lighting Fixture - HID</b>	Does not Exist
<b>Lighting Fixture - Incandescent</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>COMPUTER LAB</b>	Does not Exist
<b>GYMNASIUM</b>	Inspected
Instance on 3rd Floor	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

Question	Response
<b>GYMNASIUM</b>	
<b>Lighting</b>	Inspected
Instance on 3rd Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 3rd Floor	Does not Exist
<b>Lighting Fixture - HID</b>	
Instance on 3rd Floor	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 3rd Floor	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on 3rd Floor	Inspected
<b>Pendant Mounted</b>	Inspected
Instance on 3rd Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Does not Exist
Instance on 3rd Floor	Does not Exist
<b>Recessed Mounted</b>	Inspected
Instance on 3rd Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Local Sound System</b>	Inspected
Instance on 3rd Floor	Inspected
Installation Year	1966
Source of Installation	Inspector Estimate
Condition	5 - Poor
Deficiency	AMPLIFIER NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE SYSTEM
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Projection System</b>	Does not Exist
Instance on 3rd Floor	Does not Exist
<b>Scoreboard</b>	Inspected
Instance on 3rd Floor	Inspected
Condition	5 - Poor
Deficiency	NOT OPERATIONAL
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Theater Lighting System</b>	Does not Exist
Instance on 3rd Floor	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

Question	Response
<b>KITCHEN</b>	Inspected
Instance on 1st Floor	Inspected
<b>Lighting</b>	Inspected
Instance on 1st Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - HID</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 1st Floor	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on 1st Floor	Inspected
<b>Pendant Mounted</b>	Does not Exist
Instance on 1st Floor	Does not Exist
<b>Surface Mounted</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>LIBRARY</b>	Inspected
Instance on Room 301	Inspected
<b>Lighting</b>	Inspected
Instance on Room 301	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 301	Does not Exist
<b>Lighting Fixture - HID</b>	
Instance on Room 301	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 301	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on Room 301	Inspected
<b>Pendant Mounted</b>	Inspected
Instance on Room 301	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Does not Exist
Instance on Room 301	Does not Exist
<b>Recessed Mounted</b>	Does not Exist
Instance on Room 301	Does not Exist
<b>Raceway With Receptacles</b>	Does not Exist
Instance on Room 301	Does not Exist
<b>Projection System</b>	Does not Exist
Instance on Room 301	Does not Exist
<b>LOCKER ROOM</b>	Inspected
Instance on 4th Floor	Inspected
Alternative use	Yes

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

Question	Response
<b>LOCKER ROOM</b>	
<b>Lighting</b>	Inspected
Instance on 4th Floor	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on 4th Floor	Does not Exist
<b>Lighting Fixture - HID</b>	
Instance on 4th Floor	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on 4th Floor	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on 4th Floor	Inspected
<b>Pendant Mounted</b>	Does not Exist
Instance on 4th Floor	Does not Exist
<b>Surface Mounted</b>	Inspected
Instance on 4th Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not Exist
Instance on 4th Floor	Does not Exist
<b>MULTIPURPOSE ROOM</b>	Does not Exist
<b>SCIENCE DEMO ROOM</b>	Does not Exist
<b>SCIENCE LAB</b>	Inspected
Instance on Room 408	Inspected
Power Panel	No
Alternative use	No
<b>Lighting</b>	Inspected
Instance on Room 408	Inspected
<b>Lighting Fixture - Fluorescent</b>	
Instance on Room 408	Does not Exist
<b>Lighting Fixture - HID</b>	
Instance on Room 408	Does not Exist
<b>Lighting Fixture - Incandescent</b>	
Instance on Room 408	Does not Exist
<b>Lighting Fixture - LED</b>	
Instance on Room 408	Inspected
<b>Pendant Mounted</b>	Inspected
Instance on Room 408	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Does not Exist
Instance on Room 408	Does not Exist
<b>Recessed Mounted</b>	Does not Exist
Instance on Room 408	Does not Exist
<b>Emergency Gas Shut-Off Valve</b>	Inspected
Instance on Room 408	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Emergency Shut-Off Power</b>	Does not Exist
Instance on Room 408	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

<b>Question</b>	<b>Response</b>
<b>SCIENCE LAB</b>	Inspected
<b>Power Supply</b>	Does not Exist
Instance on Room 408	Does not Exist
<b>Projection System</b>	Does not Exist
Instance on Room 408	Does not Exist
<b>SCIENCE PREP ROOM</b>	Does not Exist
<b>SWIMMING POOL</b>	Does not Exist
<b>TOILET ROOM - STAFF</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Does not Exist
<b>Lighting Fixture - HID</b>	Does not Exist
<b>Lighting Fixture - Incandescent</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not Exist
<b>TOILET ROOM - STUDENT</b>	Inspected
<b>Lighting</b>	Inspected
<b>Lighting Fixture - Fluorescent</b>	Does not Exist
<b>Lighting Fixture - HID</b>	Does not Exist
<b>Lighting Fixture - Incandescent</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Inspected
<b>Pendant Mounted</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Surface Mounted</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not Exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Inspected
Replacement Quantity	94,000
Replacement Uom	S.F.
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not Exist
<b>EMERGENCY GENERATOR SET</b>	Does not Exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Condition	3 - Fair
Deficiency	LESS THAN 20% SPARE CIRCUIT BREAKERS
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

Question	Response
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Inspected
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>EXIT LIGHT</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Non Battery Pack</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>EXIT/EMERGENCY LIGHT</b>	Does not Exist
<b>FIRE ALARM SYSTEM</b>	Inspected
Replacement Quantity	94,000
Replacement Uom	S.F.
<b>Bell/Horn</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Strobe</b>	Does not Exist
<b>Manual Pull Station</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Fan Shutdown Control</b>	Does not Exist
<b>Duct Smoke Detector</b>	Does not Exist
<b>Area Smoke Detector</b>	Does not Exist
<b>CO Detector</b>	Does not Exist
<b>Heat Detector</b>	Does not Exist
<b>Elevator Recall</b>	Does not Exist
<b>Magnetic Door Holder/Contactor</b>	Does not Exist
<b>Fused Cutout Panel</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Digital Communicator</b>	Does not Exist
<b>Main Panel</b>	Inspected
<b>Bell At Panel</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Fire Alarm Control Panel (Electronic)</b>	Does not Exist
<b>Fire Alarm Control Panel (Standard)</b>	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH



**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

Question	Response
<b>FIRE ALARM SYSTEM</b>	
<b>Main Panel</b>	
<b>Fire Alarm Control Panel (Standard)</b>	
Instance Manufacturer	ACME
Equipment	Fire Alarm Control Board
Installation Year	1966
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Sub-Panel</b>	Does not Exist
<b>Remote Annunciator</b>	Does not Exist
<b>Sprinkler Flow/Air Pressure Switch</b>	Does not Exist
<b>Tamper Flow Switch/Chain</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>GROUNDING SYSTEM</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>INTERCOM SYSTEM</b>	Does not Exist
<b>LAN</b>	Inspected
<b>Local Distribution Frame (I/LDF)</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Main Equipment Rack (MDF)</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>LIGHTNING PROTECTION</b>	Does not Exist
<b>MOTOR CONTROLLER</b>	Inspected
<b>Motor Control Center</b>	Does not Exist
<b>Motor Starter/Contactor</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Variable Frequency Drive</b>	Does not Exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Inspected
Condition	3 - Fair
Deficiency	PANEL BOARD DOOR LOCK IS MISSING
Deficiency Location/Instance	Mechanical Room 464
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room, Mechanical Room 464
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

Question	Response
<b>PANEL BOARD</b>	
<b>Fused Disconnect Switch Type</b>	Inspected
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Fused Knife Switch Type</b>	Does not Exist
<b>Fused Toggle Switch Type</b>	Inspected
Condition	3 - Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	PANEL BOARD DOOR LOCK IS MISSING
Deficiency Location/Instance	Electrical Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	NO SPARE
Deficiency Location/Instance	Kitchen, 3rd Floor Corridor by Room 305
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	PANEL BOARD COVER IS MISSING
Deficiency Location/Instance	Main Electrical Switch Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 2
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>PUBLIC ADDRESS SYSTEM</b>	Inspected
Replacement Quantity	94,000

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

Question	Response
<b>PUBLIC ADDRESS SYSTEM</b>	
Replacement Uom	S.F.
Instance	General Office
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	1966
Source of Installation	Inspector Estimate
Deficiency	MICROPHONE / JACK NOT OPERATIONAL
Deficiency Location/Instance	General Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Corridors
Deficiency Quantity	8
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
<b>SECURITY</b>	Inspected
<b>IPDVS/CCTV System</b>	Under Construction
<b>Intrusion Alarm System</b>	Inspected
Replacement Quantity	94,000
Replacement Uom	S.F.
<b>Central Control Panel</b>	Inspected
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	2023
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Infrared Sensor</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Panic Switch</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Remote Annunciator</b>	Inspected
Condition	1 - Good

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

Question	Response
<b>SECURITY</b>	
<b>Intrusion Alarm System</b>	
<b>Remote Annunciator</b>	Inspected
Deficiency	No deficiencies recorded
<b>Siren/Strobe</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Lighting - Security</b>	Inspected
Replacement Uom	EACH
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>SERVICE SWITCH</b>	
	Inspected
Instance	Main Electrical Switch Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pacific Electric
Equipment	N/A
Capacity/Size Quantity	2,000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1965
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Electrical Switch Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	General Electric
Equipment	N/A
Capacity/Size Quantity	200
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
<b>SWITCHBOARD</b>	
	Inspected
Number of Spares	0
<b>Fused Disconnect Switch Type</b>	
	Inspected
Instance	Electrical Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pacific Electric
Equipment	N/A
Capacity/Size Quantity	2,000
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	3
Capacity/Size2 UOM	Section(S)

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q127

Question	Response
<b>SWITCHBOARD</b>	
<b>Fused Disconnect Switch Type</b>	Inspected
Source of Capacity/Size	Service Switch Size
Installation Year	1965
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Fused Knife Switch Type</b>	Does not Exist
<b>Molded Case Circuit Breaker Type</b>	Does not Exist
<b>TELEPHONE SYSTEM</b>	
<b>PBX/Intercom</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Standard</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>TRANSFORMER</b>	Does not Exist