

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Asset: P.S. 164 - QUEENS, 138-01 77 AVENUE, New York, 11367

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q164	Mechanical	2023-11-08 7:34 AM	2023-11-16 3:55 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	0
Total capacity of all above ground tanks in gal.	0
Total # of below ground tanks	2
Total capacity of all below ground tanks in gal.	15,000
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	MERs B5, 206, 226, 316, Fan Rooms 219, 326
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	Yes
Component Affected	Boiler Emergency Stop Switch
Location	Boiler Room Entrance
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Room 227
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Electric Domestic Water Heater
	Years: 2023
	Systems: Kitchen - Grease Trap; Fixtures - Staff: Urinals
	Years: 2022
	Systems: Boiler Make-up Water Backflow Preventer
	Years: 2021
	Systems: Sump Pump
	Years: 2019
	Systems: DX Split System for TV Studio Room 228 Office; MDF Room - Dedicated A/C Equipment (DX Split System); Enclosed IDF Room 217 - Dedicated A/C Equipment (DX Split System)
	Years: 2018
	Systems: Non-auditorium Handicap Lift - Stair
	Years: 2017
	Systems: F&T/Steam Drip Traps; Terminal Unit Thermostatic Traps ; Boiler Feedwater System; Boiler Feedwater Treatment (Automatic)
	Years: 2016
	Systems: Water Service (1 of 3)
	Years: 2015
	Systems: Water Service (1 of 3)
	Years: 2014
	Systems: Science Demo Rooms
	Years: 2013

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Question	Response
AIR CONDITIONING	
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	UP TO 5 TONS: DEFECTIVE
Deficiency Location/Instance	TV Studio Room 228 Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Outdoor Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	UP TO 5 TONS: DEFECTIVE
Deficiency Location/Instance	2nd Floor Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Inspected
Instance	2nd Floor Roof
Instance Condition	4 - Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	N/A
Refrigerant Type	R-22
Instance Manufacturer	Trane
Equipment	N/A
Capacity/Size Quantity	18
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	1989
Source of Installation	Inspector Estimate
Deficiency	UP TO 20 TONS: DEFECTIVE/DETERIORATED COIL - EVAP
Deficiency Location/Instance	2nd Floor Roof
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Question	Response
AIR CONDITIONING	
Packaged / Rooftop Unit	Inspected
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	
CONVEYING	Inspected
Dumbwaiter	Does not Exist
Elevator	Does not Exist
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Inspected
Are all the existing non-auditorium handicap stair lifts operable?	Yes
Condition	1 - Good
Deficiency	No deficiencies recorded
Ash Hoist	Inspected
Are all the existing ash hoists operable?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Inspected
Instance	Boiler Room
Instance Condition	4 - Between Fair and Poor
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Canariis
Equipment	N/A

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Pressure Booster System	
Electric Pressure Booster System	
Capacity/Size Quantity	3
Capacity/Size UOM	Total # Pumps
Capacity/Size2 Quantity	13
Capacity/Size2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	1996
Source of Installation	Documented
Deficiency	DEFECTIVE PUMP
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hydraulic/Pneumatic Booster System	Does not Exist
Water Service	Inspected
Instance	Boiler Room (Domestic)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Boiler Room (Sprinkler)
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Room B10 Crawlspace (Domestic)
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Electric Domestic Water Heater	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Under Construction
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Question	Response
DOMESTIC WATER SYSTEM	Inspected
Domestic Water Distribution Piping	Inspected
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Question	Response
GAS SERVICE	
Gas Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Does not Exist
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Does not Exist
HEATING	
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
HEATING PLANT	
Replacement Quantity	54
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Oil
Heating Plant Oil Number	2(B10)
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Preferred Utilities
Burner Model Number	BHE6-3A4
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	MISSING HAMMER
Deficiency Location/Instance	Boiler Room Entrance
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE RPZ
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Question	Response
HEATING PLANT	
Boiler System	Inspected
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	27
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Farrar & Trefts, Inc
Equipment	37348-01
Capacity/Size Quantity	45
Capacity/Size UOM	Burner GPH
Source of Capacity/Size	Documented
Installation Year	1948
Source of Installation	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	27
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Farrar & Trefts, Inc
Equipment	37348-02
Capacity/Size Quantity	45
Capacity/Size UOM	Burner GPH
Source of Capacity/Size	Documented
Installation Year	1948
Source of Installation	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Question	Response
HEATING PLANT	
Boiler System	Inspected
Steam Boiler	
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not Exist
Enclosed IDF Room	Inspected
Instance on Room 217	Inspected
Instance on Room 222	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 222	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 222
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Room 217	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
KITCHEN	Inspected
Instance on 1st Floor	Inspected
CO Detector	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas System	Does not Exist
Instance on 1st Floor	Does not Exist
Grease Trap	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Question	Response
KITCHEN	
Grease Trap	
Instance on 1st Floor	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/CLOGGED
Deficiency Location/Instance	Room B10 Crawlspace
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hood	
Instance on 1st Floor	Does not Exist
Hood Exhaust Ductwork	
Instance on 1st Floor	Does not Exist
Hood Exhaust Fan	
Instance on 1st Floor	Does not Exist
Hood Fire Suppression System	
Instance on 1st Floor	Does not Exist
Hot Water Temperature Booster	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Kitchen Sink	
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	
Instance on Gymnasium Closet	Inspected
Dedicated A/C Equipment	
Instance on Gymnasium Closet	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	
Instance on Rooms 233, 235	Inspected
Alternative use	No
Acid Waste Neutralizing Tank	
Instance on Rooms 233, 235	Does not Exist
CO Detector	
Instance on Rooms 233, 235	Not Required
Emergency Shower	
Instance on Rooms 233, 235	Does not Exist
Eye Wash	
Instance on Rooms 233, 235	Does not Exist
Hood Exhaust Ductwork	
Instance on Rooms 233, 235	Does not Exist
Hood Exhaust Fan	
	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Question	Response
SCIENCE DEMO ROOM	
Hood Exhaust Fan	Does not Exist
Instance on Rooms 233, 235	Does not Exist
Fixed Laboratory Hood	Does not Exist
Instance on Rooms 233, 235	Does not Exist
Laboratory Sink	Inspected
Instance on Rooms 233, 235	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Rooms 233, 235	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Does not Exist
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Does not Exist
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Room 227
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	Yes
Condition	3 - Fair
Deficiency	DAMAGED FLEXIBLE CONNECTION
Deficiency Location/Instance	MER 226/Gymnasium Exhauster , Fan Room 219/ House Exhauster

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q164

Question	Response
VENTILATION	
Metal Ductwork	
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	
Inspected	Inspected
Approximate Total # of Fans	6-10
Condition	3 - Fair
Deficiency	No deficiencies recorded
Unit Ventilator	Does not Exist