

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q173

Asset: P.S. 173 - QUEENS, 174-10 67TH AVENUE, New York, 11365

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q173	Mechanical	2023-10-24 7:47 AM	2023-11-03 3:56 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	2
Total capacity of all above ground tanks in gal.	15,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Boiler Room MER, Basement Stair B MER, Basement Fan Room, MERs 210, 220, 310, 322
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Room 208
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Steam Condensate Return Pumping System; Boiler Fresh Air Louver/Damper (1 of 4); Boiler Safety Valves on Boiler #2 (2 of 4)
	Years: 2021
	Systems: F&T/Steam Drip Traps (90%); Terminal Unit Thermostatic Traps ; Kitchen - Hood Exhaust Fan
	Years: 2020
	Systems: Water Service (1 of 3); Boiler Make-up Water Backflow Preventer in Crawlspace
	Years: 2019
	Systems: Fixtures - Student: Urinals (34%)
	Years: 2018
	Systems: Fixtures - Student: Urinals (66%)
	Years: 2017
	Systems: Climate Control System - Pneumatic System: Pneumatic PRV Station, Refrigerated Air Dryer; MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2016
	Systems: Boiler Fresh Air Louver/Dampers (3 of 4)
	Years: 2015

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No	Defective Boiler Safety Auxiliary	Boiler#1 - Safety Valve leaking (1 of 2)	HEATING PLANT Boiler Auxiliaries Boiler Safety Valve	Boiler Room/Boiler#1	William Magsamen	Custodian	Sent to DSF	
Yes	Defective Sprinkler/Stand pipe System	Defective Wet Sprinkler Alarm Valve Assembly	SPRINKLERS, STANDPIPE, FIRE SYSTEM Wet Sprinkler Alarm Valve Assembly	Boiler Room Crawlspace	William Magsamen	Custodian	Sent to DSF	

Inspection

Question	Response
----------	----------

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q173

Question	Response
Mechanical	
AIR CONDITIONING	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Basement East Crawlspace
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement East Crawlspace
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room Crawlspace (Domestic)
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Boiler Room Crawlspace (Sprinkler)

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q173

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Boiler Room Crawlspace (Sprinkler)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Electric Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Laars
Equipment	N/A
Capacity/Size Quantity	325
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	0
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Inspector Estimate
Installation Year	1990
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q173

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Sewage Ejector Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	
Does not Exist	
FIXTURES	
Inspected	
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Boys Toilet Room 226
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Locker Room Shower	Inspected
Instance on 1st Floor - Boys	Inaccessible
Instance on 1st Floor - Girls	Inaccessible
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q173

Question	Response
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Does not Exist
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Does not Exist
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	RADIATOR/CONVECTOR: DEFECTIVE
Deficiency Location/Instance	Cafeteria
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Does not Exist
HEATING PLANT	Inspected
Replacement Quantity	10,808
Replacement Uom	MBH Net

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q173

Question	Response
HEATING PLANT	
Instance on Basement	Inspected
Burner Type	Oil
Heating Plant Oil Number	4
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Preferred Utilities
Burner Model Number	HE7-3A4
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Does not Exist
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler#1 (Safety valve leaking)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler System	Inspected
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q173

Question	Response
HEATING PLANT	
Boiler System	
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	5,404
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Farrar & Trefths, Inc
Equipment	38182-1
Capacity/Size Quantity	60
Capacity/Size UOM	Burner GPH
Source of Capacity/Size	Documented
Installation Year	1949
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	5,404
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Farrar & Trefths, Inc
Equipment	38182-2
Capacity/Size Quantity	60
Capacity/Size UOM	Burner GPH
Source of Capacity/Size	Documented
Installation Year	1949
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fuel System	
	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	OIL BURNER: DEFECTIVE
Deficiency Location/Instance	Boiler Room / Boiler #2 (oil leak at solenoid)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q173

Question	Response
HEATING PLANT	
Fuel System	
Burner/Burner Control Panel	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not Exist
Enclosed IDF Room	Inspected
Instance on Room 209A	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 209A	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Room 209A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
KITCHEN	Inspected
Instance on 1st Floor	Inspected
CO Detector	Not Required
Instance on 1st Floor	Not Required
Gas System	Does not Exist
Instance on 1st Floor	Does not Exist
Grease Trap	Does not Exist
Instance on 1st Floor	Does not Exist
Hood	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Does not Exist
Instance on 1st Floor	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q173

Question	Response
KITCHEN	
Hot Water Temperature Booster	Does not Exist
Instance on 1st Floor	Does not Exist
Kitchen Sink	Inspected
Instance on 1st Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room 222	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 222	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Boiler Room Crawlspace
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Does not Exist
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Room 208
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q173

Question	Response
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	Yes
Condition	3 - Fair
Deficiency	DAMAGED FLEXIBLE CONNECTION
Deficiency Location/Instance	MER 322 / House Blower B-11
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	Inspected
Approximate Total # of Fans	6-10
Condition	3 - Fair
Deficiency	No deficiencies recorded
Unit Ventilator	Does not Exist