

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Asset: I.S. 238 - QUEENS, 88-15 182 STREET, New York, 11423

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q238	Mechanical	2023-12-26 7:55 AM	2024-02-28 3:34 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	2
Total capacity of all above ground tanks in gal.	30,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Penthouse MER, Ground Floor Staircase B MER.
Are there any spaces with Missing or Defective CO Detectors?	Yes
Location(s)	Science Lab 353, Science Prep Room 353A
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Boiler Room - Fireman's Office, Rooms G31A, G31B, 139, 139B, 251, 329 (painted)
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Sewage Ejector Pumps
	Years: 2024
	Systems: Steam Condensate Return Pumping Systems; Gas Fired Domestic Water Heater; Climate Control System - Pneumatic System: Air Compressor, Refrigerated Air Dryers, Pneumatic PRV Station; Fixtures - Student: Drinking Fountains (60%), Lavatories/Sinks (25%), Toilets (25%), Urinals (25%); F&T/Steam Drip Traps, Boiler Safety Valves
	Years: 2023
	Systems: Eye Wash in Science Demo Rooms 153, 155
	Years: 2022
	Systems: Boiler Make-Up Water Backflow Preventer; Boiler Feedwater Treatment (Automatic)
	Years: 2020
	Systems: Climate Control System: Temperature Control Thermostats (50%), Terminal Unit Control Valves (50%); Electric Domestic Water Heater in Kitchen; Kitchen - Sinks, Hood Exhaust Fan
	Years: 2018
	Systems: Kitchen - Grease Trap
	Years: 2017
	Systems: Gas Meter Room Exhaust Fan
	Years: 2016
	Systems: Fixtures - Student: Lavatories/Sinks (25%), Toilets (25%); Urinals (25%)
	Years: 2015
	Systems: Terminal Unit Thermostatic Traps; Boiler Fresh Air Louver/Dampers
	Years: 2014
	Systems: MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2013

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
-------------------------------------	-------------------	-----------------------	--------------------	----------------------	--------------------	-----------------	--------	------------

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

No	Other	Construction fence blocks access to Siamese Connections	Siamese Connection	All sides of the school	Kevin Fitzgerald Custodian	Sent to DSF
----	-------	---	--------------------	-------------------------	----------------------------	-------------

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Inspected
Absorption Chiller	Does not Exist
Air Cooled Chiller	Inspected
Instance	Penthouse MER
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-22
Instance Manufacturer	Trane
Equipment	Chiller #2
Capacity/Size Quantity	40
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1972
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Penthouse MER
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Refrigerant Type	R-22
Instance Manufacturer	Trane
Equipment	Chiller #1
Capacity/Size Quantity	40
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1972
Source of Installation	Documented
Deficiency	No deficiencies recorded
Air Cooled Condenser	Inspected
Instance	Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Trane
Equipment	Condenser #1
Capacity/Size Quantity	40
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1972
Source of Installation	Documented

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
AIR CONDITIONING	
Chilled Water System	
Air Cooled Condenser	
Deficiency	No deficiencies recorded
Instance	Roof
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Trane
Equipment	Condenser #2
Capacity/Size Quantity	40
Capacity/Size UOM	Tons
Source of Capacity/Size	Inspector Estimate
Installation Year	1972
Source of Installation	Documented
Deficiency	No deficiencies recorded
Chilled Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Backflow Preventer	Does not Exist
Central Station Air Handler	Inspected
Instance	Penthouse MER
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	American Air Filter
Equipment	Library Supply 46
Capacity/Size Quantity	5
Capacity/Size UOM	Fan Motor HP
Source of Capacity/Size	Documented
Installation Year	1972
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Penthouse MER
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	American Air Filter
Equipment	Auditorium Supply 49
Capacity/Size Quantity	15
Capacity/Size UOM	Fan Motor HP
Source of Capacity/Size	Documented
Installation Year	1972
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fan Coil Unit	Does not Exist
Packaged Air Cooled Chiller	Does not Exist
Water Cooled Chiller	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
AIR CONDITIONING	
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Return Fan	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CENTRAL ACID WASTE NEUTRALIZING TANK	
Condition	3 - Fair
Deficiency	No deficiencies recorded
CLIMATE CONTROL SYSTEM	
BMS	Does not Exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	DEFECTIVE DAMPER ACTUATOR
Deficiency Location/Instance	Penthouse - MER by AHUs - Auditorium Supply 49 and Library Supply 46 (disconnected)
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Kitchen, Rooms 239, Science Prep Room 333 and other locations
Deficiency Quantity	15
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
CLIMATE CONTROL SYSTEM	Inspected
Pneumatic System	Inspected
Violations	No violations recorded.
Hybrid System	Does not Exist
Electric System	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Inspected
Dumbwaiter	Does not Exist
Elevator	Inspected
Are all the existing elevators operable?	Yes
Condition	3 - Fair
Deficiency	No deficiencies recorded
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Does not Exist
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Does not Exist
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Inspected
Electric Pressure Booster System	Does not Exist
Hydraulic/Pneumatic Booster System	Inspected
Water Pressure Booster - Compressor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Pressure Booster Pump	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room (leaking)
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Cold Water Tank	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	Inspected
Instance	Basement - Crawlspace
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement - Crawlspace
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Basement - Gas Meter Room
Instance Condition	3 - Fair
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement - Gas Meter Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Electric Domestic Water Heater	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	RayPak
Equipment	N/A
Capacity/Size Quantity	250
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	0
Capacity/Size2 UOM	Gallons

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Gas Fired Domestic Water Heater	
Source of Capacity/Size	Documented
Installation Year	2023
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	2 - Between Good and Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Boys Locker Room (missing)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo 1	No photo recorded
Violations	No violations recorded.

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
FIXTURES	
Student	
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Inspected
Instance on Ground Floor - Boys	Inaccessible
Instance on Ground Floor - Girls	Inaccessible
Sink And Fountain Combo Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Meter Room Vent	Does not Exist
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Does not Exist
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Steam Piping	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
HEATING	
Steam Heating	
Steam Piping	
Condition	3 - Fair
Deficiency	DEFECTIVE/LEAKS
Deficiency Location/Instance	Room 151
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Terminal Unit Thermostatic Trap	
Condition	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Throughout
Deficiency Quantity	250
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Steam supplied by External Sources	
Does not Exist	
Unit Heater/Cabinet Heater	
Inspected	
Condition	3 - Fair
Deficiency	No deficiencies recorded
HEATING PLANT	
Inspected	
Replacement Quantity	18,051
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Oil
Heating Plant Oil Number	2(B10)
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Preferred Utilities
Burner Model Number	BHE7-3A4
Boiler Auxiliaries	
Inspected	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Feedwater System	
Deficiency	No deficiencies recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,017
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Kewanee Boiler Corporation
Equipment	56374-01
Capacity/Size Quantity	7,750
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	1972
Source of Installation	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,017
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Kewanee Boiler Corporation
Equipment	56374-03
Capacity/Size Quantity	7,750
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	1972
Source of Installation	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	80
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	6,017
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Kewanee Boiler Corporation
Equipment	56374-02
Capacity/Size Quantity	7,750
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	1972
Source of Installation	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	3

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	20
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not Exist
Enclosed IDF Room	Inspected
Instance on Rooms 126, 156, 356	Inspected
Dedicated A/C Equipment	
Instance on Rooms 126, 156, 356	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Rooms 126, 156, 356
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
KITCHEN	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
KITCHEN	
Instance on Ground Floor	Inspected
CO Detector	Inspected
Instance on Ground Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas System	Inspected
Instance on Ground Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Grease Trap	Inspected
Instance on Ground Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood	Inspected
Instance on Ground Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Inspected
Instance on Ground Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	Inspected
Instance on Ground Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Hood Fire Suppression System	Does not Exist
Instance on Ground Floor	Does not Exist
Hot Water Temperature Booster	Does not Exist
Instance on Ground Floor	Does not Exist
Kitchen Sink	Inspected
Instance on Ground Floor	Inspected
Condition	1 - Good
Deficiency	MISSING AIR GAP
Deficiency Location/Instance	Kitchen
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
MDF Room	Inspected
Instance on Room 329A	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 329A	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Inspected
Instance on Room 355	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
SCIENCE DEMO ROOM	
Alternative use	No
Instance on Rooms 153, 155	Inspected
Alternative use	No
Instance on Rooms 253, 255	Inspected
Alternative use	No
Acid Waste Neutralizing Tank	
Instance on Rooms 253, 255	Does not Exist
Instance on Rooms 153, 155	Does not Exist
Instance on Room 355	Does not Exist
CO Detector	
Instance on Rooms 253, 255	Not Required
Instance on Rooms 153, 155	Not Required
Instance on Room 355	Not Required
Emergency Shower	
Instance on Rooms 253, 255	Does not Exist
Instance on Rooms 153, 155	Does not Exist
Instance on Room 355	Does not Exist
Eye Wash	
Instance on Rooms 253, 255	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms 153, 155	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Instance on Room 355	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on Rooms 253, 255	Does not Exist
Instance on Rooms 153, 155	Does not Exist
Instance on Room 355	Does not Exist
Hood Exhaust Fan	
Instance on Rooms 253, 255	Does not Exist
Instance on Rooms 153, 155	Does not Exist
Instance on Room 355	Does not Exist
Fixed Laboratory Hood	
Instance on Rooms 253, 255	Does not Exist
Instance on Rooms 153, 155	Does not Exist
Instance on Room 355	Does not Exist
Laboratory Sink	
Instance on Rooms 253, 255	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Rooms 153, 155	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 355	Inspected
Condition	4 - Between Fair and Poor

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
SCIENCE DEMO ROOM	
Laboratory Sink	
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Room 355
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Make-up Air Unit	
	Does not Exist
Instance on Rooms 253, 255	Does not Exist
Instance on Rooms 153, 155	Does not Exist
Instance on Room 355	Does not Exist
SCIENCE LAB	
	Inspected
Instance on Room 353	Inspected
Alternative use	No
Acid Waste Neutralizing Tank	
	Inspected
Instance on Room 353	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CO Detector	
	Inspected
Instance on Room 353	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/MISSING
Deficiency Location/Instance	Room 353
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Emergency Shower	
	Does not Exist
Instance on Room 353	Does not Exist
Eye Wash	
	Inspected
Instance on Room 353	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
	Does not Exist
Instance on Room 353	Does not Exist
Hood Exhaust Fan	
	Does not Exist
Instance on Room 353	Does not Exist
Fixed Laboratory Hood	
	Does not Exist
Instance on Room 353	Does not Exist
Laboratory Sink	
	Inspected
Instance on Room 353	Inspected
Condition	4 - Between Fair and Poor

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
SCIENCE LAB	
Laboratory Sink	
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Room 353 (3 of 5)
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Make-up Air Unit	
	Does not Exist
Instance on Room 353	Does not Exist
SCIENCE PREP ROOM	
	Inspected
Instance on Room 333	Inspected
Alternative use	No
Instance on Room 353A	Inspected
Alternative use	No
Acid Waste Neutralizing Tank	
	Inspected
Instance on Room 353A	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 333	Does not Exist
CO Detector	
	Inspected
Instance on Room 353A	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/MISSING
Deficiency Location/Instance	Room 353A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Room 333	Not Required
Emergency Shower	
	Inspected
Instance on Room 353A	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 333	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Eye Wash	
	Inspected
Instance on Room 353A	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 333	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
SCIENCE PREP ROOM	
Hood Exhaust Ductwork	Inspected
Instance on Room 353A	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 333	Does not Exist
Hood Exhaust Fan	Inspected
Instance on Room 353A	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 333	Does not Exist
Fixed Laboratory Hood	Inspected
Instance on Room 353A	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 333	Does not Exist
Laboratory Sink	Inspected
Instance on Room 353A	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 333	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Inspected
Instance on Room 353A	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Instance on Room 333	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not Exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Booster Pump Assembly	Does not Exist
Roof Tank	Does not Exist
Siamese Connection	Inspected
Condition	3 - Fair
Deficiency	MISSING CAPS
Deficiency Location/Instance	182nd Street by the Main Entrance, 182nd Place
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Head	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE/DETERIORATED

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q238

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Sprinkler Head	
Deficiency Location/Instance	Boiler Room - Fireman's Office, Rooms G31A, G31B, 139, 139B, 251, 329 (painted)
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Sprinkler Piping	
Condition	Inspected
Deficiency	3 - Fair
Standpipe System	
Condition	Does not Exist
Water Gong	
Condition	Does not Exist
SWIMMING POOL	
Condition	Does not Exist
VENTILATION	
Is the building mechanically ventilated?	Inspected
Condition	Partial
Exhaust Fan	
Approximate Total # of Fans	Inspected
Condition	26-50
Deficiency	3 - Fair
Heating And Ventilating Unit	
Condition	Inspected
Deficiency	3 - Fair
Metal Ductwork	
Are there any uninsulated ductwork by design in Mechanical Rooms?	Inspected
Are there chain operated dampers?	Yes
Condition	No
Deficiency	3 - Fair
Supply Fan	
Approximate Total # of Fans	Inspected
Condition	1-5
Deficiency	3 - Fair
Unit Ventilator	
Condition	Inspected
Deficiency	3 - Fair