

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

**Asset:** P.S. 339 - QUEENS, 39-07 57TH STREET, New York, 11377

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q339	Mechanical	2023-09-27 8:01 AM	2023-10-27 12:13 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	275
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	3
MERs/Fan Rooms Locations	Fire Booster Pump Assembly Room C08K
Are there any spaces with Missing or Defective CO Detectors?	Yes
Location(s)	Kitchen
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Climate Control System - BMS; Sump Pump
	Years: 2023
	Systems: Kitchen - Hot Water Temperature Booster; Boiler Make-up Water Backflow Preventer
	Years: 2022

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
<b>Mechanical</b>	
<b>AIR CONDITIONING</b>	Inspected
<b>Chilled Water System</b>	Inspected
<b>Absorption Chiller</b>	Does not Exist
<b>Air Cooled Chiller</b>	Does not Exist
<b>Air Cooled Condenser</b>	Does not Exist
<b>Chilled Water Distribution: Piping, Pumps and Auxiliaries</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Backflow Preventer</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Central Station Air Handler</b>	Inspected
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Seasons.4
Equipment	DOAS-02
Capacity/Size Quantity	13,000
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

Question	Response
<b>AIR CONDITIONING</b>	
<b>Chilled Water System</b>	
<b>Central Station Air Handler</b>	
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Seasons.4
Equipment	AHU-2
Capacity/Size Quantity	7,000
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Seasons.4
Equipment	DOAS-01
Capacity/Size Quantity	12,500
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Trane
Equipment	AHU-1
Capacity/Size Quantity	6,000
Capacity/Size UOM	CFM
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Fan Coil Unit</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Packaged Air Cooled Chiller</b>	Inspected
Instance	Main Roof
Instance Condition	1 - Good
Instance Quantity	1

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

Question	Response
<b>AIR CONDITIONING</b>	
<b>Chilled Water System</b>	
<b>Packaged Air Cooled Chiller</b>	
Instance Quantity Uom	EACH
Refrigerant Type	R-410A
Instance Manufacturer	Airstack
Equipment	Chiller #1
Capacity/Size Quantity	300
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Water Cooled Chiller</b>	Does not Exist
<b>Condenser Water Distribution: Piping, Pumps and Auxiliaries</b>	Does not Exist
<b>Cooling Coil in Ductwork</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Cooling Tower</b>	Does not Exist
<b>DX Split System</b>	Inspected
<b>Indoor Unit</b>	
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Outdoor Unit</b>	
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Dry Cooler</b>	Does not Exist
<b>Packaged / Rooftop Unit</b>	Does not Exist
<b>Packaged Terminal A/C</b>	Does not Exist
<b>Refrigerant Leak Detection System</b>	Does not Exist
<b>Refrigerant Piping</b>	
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Return Fan</b>	Does not Exist
<b>CENTRAL ACID WASTE NEUTRALIZING TANK</b>	Does not Exist
<b>CLIMATE CONTROL SYSTEM</b>	Inspected
<b>BMS</b>	
Instance	Throughout
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Installation Year	2023
Source of Installation	Custodial Staff
Deficiency	No deficiencies recorded
<b>Pneumatic System</b>	Does not Exist
<b>Hybrid System</b>	Does not Exist
<b>Electric System</b>	Does not Exist
<b>COMPACTOR</b>	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

Question	Response
<b>CONVEYING</b>	Inspected
<b>Dumbwaiter</b>	Does not Exist
<b>Elevator</b>	Inspected
Are all the existing elevators operable?	Yes
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Escalator</b>	Does not Exist
<b>Non-auditorium Handicap Lift - Vertical</b>	Does not Exist
<b>Non-auditorium Handicap Lift - Stair</b>	Inspected
Are all the existing non-auditorium handicap stair lifts operable?	No
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Ash Hoist</b>	Does not Exist
<b>Sidewalk Elevator</b>	Does not Exist
<b>DOMESTIC WATER SYSTEM</b>	Inspected
<b>Domestic Cold Water System</b>	Inspected
<b>Gravity System</b>	Does not Exist
<b>Pressure Booster System</b>	Inspected
<b>Electric Pressure Booster System</b>	Inspected
Instance	Room C08J
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Federal Pump
Equipment	N/A
Capacity/Size Quantity	2
Capacity/Size UOM	Total # Pumps
Capacity/Size2 Quantity	15
Capacity/Size2 UOM	Total Pumps HP
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Documented
Deficiency	RUSTY/LEAKY VALVES AND PIPE FITTINGS
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE PUMP
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

Question	Response
<b>DOMESTIC WATER SYSTEM</b>	
<b>Domestic Cold Water System</b>	
<b>Pressure Booster System</b>	
<b>Electric Pressure Booster System</b>	
Deficiency	PRE-CHARGED TANK RUSTY/LEAK
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Hydraulic/Pneumatic Booster System</b>	
	Does not Exist
<b>Water Service</b>	
	Inspected
Instance	Room C07
Instance Condition	1 - Good
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	Room C08J
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
<b>Domestic Hot Water System</b>	
	Inspected
<b>Domestic Hot Water Remote Storage Tank</b>	
	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Domestic Water Heat Exchanger</b>	
	Does not Exist
<b>Electric Domestic Water Heater</b>	
	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Heat Pump Domestic Water Heater</b>	
	Does not Exist
<b>Gas Fired Domestic Water Heater</b>	
	Inspected
Instance	Room 509
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Lochinvar
Equipment	N/A
Capacity/Size Quantity	500
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	0
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

Question	Response
<b>DOMESTIC WATER SYSTEM</b>	
<b>Domestic Hot Water System</b>	
<b>Gas Fired Domestic Water Heater</b>	Inspected
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>Oil Fired Domestic Water Heater</b>	Does not Exist
<b>Domestic Water Distribution Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>DRAIN/WASTE/VENT AND STORM SYSTEM</b>	Inspected
<b>Interior Storm Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Sewage/Waste/Vent Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Sewage Ejector Pump</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Room C08J (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Sump Pump</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)</b>	Does not Exist
<b>FIXTURES</b>	Inspected
<b>Staff And Other</b>	Inspected
<b>Janitor Sink</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Toilet</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Urinal</b>	Does not Exist
<b>Student</b>	Inspected
<b>Drinking Fountain</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Lavatory/Sink</b>	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

Question	Response
<b>FIXTURES</b>	
<b>Student</b>	
<b>Lavatory/Sink</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Locker Room Shower</b>	Does not Exist
<b>Sink And Fountain Combo Unit</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Toilet</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Urinal</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>GAS FIRED FURNACE</b>	Does not Exist
<b>GAS SERVICE</b>	Inspected
<b>Gas Distribution Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Gas Meter Room Exhaust Fan</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Gas Meter Room Vent</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Gas Pressure Booster</b>	Does not Exist
<b>CO/Gas Leak Detection</b>	Inspected
Instance	Boiler Room, Room 509, Gas Meter Room C08L
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
<b>HEATING</b>	Inspected
<b>Heating Coil In Ductwork</b>	Does not Exist
<b>Hydronic Heating</b>	Inspected
<b>Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Backflow Preventer</b>	Does not Exist
<b>Hot Water Heat Exchanger</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Radiator/Convactor/Fin Tube</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Steam Heating</b>	Does not Exist
<b>Steam supplied by External Sources</b>	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

Question	Response
<b>HEATING</b>	Inspected
<b>Unit Heater/Cabinet Heater</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>HEATING PLANT</b>	Inspected
Replacement Quantity	2,782
Replacement Uom	MBH Net
Instance on Penthouse	Inspected
Burner Type	Gas
Heating Plant Oil Number	N/A
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	No
<b>Boiler Auxiliaries</b>	Inspected
Instance on Penthouse	Inspected
<b>Boiler Auxiliary Piping</b>	
Instance on Penthouse	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Boiler Emergency Stop Switch</b>	
Instance on Penthouse	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Boiler Feedwater System</b>	
Instance on Penthouse	Does not Exist
<b>Boiler Feedwater Treatment(Automatic)</b>	
Instance on Penthouse	Does not Exist
<b>Boiler Flue Exhaust</b>	
Instance on Penthouse	Does not Exist
<b>Boiler Make-up Water Backflow Preventer</b>	
Instance on Penthouse	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Boiler Room Steam And Condensate Piping</b>	
Instance on Penthouse	Does not Exist
<b>Boiler Safety Valve</b>	
Instance on Penthouse	Does not Exist
<b>Boiler System</b>	Inspected
Instance on Penthouse	Inspected
<b>Coal-fired Boiler</b>	
Instance on Penthouse	Does not Exist
<b>Hot Water Boiler</b>	
Instance on Penthouse	Does not Exist
<b>Modular Boiler</b>	
Instance on Penthouse	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1,391
Instance Quantity Uom	MBH Net
Instance Manufacturer	AERCO
Equipment	167007-01



**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

Question	Response
<b>HEATING PLANT</b>	Inspected
<b>Boiler System</b>	
<b>Modular Boiler</b>	
Capacity/Size Quantity	2,000
Capacity/Size UOM	MBH Input
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Documented
Deficiency	DEFECTIVE FLUE EXHAUST
Deficiency Location/Instance	Boiler Room (minor rust)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1,391
Instance Quantity Uom	MBH Net
Instance Manufacturer	AERCO
Equipment	167007-02
Capacity/Size Quantity	2,000
Capacity/Size UOM	MBH Input
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Documented
Deficiency	DEFECTIVE FLUE EXHAUST
Deficiency Location/Instance	Boiler Room (minor rust)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Steam Boiler</b>	
Instance on Penthouse	Does not Exist
<b>Fuel System</b>	Inspected
Instance on Penthouse	Inspected
<b>Boiler Fresh Air Louver/Damper</b>	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Penthouse	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Burner/Burner Control Panel</b>	
Instance on Penthouse	Does not Exist
<b>Fuel Oil Storage/Supply System</b>	

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

<b>Question</b>	<b>Response</b>
<b>HEATING PLANT</b>	Inspected
<b>Fuel System</b>	
Instance on Penthouse	Does not Exist
<b>Gas Trains And Vent At The Boiler</b>	
Instance on Penthouse	Does not Exist
<b>Enclosed IDF Room</b>	Inspected
Instance on Room C08A	Inspected
Instance on Room 406	Inspected
<b>Dedicated A/C Equipment</b>	Inspected
Instance on Room 406	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Room 406
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Instance on Room C08A	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>KITCHEN</b>	Inspected
Instance on 1st Floor	Inspected
<b>CO Detector</b>	Inspected
Instance on 1st Floor	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE/MISSING
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Gas System</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Grease Trap</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood Exhaust Ductwork</b>	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

Question	Response
<b>KITCHEN</b>	
<b>Hood Exhaust Ductwork</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood Exhaust Fan</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood Fire Suppression System</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hot Water Temperature Booster</b>	Inspected
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Kitchen Sink</b>	Inspected
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>MDF Room</b>	Inspected
Instance on Room 206	Inspected
<b>Dedicated A/C Equipment</b>	Inspected
Instance on Room 206	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>SCIENCE DEMO ROOM</b>	Does not Exist
<b>SCIENCE LAB</b>	Inspected
Instance on Room 516	Inspected
Alternative use	No
<b>Acid Waste Neutralizing Tank</b>	Does not Exist
Instance on Room 516	Does not Exist
<b>CO Detector</b>	Not Required
Instance on Room 516	Not Required
<b>Emergency Shower</b>	Does not Exist
Instance on Room 516	Does not Exist
<b>Eye Wash</b>	Inspected
Instance on Room 516	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Hood Exhaust Ductwork</b>	Does not Exist
Instance on Room 516	Does not Exist
<b>Hood Exhaust Fan</b>	Does not Exist
Instance on Room 516	Does not Exist
<b>Fixed Laboratory Hood</b>	Does not Exist
Instance on Room 516	Does not Exist
<b>Laboratory Sink</b>	Inspected
Instance on Room 516	Inspected
Condition	2 - Between Good and Fair

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

Question	Response
<b>SCIENCE LAB</b>	Inspected
<b>Laboratory Sink</b>	Inspected
Deficiency	No deficiencies recorded
<b>Make-up Air Unit</b>	Does not Exist
Instance on Room 516	Does not Exist
<b>SCIENCE PREP ROOM</b>	Inspected
Instance on Room 516A	Inspected
Alternative use	Yes
<b>Acid Waste Neutralizing Tank</b>	Does not Exist
Instance on Room 516A	Does not Exist
<b>CO Detector</b>	Not Required
Instance on Room 516A	Not Required
<b>Emergency Shower</b>	Does not Exist
Instance on Room 516A	Does not Exist
<b>Eye Wash</b>	Does not Exist
Instance on Room 516A	Does not Exist
<b>Hood Exhaust Ductwork</b>	Does not Exist
Instance on Room 516A	Does not Exist
<b>Hood Exhaust Fan</b>	Does not Exist
Instance on Room 516A	Does not Exist
<b>Fixed Laboratory Hood</b>	Does not Exist
Instance on Room 516A	Does not Exist
<b>Laboratory Sink</b>	Inspected
Instance on Room 516A	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Make-up Air Unit</b>	Does not Exist
Instance on Room 516A	Does not Exist
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	Inspected
<b>Dry Sprinkler Alarm Valve Assembly</b>	Does not Exist
<b>Wet Sprinkler Alarm Valve Assembly</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Fire Booster Pump Assembly</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Roof Tank</b>	Does not Exist
<b>Siamese Connection</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Sprinkler Head</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Sprinkler Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Standpipe System</b>	Inspected
<b>Hose Valve Assembly</b>	Inspected
Condition	1 - Good

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q339

Question	Response
<b>SPRINKLERS, STANDPIPE, FIRE SYSTEM</b>	
<b>Standpipe System</b>	Inspected
<b>Hose Valve Assembly</b>	Inspected
Deficiency	No deficiencies recorded
<b>Piping</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Water Gong</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>SWIMMING POOL</b>	
Does not Exist	
<b>VENTILATION</b>	
Inspected	
Is the building mechanically ventilated?	Yes
<b>Exhaust Fan</b>	
Inspected	
Approximate Total # of Fans	1-25
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Heating And Ventilating Unit</b>	
Does not Exist	
<b>Metal Ductwork</b>	
Inspected	
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>Supply Fan</b>	
Inspected	
Approximate Total # of Fans	1-5
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Unit Ventilator</b>	
Does not Exist	