

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q378

Asset: PRE-K CENTER @ 46-16 76TH STREET - QUEENS, 46-16 76 STREET, New York, 11373

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q378	Mechanical	2024-02-13 7:52 AM	2024-02-20 4:27 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No	Defective CO/Gas Leak Detection	CO/Gas Leak Detection Panels Faulty	GAS SERVICE CO/Gas Leak Detection	Custodian Office, Boiler Room	Veronica Warmly	Custodian	Sent to DSF	

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Inspected
Instance	Roof
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Source of Heating	Gas
Refrigerant Type	R-410A
Instance Manufacturer	Daikin
Equipment	N/A
Capacity/Size Quantity	33
Capacity/Size UOM	Tons
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q378

Question	Response
AIR CONDITIONING	
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	
	Does not Exist
CLIMATE CONTROL SYSTEM	
	Inspected
BMS	Does not Exist
Pneumatic System	Does not Exist
Hybrid System	Does not Exist
Electric System	Inspected
Instance	Throughout
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	
	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Room 114
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	
	Inspected
Interior Storm Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q378

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Sewage/Waste/Vent Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Does not Exist
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Does not Exist
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Does not Exist
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2015
Source of Installation	Documented
Deficiency	DEFECTIVE CONTROL PANEL

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q378

Question	Response
GAS SERVICE	
CO/Gas Leak Detection	
Deficiency Location/Instance	Custodian Office, Boiler Room
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPAIR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
HEATING	
	Inspected
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Inspected
Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Backflow Preventer	Does not Exist
Hot Water Heat Exchanger	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Radiator/Convactor/Fin Tube	Does not Exist
Steam Heating	Does not Exist
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
HEATING PLANT	
	Inspected
Replacement Quantity	338
Replacement Uom	MBH Net
Instance on Penthouse	Inspected
Burner Type	Gas
Heating Plant Oil Number	N/A
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	No
Boiler Auxiliaries	Inspected
Instance on Penthouse	Inspected
Boiler Auxiliary Piping	
Instance on Penthouse	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Penthouse	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Penthouse	Does not Exist
Boiler Feedwater Treatment(Automatic)	
Instance on Penthouse	Does not Exist
Boiler Flue Exhaust	
Instance on Penthouse	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q378

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Make-up Water Backflow Preventer	
Instance on Penthouse	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Penthouse	Does not Exist
Boiler Safety Valve	
Instance on Penthouse	Does not Exist
Boiler System	
Instance on Penthouse	Inspected
Coal-fired Boiler	
Instance on Penthouse	Does not Exist
Hot Water Boiler	
Instance on Penthouse	Does not Exist
Modular Boiler	
Instance on Penthouse	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	169
Instance Quantity Uom	MBH Net
Instance Manufacturer	Viessmann
Equipment	166729-01
Capacity/Size Quantity	169
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	169
Instance Quantity Uom	MBH Net
Instance Manufacturer	Viessmann
Equipment	166729-02
Capacity/Size Quantity	169
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
Steam Boiler	
Instance on Penthouse	Does not Exist
Fuel System	
Instance on Penthouse	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Penthouse	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q378

Question	Response
HEATING PLANT	
Fuel System	
Boiler Fresh Air Louver/Damper	
Condition	1 - Good
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Penthouse	Does not Exist
Fuel Oil Storage/Supply System	
Instance on Penthouse	Does not Exist
Gas Trains And Vent At The Boiler	
Instance on Penthouse	Does not Exist
Enclosed IDF Room	Does not Exist
KITCHEN	
Instance on 1st Floor	Inspected
CO Detector	
Instance on 1st Floor	Not Required
Gas System	
Instance on 1st Floor	Does not Exist
Grease Trap	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood	
Instance on 1st Floor	Does not Exist
Hood Exhaust Ductwork	
Instance on 1st Floor	Does not Exist
Hood Exhaust Fan	
Instance on 1st Floor	Does not Exist
Hood Fire Suppression System	
Instance on 1st Floor	Does not Exist
Hot Water Temperature Booster	
Instance on 1st Floor	Does not Exist
Kitchen Sink	
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
MDF Room	
Instance on Room 124A	Inspected
Dedicated A/C Equipment	
Instance on Room 124A	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	
SCIENCE LAB	
SCIENCE PREP ROOM	
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Dry Sprinkler Alarm Valve Assembly	
Wet Sprinkler Alarm Valve Assembly	
Fire Booster Pump Assembly	

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q378

Question	Response
SPRINKLERS, STANDPIPE, FIRE SYSTEM	
Roof Tank	Does not Exist
Siamese Connection	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Sprinkler Head	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Sprinkler Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Standpipe System	Does not Exist
Water Gong	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Partial
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	Yes
Are there chain operated dampers?	No
Condition	1 - Good
Deficiency	No deficiencies recorded
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist