

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q409

Asset: **PRE-K CENTER @ 14-45 143RD STREET - QUEENS, 14-45 143RD STREET, New York, 11357**

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q409	Mechanical	2023-12-05 9:08 AM	2023-12-15 4:27 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	0
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Exhaust Fans, Metal Ductwork, Unit Heater/Cabinet Heaters, Non-Auditorium Handicap Lift Vertical; DX Split Systems
	Years: 2022

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Inspected
Dumbwaiter	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q409

Question	Response
CONVEYING	
Elevator	Does not Exist
Escalator	Does not Exist
Non-auditorium Handicap Lift - Vertical	Inspected
Are all the existing non-auditorium vertical handicap lifts operable?	No
Condition	1 - Good
Deficiency	No deficiencies recorded
Non-auditorium Handicap Lift - Stair	Does not Exist
Ash Hoist	Does not Exist
Sidewalk Elevator	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Does not Exist
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Does not Exist
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Does not Exist
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q409

Question	Response
FIXTURES	
Student	
Drinking Fountain	Inspected
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Does not Exist
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Does not Exist
HEATING	Inspected
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Does not Exist
MER Steam and Condensate Piping	Does not Exist
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Does not Exist
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
HEATING PLANT	Does not Exist
Enclosed IDF Room	Does not Exist
KITCHEN	Inspected
Instance on 1st Floor	Inspected
Instance on 2nd Floor	Inspected
Instance Quantity Uom	EACH
CO Detector	Not Required
Instance on 2nd Floor	Not Required
Instance on 1st Floor	Not Required

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q409

Question	Response
KITCHEN	
Gas System	Does not Exist
Instance on 2nd Floor	Does not Exist
Instance on 1st Floor	Does not Exist
Grease Trap	Inspected
Instance on 2nd Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Instance on 1st Floor	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood	Does not Exist
Instance on 2nd Floor	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Exhaust Ductwork	Does not Exist
Instance on 2nd Floor	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on 2nd Floor	Does not Exist
Instance on 1st Floor	Does not Exist
Hood Fire Suppression System	Does not Exist
Instance on 2nd Floor	Does not Exist
Instance on 1st Floor	Does not Exist
Hot Water Temperature Booster	Does not Exist
Instance on 2nd Floor	Does not Exist
Instance on 1st Floor	Does not Exist
Kitchen Sink	Inspected
Instance on 2nd Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Instance on 1st Floor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room 211	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 211	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	1 - Good

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q409

Question	Response
VENTILATION	
Exhaust Fan	Inspected
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	1 - Good
Deficiency	No deficiencies recorded
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist