

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

**Q416**

**Asset:** CARDOZO AF - QUEENS, 57-00 223 STREET, New York, 11364

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q416	Electrical	2023-11-20 8:09 AM	2023-12-07 6:07 PM

**Asset Data**

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	No
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Athletic Field (Exterior Lighting, Scoreboard), Emergency Lighting (Battery Pack), Exit/Emergency Light
	Years: 2019
	Systems: Molded Case Circuit Breaker Type Panel Board
	Years: 2002, 2019
	Systems: Surface Fluorescent Lighting
	Years: 2002

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

**Priority Condition**

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

**Inspection**

Question	Response
<b>Electrical</b>	
<b>ATHLETIC FIELD</b>	Inspected
<b>Exterior Lighting</b>	Inspected
Replacement Uom	EACH
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Local Sound System</b>	Does not Exist
<b>Scoreboard</b>	Inspected
Instance	Football Field - Facing Springfield Boulevard
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	West Side of Softball Field
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Inspected
<b>Lighting</b>	Inspected
Does a Chandelier exist?	No
<b>Lighting Fixture - Fluorescent</b>	Inspected
<b>Pendant Mounted</b>	Does not Exist
<b>Surface Mounted</b>	Inspected

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

**Q416**

<b>Question</b>	<b>Response</b>
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	
<b>Lighting</b>	
<b>Lighting Fixture - Fluorescent</b>	
<b>Surface Mounted</b>	
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Recessed Mounted</b>	Does not Exist
<b>Lighting Fixture - HID</b>	Does not Exist
<b>Lighting Fixture - Incandescent</b>	Does not Exist
<b>Lighting Fixture - LED</b>	Does not Exist
<b>LOCKER ROOM</b>	Does not Exist
<b>TOILET ROOM - STAFF</b>	Does not Exist
<b>TOILET ROOM - STUDENT</b>	Does not Exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Does not Exist
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not Exist
<b>EMERGENCY GENERATOR SET</b>	Does not Exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Does not Exist
<b>EMERGENCY LIGHTING</b>	Inspected
<b>Battery Pack</b>	Inspected
Condition	1 - Good
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Exterior Wall facing Football Field
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
<b>Non Battery Pack</b>	Does not Exist
<b>EXIT LIGHT</b>	Does not Exist
<b>EXIT/EMERGENCY LIGHT</b>	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
<b>FIRE ALARM SYSTEM</b>	Does not Exist
<b>GROUNDING SYSTEM</b>	Does not Exist
<b>LAN</b>	Does not Exist
<b>LIGHTNING PROTECTION</b>	Does not Exist
<b>MOTOR CONTROLLER</b>	Inspected
<b>Motor Control Center</b>	Does not Exist
<b>Motor Starter/Contactor</b>	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
<b>Variable Frequency Drive</b>	Does not Exist
<b>PANEL BOARD</b>	Inspected
<b>Fused Disconnect Switch Type</b>	Does not Exist
<b>Fused Knife Switch Type</b>	Does not Exist
<b>Fused Toggle Switch Type</b>	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q416

<b>Question</b>	<b>Response</b>
<b>PANEL BOARD</b>	Inspected
<b>Molded Case Circuit Breaker Type</b>	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>PUBLIC ADDRESS SYSTEM</b>	Does not Exist
<b>SECURITY</b>	Does not Exist
<b>SERVICE SWITCH</b>	Does not Exist
<b>SWITCHBOARD</b>	Does not Exist
<b>TELEPHONE SYSTEM</b>	Does not Exist
<b>TRANSFORMER</b>	Does not Exist