

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

**Q421**

**Asset: SPRINGFIELD GDNS AF - QUEENS, 143-10 SPRINGFIELD BLVD, New York, 11413**

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q421	Electrical	2024-04-15 8:10 AM	2024-04-24 11:18 AM

**Asset Data**

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	No
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Athletic Field (Exterior Lighting, Scoreboard)
	Years: 2018

**DEDICATED INTERCOMS IN FIRE RESCUE AREAS**

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

**Priority Condition**

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

**Inspection**

Question	Response
<b>Electrical</b>	
<b>ATHLETIC FIELD</b>	Inspected
<b>Exterior Lighting</b>	Inspected
Replacement Uom	EACH
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
<b>Local Sound System</b>	Does not Exist
<b>Scoreboard</b>	Inspected
Instance	South side of Baseball Field
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Instance	South side of Football Field
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
<b>CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE</b>	Does not Exist
<b>LOCKER ROOM</b>	Does not Exist
<b>TOILET ROOM - STAFF</b>	Does not Exist
<b>TOILET ROOM - STUDENT</b>	Does not Exist
<b>AUXILIARY SIGNAL/BELL SYSTEM</b>	Does not Exist
<b>EMERGENCY DC STANDBY BATTERY POWER</b>	Does not Exist
<b>EMERGENCY GENERATOR SET</b>	Does not Exist
<b>EMERGENCY LIGHT/EXIT LIGHT PANEL</b>	Does not Exist
<b>EMERGENCY LIGHTING</b>	Does not Exist
<b>EXIT LIGHT</b>	Does not Exist

**NYC Department of Education**  
**Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q421

<b>Question</b>	<b>Response</b>
<b>EXIT/EMERGENCY LIGHT</b>	Does not Exist
<b>FIRE ALARM SYSTEM</b>	Does not Exist
<b>GROUNDING SYSTEM</b>	Does not Exist
<b>LAN</b>	Does not Exist
<b>LIGHTNING PROTECTION</b>	Does not Exist
<b>MOTOR CONTROLLER</b>	Does not Exist
<b>PANEL BOARD</b>	Does not Exist
<b>PUBLIC ADDRESS SYSTEM</b>	Does not Exist
<b>SECURITY</b>	Does not Exist
<b>SERVICE SWITCH</b>	Does not Exist
<b>SWITCHBOARD</b>	Does not Exist
<b>TELEPHONE SYSTEM</b>	Does not Exist
<b>TRANSFORMER</b>	Does not Exist