

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q503

Asset: 3K CENTER @ 47-09 36TH STREET - QUEENS, 47-09 36TH STREET, 11101

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q503	Electrical	2024-05-06 8:53 AM	2024-05-23 12:50 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: All Electrical Systems and Components
	Years: 2024

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	Yes
Are dedicated intercoms available in all of these spaces for use during a fire?	Yes
Are all dedicated intercoms operational?	Yes

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Electrical	
AUDITORIUM	Does not Exist
CAFETERIA	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Does not Exist
GYMNASIUM	Does not Exist
KITCHEN	Inspected
Instance on Basement	Inspected
Lighting	Inspected
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q503

Question	Response
KITCHEN	
Lighting	
Lighting Fixture - Fluorescent	
Instance on Basement	Does not Exist
Lighting Fixture - HID	
Instance on Basement	Does not Exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not Exist
Lighting Fixture - LED	
Instance on Basement	Inspected
Pendant Mounted	Does not Exist
Instance on Basement	Does not Exist
Surface Mounted	Does not Exist
Instance on Basement	Does not Exist
Recessed Mounted	Inspected
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
LIBRARY	Does not Exist
LOCKER ROOM	Does not Exist
MULTIPURPOSE ROOM	Inspected
Instance on Rooms C01, C03	Inspected
Lighting	Inspected
Instance on Rooms C01, C03	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms C01, C03	Does not Exist
Lighting Fixture - HID	
Instance on Rooms C01, C03	Does not Exist
Lighting Fixture - Incandescent	
Instance on Rooms C01, C03	Does not Exist
Lighting Fixture - LED	
Instance on Rooms C01, C03	Inspected
Pendant Mounted	Does not Exist
Instance on Rooms C01, C03	Does not Exist
Surface Mounted	Does not Exist
Instance on Rooms C01, C03	Does not Exist
Recessed Mounted	Inspected
Instance on Rooms C01, C03	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Local Sound System	Does not Exist
Instance on Rooms C01, C03	Does not Exist
Projection System	Does not Exist
Instance on Rooms C01, C03	Does not Exist
Theater Lighting System	Does not Exist
Instance on Rooms C01, C03	Does not Exist
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q503

Question	Response
SWIMMING POOL	Does not Exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Does not Exist
Recessed Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Does not Exist
Recessed Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Replacement Quantity	30,000
Replacement Uom	S.F.
Condition	1 - Good
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Non Battery Pack	Does not Exist
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Non Battery Pack	Does not Exist
EXIT/EMERGENCY LIGHT	Does not Exist
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	30,000
Replacement Uom	S.F.
Bell/Horn	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q503

Question	Response
FIRE ALARM SYSTEM	
Strobe	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
CO Detector	Does not Exist
Heat Detector	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Fused Cutout Panel	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not Exist
Main Panel	Inspected
Bell At Panel	Does not Exist
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Mircom
Equipment	Fire Alarm Control Panel
Model	FleX-Net
Installation Year	2024
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not Exist
Sub-Panel	Does not Exist
Remote Annunciator	Inspected
Display Monitor	Does not Exist
Panel	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q503

Question	Response
FIRE ALARM SYSTEM	
Remote Annunciator	
Printer	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Punch Register	Does not Exist
Sprinkler Flow/Air Pressure Switch	
Condition	1 - Good
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	
Condition	1 - Good
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	1 - Good
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	
Elevator	
Condition	1 - Good
Deficiency	No deficiencies recorded
Holding Area	
Does not Exist	
LAN	
Local Distribution Frame (LDF)	
Condition	1 - Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	
Condition	1 - Good
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	
Does not Exist	
MOTOR CONTROLLER	
Motor Control Center	
Does not Exist	
Motor Starter/Contactor	
Condition	1 - Good
Deficiency	No deficiencies recorded
Variable Frequency Drive	
Does not Exist	
PANEL BOARD	
Fused Disconnect Switch Type	
Does not Exist	
Fused Knife Switch Type	
Does not Exist	
Fused Toggle Switch Type	
Does not Exist	
Molded Case Circuit Breaker Type	
Condition	1 - Good
Deficiency	No deficiencies recorded
PUBLIC ADDRESS SYSTEM	
Replacement Quantity	30,000
Replacement Uom	S.F.
Instance	MDF Room 116
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Bogen Multicom - 2000

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q503

Question	Response
PUBLIC ADDRESS SYSTEM	Inspected
Installation Year	2024
Source of Installation	Documented
Deficiency	No deficiencies recorded
SECURITY	Inspected
IPDVS/CCTV System	Inspected
Replacement Quantity	30,000
Replacement Uom	S.F.
Installation Year	2024
Source of Installation	Documented
Condition	1 - Good
Deficiency	No deficiencies recorded
Intrusion Alarm System	Inspected
Replacement Quantity	30,000
Replacement Uom	S.F.
Central Control Panel	Inspected
Instance	Custodian's Office
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista-128BPT
Installation Year	2024
Source of Installation	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Lighting - Security	Does not Exist
SERVICE SWITCH	Inspected
Instance	Main Electric Dist. Room C05
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Electrotech
Equipment	Main Disconnect Switch
Capacity/Size Quantity	2,000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2024
Source of Installation	Documented

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q503

Question	Response
SERVICE SWITCH	
Deficiency	No deficiencies recorded
Instance	Main Electric Dist. Room C05
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Siemens
Equipment	Sprinkler Booster Pump Disconnect
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2024
Source of Installation	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	
Number of Spares	4
Fused Disconnect Switch Type	Inspected
Instance	Main Electric Dist. Room C05
Instance Condition	1 - Good
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Electrotech
Equipment	MSSB
Capacity/Size Quantity	2,000
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	2
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	2024
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Does not Exist
TELEPHONE SYSTEM	
PBX/Intercom	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
TRANSFORMER	Does not Exist