

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Asset: **YOUNG WOMENS' LEADERSHIP SCHOOL - QUEENS, 150-91 87 ROAD, New York, 11432**

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q680	Electrical	2024-02-15 7:30 AM	2024-02-26 12:12 PM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Cafeteria (Local Sound System)
	Years: 2024
	Systems: Fire Alarm System (Printer), LAN
	Years: 2021
	Systems: IPDVS/CCTV System
	Years: 2012
	Systems: Intrusion Alarm System
	Years: 2011
	Systems: Security Lights
	Years: 1998, 2020
	Systems: All Other Electrical Systems and Components
	Years: 1998

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
Yes	Water Leaks onto Electrical Equipment	N/A	lighting fixture, Electric cable box	Rooms (421A, 316), Stair A Bulkhead	Vidal Monroe	Fireman	Sent to DSF	
Yes	Fire Alarm System - Components Not Operational	N/A	FIRE ALARM SYSTEM Main Panel Bell At Panel	Main Entrance Lobby	Vidal Monroe	Fireman	Sent to DSF	
Yes	Fire Alarm System - Components Not Operational	Due to this defective smoke detector, the fire alarm system main panel was in trouble mode.	FIRE ALARM SYSTEM Area Smoke Detector	Room 316C	Vidal Monroe	Fireman	Sent to DSF	

Inspection

Question	Response
Electrical	
AUDITORIUM	Does not Exist
CAFETERIA	Inspected
Instance on 2nd Floor	Inspected
Lighting	Inspected
Instance on 2nd Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
CAFETERIA	
Lighting	
Lighting Fixture - Fluorescent	
Pendant Mounted	
Instance on 2nd Floor	Does not Exist
Surface Mounted	Does not Exist
Instance on 2nd Floor	Does not Exist
Recessed Mounted	Inspected
Instance on 2nd Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 2nd Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 2nd Floor	Does not Exist
Lighting Fixture - LED	
Instance on 2nd Floor	Does not Exist
Local Sound System	Inspected
Instance on 2nd Floor	Inspected
Installation Year	2024
Source of Installation	Documented
Condition	1 - Good
Deficiency	No deficiencies recorded
Projection System	Does not Exist
Instance on 2nd Floor	Does not Exist
Theater Lighting System	Does not Exist
Instance on 2nd Floor	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
COMPUTER LAB	Does not Exist
GYMNASIUM	Inspected
Instance on Basement	Inspected
Lighting	Inspected
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not Exist
Surface Mounted	
Instance on Basement	Does not Exist
Recessed Mounted	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Basement	Does not Exist
Recessed Mounted	
Instance on Basement	Does not Exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not Exist
Lighting Fixture - LED	
Instance on Basement	Does not Exist
Local Sound System	
Instance on Basement	Inspected
Installation Year	1998
Source of Installation	Documented
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Basement	Does not Exist
Scoreboard	
Instance on Basement	Does not Exist
Theater Lighting System	
Instance on Basement	Does not Exist
KITCHEN	
Instance on 2nd Floor	Inspected
Lighting	
Instance on 2nd Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 2nd Floor	Inspected
Pendant Mounted	
Instance on 2nd Floor	Does not Exist
Surface Mounted	
Instance on 2nd Floor	Does not Exist
Recessed Mounted	
Instance on 2nd Floor	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
KITCHEN	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	
Instance on 2nd Floor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on 2nd Floor	Does not Exist
Lighting Fixture - Incandescent	
Instance on 2nd Floor	Does not Exist
Lighting Fixture - LED	
Instance on 2nd Floor	Does not Exist
LIBRARY	Does not Exist
LOCKER ROOM	Inspected
Instance on 1st Floor - Boys	Inaccessible
Instance on 1st Floor - Girls	Inspected
Alternative use	Yes
Lighting	Inspected
Instance on 1st Floor - Girls	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor - Girls	Inspected
Pendant Mounted	Inspected
Instance on 1st Floor - Girls	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Surface Mounted	Inspected
Instance on 1st Floor - Girls	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Instance on 1st Floor - Girls	Does not Exist
Lighting Fixture - HID	
Instance on 1st Floor - Girls	Does not Exist
Lighting Fixture - Incandescent	
Instance on 1st Floor - Girls	Does not Exist
Lighting Fixture - LED	
Instance on 1st Floor - Girls	Does not Exist
MULTIPURPOSE ROOM	Does not Exist
SCIENCE DEMO ROOM	Inspected
Instance on Rooms 424, 426	Inspected
Power Panel	No
Alternative use	No
Lighting	Inspected
Instance on Rooms 424, 426	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 424, 426	Inspected
Pendant Mounted	Does not Exist
Instance on Rooms 424, 426	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2023 - 2024**

Electrical Inspection

Q680

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	Inspected
Instance on Rooms 424, 426	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Instance on Rooms 424, 426	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Rooms 424, 426	Does not Exist
Lighting Fixture - Incandescent	
Instance on Rooms 424, 426	Does not Exist
Lighting Fixture - LED	
Instance on Rooms 424, 426	Does not Exist
Emergency Gas Shut-Off Valve	Inspected
Instance on Rooms 424, 426	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	Inspected
Instance on Rooms 424, 426	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Power Supply	Inspected
Instance on Rooms 424, 426	Inspected
Instructor Unit	
Instance on Rooms 424, 426	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Rooms 424, 426	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	Does not Exist
Instance on Rooms 424, 426	Does not Exist
SCIENCE LAB	Inspected
Instance on Rooms 318, 322	Inspected
Power Panel	Yes
Alternative use	No
Lighting	Inspected
Instance on Rooms 318, 322	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms 318, 322	Inspected
Pendant Mounted	Does not Exist
Instance on Rooms 318, 322	Does not Exist
Surface Mounted	Inspected
Instance on Rooms 318, 322	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	Inspected
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Instance on Rooms 318, 322	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Rooms 318, 322	Does not Exist
Lighting Fixture - Incandescent	
Instance on Rooms 318, 322	Does not Exist
Lighting Fixture - LED	
Instance on Rooms 318, 322	Does not Exist
Emergency Gas Shut-Off Valve	Inspected
Instance on Rooms 318, 322	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	Inspected
Instance on Rooms 318, 322	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Power Supply	Inspected
Instance on Rooms 318, 322	Inspected
Instructor Unit	
Instance on Rooms 318, 322	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Rooms 318, 322	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Rooms 318, 322	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Projection System	Does not Exist
Instance on Rooms 318, 322	Does not Exist
SCIENCE PREP ROOM	Inspected
Instance on Room 320	Inspected
Power Panel	Yes
Alternative use	No
Lighting	Inspected
Instance on Room 320	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 320	Inspected
Pendant Mounted	Does not Exist
Instance on Room 320	Does not Exist
Surface Mounted	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
SCIENCE PREP ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	Does not Exist
Instance on Room 320	Does not Exist
Recessed Mounted	Inspected
Instance on Room 320	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 320	Does not Exist
Lighting Fixture - Incandescent	
Instance on Room 320	Does not Exist
Lighting Fixture - LED	
Instance on Room 320	Does not Exist
Emergency Gas Shut-Off Valve	Inspected
Instance on Room 320	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	Inspected
Instance on Room 320	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Power Supply	Does not Exist
Instance on Room 320	Does not Exist
SWIMMING POOL	Does not Exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Does not Exist
Recessed Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Does not Exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
TOILET ROOM - STUDENT	Inspected
Lighting	
Lighting Fixture - LED	Does not Exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Replacement Quantity	55,000
Replacement Uom	S.F.
Condition	3 - Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Inspected
Automatic Transfer Switch (ATS)	Inspected
Instance	Electrical Room 122A
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Detroit Diesel Spectrum
Equipment	ATS-1
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room 122A
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Detroit Diesel Spectrum
Equipment	ATS-2
Capacity/Size Quantity	70
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Sprinkler Room B14A
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Master Control Systems
Equipment	Fire Pump Automatic Transfer Switch
Capacity/Size Quantity	20
Capacity/Size UOM	HP
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
Battery Charger	Inspected
Instance	Penthouse

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
EMERGENCY GENERATOR SET	
Battery Charger	
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Detroit Diesel Spectrum
Equipment	Battery Charger
Capacity/Size Quantity	10
Capacity/Size UOM	AmpsDC
Capacity/Size2 Quantity	26
Capacity/Size2 UOM	VDC
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
Emergency Distribution Board	Inspected
Number of Spares	4
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room 122A
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Challenger
Equipment	EDP
Capacity/Size Quantity	800
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	1
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
Molded Case Circuit Breaker Type	Does not Exist
Diesel	Inspected
Instance	Electrical Room 122A
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Detroit Diesel Spectrum
Equipment	Emergency Generator
Capacity/Size Quantity	288
Capacity/Size UOM	KVA
Capacity/Size2 Quantity	230
Capacity/Size2 UOM	KW
Capacity/Size3Quantity	798
Capacity/Size3 UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Documented

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
EMERGENCY GENERATOR SET	Inspected
Diesel	Inspected
Deficiency	No deficiencies recorded
Natural Gas	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Does not Exist
Non Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Does not Exist
Non Battery Pack	Inspected
Condition	3 - Fair
Deficiency	FIXTURE NOT OPERATIONAL
Deficiency Location/Instance	Corridor by Room B14
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 4
Deficiency Photo1	No photo recorded
Violations	35671748P
EXIT/EMERGENCY LIGHT	Does not Exist
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	55,000
Replacement Uom	S.F.
Bell/Horn	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Strobe	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Manual Pull Station	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Duct Smoke Detector	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Area Smoke Detector	Inspected
Condition	3 - Fair
Deficiency	DETECTOR NOT OPERATIONAL
Deficiency Location/Instance	Room 316C
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
FIRE ALARM SYSTEM	
Area Smoke Detector	Inspected
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
CO Detector	Does not Exist
Heat Detector	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Elevator Recall	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Magnetic Door Holder/Contactor	Does not Exist
Fused Cutout Panel	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Inspected
Instance	Sprinkler Room B14A
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Silent Knight
Equipment	N/A
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
Main Panel	Inspected
Bell At Panel	Inspected
Condition	4 - Between Fair and Poor
Deficiency	BELL NOT OPERATIONAL
Deficiency Location/Instance	Main Entrance Lobby
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Edwards System Technology
Equipment	Fire Alarm Control Panel
Model	EST
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
FIRE ALARM SYSTEM	
Main Panel	Inspected
Fire Alarm Control Panel (Standard)	Does not Exist
Sub-Panel	Does not Exist
Remote Annunciator	Inspected
Display Monitor	Inspected
Condition	4 - Between Fair and Poor
Deficiency	MONITOR MISSING
Deficiency Location/Instance	General Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL MONITOR
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Panel	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Punch Register	Does not Exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	3 - Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	
Condition	Inspected
Elevator	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Holding Area	Does not Exist
LAN	
Condition	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	
Condition	Does not Exist
MOTOR CONTROLLER	
Condition	Inspected
Motor Control Center	Does not Exist
Motor Starter/Contactor	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
MOTOR CONTROLLER	
Motor Starter/Contactor	Inspected
Deficiency	No deficiencies recorded
Variable Frequency Drive	Inspected
Condition	4 - Between Fair and Poor
Deficiency	VARIABLE FREQUENCY DRIVE NOT OPERATIONAL
Deficiency Location/Instance	Boiler Room (VFS Pump 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not Exist
Fused Toggle Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Inspected
Condition	3 - Fair
Deficiency	NO SPARE
Deficiency Location/Instance	Corridor by Rooms 213, 411
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	55,000
Replacement Uom	S.F.
Instance	General Office
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Rauland Telecenter
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
SECURITY	Inspected
IPDVS/CCTV System	Inspected
Replacement Quantity	55,000
Replacement Uom	S.F.
Installation Year	2012
Source of Installation	Inspector Estimate
Condition	2 - Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
SECURITY	
IPDVS/CCTV System	
Deficiency	MONITOR NOT OPERATIONAL
Deficiency Location/Instance	Main Entrance Lobby
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Intrusion Alarm System	
	Inspected
Replacement Quantity	55,000
Replacement Uom	S.F.
Central Control Panel	
	Inspected
Instance	Custodian's Office
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista-128BP
Installation Year	2011
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
Infrared Sensor	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Panic Switch	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting - Security	
	Inaccessible
SERVICE SWITCH	
	Inspected
Instance	Electrical Room 122A
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Challenger
Equipment	SSW-1 3000AMP
Capacity/Size Quantity	3,000
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
SERVICE SWITCH	
Instance	Electrical Room 122A
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Challenger
Equipment	SSW-2 600AMP
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room 122A
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Eaton
Equipment	FPSW-1
Capacity/Size Quantity	600
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1988
Source of Installation	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	Inspected
Number of Spares	3
Fused Disconnect Switch Type	Inspected
Instance	Electrical Room 122A
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Challenger
Equipment	MDB Section 1, 2
Capacity/Size Quantity	3,000
Capacity/Size UOM	Amps Total
Capacity/Size2 Quantity	2
Capacity/Size2 UOM	Section(S)
Source of Capacity/Size	Service Switch Size
Installation Year	1998
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fused Knife Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Does not Exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standard	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q680

Question	Response
TELEPHONE SYSTEM	Inspected
Standard	
Condition	3 - Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not Exist