

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q777

Asset: P.S. 199 ANNEX (@ ST. TERESA'S) - QUEENS, 50-15 44TH STREET, New York, 11377

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q777	Mechanical	2024-02-22 11:02 AM	2024-03-05 4:47 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: DX Split System for Kitchen Storage Room B04; Gas Meter Room Vent
	Years: 2018
	Systems: MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2017

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q777

Question	Response
CLIMATE CONTROL SYSTEM	
Hybrid System	Does not Exist
Electric System	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Water Meter Room B07
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Water Meter Room B07
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Heat Pump Domestic Water Heater	Does not Exist
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	2 - Between Good and Fair
Instance Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q777

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Hot Water System	
Gas Fired Domestic Water Heater	
Instance Quantity Uom	EACH
Instance Manufacturer	A.O. Smith
Equipment	N/A
Capacity/Size Quantity	75
Capacity/Size UOM	MBH Input
Capacity/Size2 Quantity	74
Capacity/Size2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2015
Source of Installation	Documented
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Does not Exist
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Men's Toilet Room M200
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Urinal	Does not Exist
Student	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q777

Question	Response
FIXTURES	
Student	
Drinking Fountain	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not Exist
Gas Meter Room Vent	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Pressure Booster	Does not Exist
CO/Gas Leak Detection	Does not Exist
HEATING	
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Does not Exist
MER Steam and Condensate Piping	Does not Exist
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Does not Exist
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q777

Question	Response
HEATING	Inspected
Unit Heater/Cabinet Heater	Does not Exist
HEATING PLANT	Inspected
Replacement Quantity	1,904
Replacement Uom	MBH Net
Instance on Sub-Basement	Inspected
Burner Type	Gas
Heating Plant Oil Number	N/A
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Power Flame
Burner Model Number	WCR2-G-20B
Boiler Auxiliaries	Inspected
Instance on Sub-Basement	Inspected
Boiler Auxiliary Piping	
Instance on Sub-Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Sub-Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Sub-Basement	Does not Exist
Boiler Feedwater Treatment(Automatic)	
Instance on Sub-Basement	Does not Exist
Boiler Flue Exhaust	
Instance on Sub-Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Sub-Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Boiler Safety Valve	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler System	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q777

Question	Response
HEATING PLANT	Inspected
Boiler System	
Instance on Sub-Basement	Inspected
Coal-fired Boiler	
Instance on Sub-Basement	Does not Exist
Hot Water Boiler	
Instance on Sub-Basement	Does not Exist
Modular Boiler	
Instance on Sub-Basement	Does not Exist
Steam Boiler	
Instance on Sub-Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1,904
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	Yes
Instance Manufacturer	Weil-McLain
Equipment	102021-03
Capacity/Size Quantity	1,904
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	2006
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fuel System	Inspected
Instance on Sub-Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Fixed Louver
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Sub-Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Sub-Basement	Does not Exist
Gas Trains And Vent At The Boiler	
Instance on Sub-Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Enclosed IDF Room	Does not Exist
KITCHEN	Inspected
Instance on Basement	Inspected
CO Detector	Not Required
Instance on Basement	Not Required
Gas System	Does not Exist
Instance on Basement	Does not Exist
Grease Trap	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q777

Question	Response
KITCHEN	
Grease Trap	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Does not Exist
Instance on Basement	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Basement	Does not Exist
Hood Fire Suppression System	Does not Exist
Instance on Basement	Does not Exist
Hot Water Temperature Booster	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Kitchen Sink	Inspected
Instance on Basement	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
MDF Room	Inspected
Instance on Room 105	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 105	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Inspected
Instance on Room 306	Inspected
Alternative use	Yes
Acid Waste Neutralizing Tank	Does not Exist
Instance on Room 306	Does not Exist
CO Detector	Not Required
Instance on Room 306	Not Required
Emergency Shower	Does not Exist
Instance on Room 306	Does not Exist
Eye Wash	Inspected
Instance on Room 306	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Does not Exist
Instance on Room 306	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Room 306	Does not Exist
Fixed Laboratory Hood	Does not Exist
Instance on Room 306	Does not Exist
Laboratory Sink	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q777

Question	Response
SCIENCE LAB	
Laboratory Sink	Inspected
Instance on Room 306	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 306	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	No
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist