

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q792

Asset: NORTH QUEENS COMMUNITY HS - Q, 141-25 77TH ROAD, New York, 11367

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q792	Mechanical	2023-11-09 12:12 PM	2023-11-14 9:42 AM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	0
Total capacity of all above ground tanks in gal.	0
Total # of below ground tanks	1
Total capacity of all below ground tanks in gal.	2,000
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	Steam Condensate Return Pumping System Room inside Multipurpose Room
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Fixtures - Student: Urinals
	Years: 2023
	Systems: Electric Domestic Water Heater; Exhaust Fans
	Years: 2022
	Systems: MDF Room - Dedicated A/C Equipment (DX Split System, 1 of 2)
	Years: 2017

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Does not Exist
Hybrid System	Does not Exist
Electric System	Inspected
Instance	Throughout
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q792

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	Inspected
Instance	Basement Crawlspace
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement Crawlspace
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Does not Exist
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3 - Fair

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q792

Question	Response
FIXTURES	
Staff And Other	Inspected
Toilet	Inspected
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Does not Exist
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Does not Exist
HEATING	Inspected
Heating Coil In Ductwork	Does not Exist
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Does not Exist
Steam Condensate Return Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Steam Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Does not Exist
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Does not Exist
HEATING PLANT	Inspected
Replacement Quantity	1,612
Replacement Uom	MBH Net
Instance on Basement	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q792

Question	Response
HEATING PLANT	
Burner Type	Oil
Heating Plant Oil Number	2
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Carlin
Burner Model Number	800 CRD
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Does not Exist
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Does not Exist
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DEFECTIVE RPZ
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo	No photo recorded
Violations	No violations recorded.
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Does not Exist

**NYC Department of Education
Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q792

Question	Response
HEATING PLANT	
Boiler System	
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1,612
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	H. B. Smith Co., Inc.
Equipment	93731-1
Capacity/Size Quantity	1,612
Capacity/Size UOM	MBH Net
Source of Capacity/Size	Documented
Installation Year	1980
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist?	Yes
Type	Automatic
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not Exist
Enclosed IDF Room	Does not Exist
KITCHEN	Does not Exist
MDF Room	Inspected
Instance on Room 210	Inspected
Dedicated A/C Equipment	
Instance on Room 210	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Inspected
Instance on Room 202	Inspected
Alternative use	No
Acid Waste Neutralizing Tank	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q792

Question	Response
SCIENCE LAB	
Acid Waste Neutralizing Tank	Inspected
Instance on Room 202	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
CO Detector	Not Required
Instance on Room 202	Not Required
Emergency Shower	Does not Exist
Instance on Room 202	Does not Exist
Eye Wash	Inspected
Instance on Room 202	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	Does not Exist
Instance on Room 202	Does not Exist
Hood Exhaust Fan	Does not Exist
Instance on Room 202	Does not Exist
Fixed Laboratory Hood	Does not Exist
Instance on Room 202	Does not Exist
Laboratory Sink	Inspected
Instance on Room 202	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Make-up Air Unit	Does not Exist
Instance on Room 202	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	1 - Good
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	No deficiencies recorded
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist