

**NYC Department of Education
Building Condition Assessment Survey 2023 - 2024**

Mechanical Inspection

Q797

Asset: PS 150 ANNEX - QUEENS, 41-12 44TH STREET, New York, 11104

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q797	Mechanical	2023-11-14 12:50 PM	2023-11-21 3:12 PM

Asset Data

Question	Answer
Are there fuel tanks?	Yes
Total # of above ground tanks	0
Total capacity of all above ground tanks in gal.	0
Total # of below ground tanks	1
Total capacity of all below ground tanks in gal.	7,500
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	None
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Sewage Ejector Pumps
	Years: 2022
	Systems: Boiler Safety Valve (1 of 2)
	Years: 2021
	Systems: Electric Domestic Water Heaters; Boiler Safety Valve (1 of 2)
	Years: 2019
	Systems: MDF Room - Dedicated A/C Equipment (DX Split System)
	Years: 2018
	Systems: CO/Gas Leak Detection
	Years: 2017

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not Exist
Pneumatic System	Does not Exist
Hybrid System	Does not Exist
Electric System	Inspected
Instance	Throughout (2 Zones)
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	No deficiencies recorded
COMPACTOR	Does not Exist
CONVEYING	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q797

Question	Response
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	Room B3
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	No deficiencies recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Sump Pump	Does not Exist
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	4 - Between Fair and Poor
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Toilet Room 200H
Deficiency Quantity	1
Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q797

Question	Response
FIXTURES	
Staff And Other	
Toilet	
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Urinal	
	Does not Exist
Student	
	Inspected
Drinking Fountain	
	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Locker Room Shower	
	Does not Exist
Sink And Fountain Combo Unit	
	Does not Exist
Toilet	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	
	Does not Exist
GAS SERVICE	
	Inspected
Gas Distribution Piping	
	Does not Exist
Gas Meter Room Exhaust Fan	
	Does not Exist
Gas Meter Room Vent	
	Does not Exist
Gas Pressure Booster	
	Does not Exist
CO/Gas Leak Detection	
	Inspected
Instance	Boiler Room (CO Detection)
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Installation Year	2017
Source of Installation	Inspector Estimate
Deficiency	No deficiencies recorded
HEATING	
	Inspected
Heating Coil In Ductwork	
	Does not Exist
Hydronic Heating	
	Inspected
Hydronic Hot Water Distribution: Piping, Pumps and Auxiliaries	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Backflow Preventer	
	Does not Exist
Hot Water Heat Exchanger	
	Does not Exist
Radiator/Convactor/Fin Tube	
	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q797

Question	Response
HEATING	Inspected
Steam Heating	Does not Exist
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Does not Exist
HEATING PLANT	Inspected
Replacement Quantity	3,548
Replacement Uom	MBH Net
Instance on Basement	Inspected
Burner Type	Oil
Heating Plant Oil Number	2
Is there a water meter on the boiler make-up water piping?	No
Burner Exists?	Yes
Burner Manufacturer	Carlin
Burner Model Number	801CRD
Boiler Auxiliaries	Inspected
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Does not Exist
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Does not Exist
Boiler Flue Exhaust	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Boiler Room Steam And Condensate Piping	
Instance on Basement	Does not Exist
Boiler Safety Valve	
Instance on Basement	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Boiler System	Inspected
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not Exist
Hot Water Boiler	
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1,774

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q797

Question	Response
HEATING PLANT	Inspected
Boiler System	
Hot Water Boiler	
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Kewanee Boiler Corporation
Equipment	83258-01
Capacity/Size Quantity	2,040
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	1956
Source of Installation	Documented
Deficiency	No deficiencies recorded
Instance	Boiler Room
Instance Condition	3 - Fair
Instance Quantity	1,774
Instance Quantity Uom	MBH Net
Cast Iron Boiler?	No
Instance Manufacturer	Kewanee Boiler Corporation
Equipment	83258-02
Capacity/Size Quantity	2,040
Capacity/Size UOM	MBH Gross
Source of Capacity/Size	Documented
Installation Year	1956
Source of Installation	Documented
Deficiency	No deficiencies recorded
Modular Boiler	
Instance on Basement	Does not Exist
Steam Boiler	
Instance on Basement	Does not Exist
Fuel System	Inspected
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Do Boiler Combustion Air Louvers exist? Type	Yes Mechanical
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not Exist
Enclosed IDF Room	Does not Exist
KITCHEN	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q797

Question	Response
MDF Room	Inspected
Instance on Room 200A	Inspected
Dedicated A/C Equipment	Inspected
Instance on Room 200A	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	No
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No
Condition	3 - Fair
Deficiency	No deficiencies recorded
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist