

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q822

Asset: P.S. 811 MINISCHOOL (OLD 136 MN)-Q, 114-36 202ND STREET, New York, 11412

Inspection Id	Inspection Type	Time In	Last Edited
EE : Q822	Electrical	2023-11-14 7:55 AM	2023-12-11 10:03 AM

Asset Data

Question	Answer
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration in Electrical Room?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Fire Alarm System (Bell/Horn, Strobe, Fan Shutdown Control, Duct Smoke Detector, Area Smoke Detector)
	Years: Under construction
	Systems: Recessed LED Lighting, LAN, Security Lights
	Years: 2023
	Systems: Interior Lighting, Intrusion Alarm System (Central Control Panel, Infrared Sensor)
	Years: 2015
	Systems: Fire Alarm System
	Years: 2010
	Systems: Public Address System
	Years: 2006
	Systems: Partial Molded Case Circuit Breaker Type Panel Board
	Years: 1991

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
Yes	Fire Alarm System - Components Not Operational	Defective sprinkler flow switch is causing a trouble mode on the fire alarm main control panel.	FIRE ALARM SYSTEM Sprinkler Flow/Air Pressure Switch	Mechanical Room M-8	Joseph Barbieri	Fireman	Sent to DSF	

Inspection

Question	Response
Electrical	
AUDITORIUM	Does not Exist
CAFETERIA	Does not Exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	Inspected
Lighting	Inspected
Does a Chandelier exist?	No
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q822

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
COMPUTER LAB	Does not Exist
GYMNASIUM	Does not Exist
KITCHEN	Does not Exist
LIBRARY	Does not Exist
LOCKER ROOM	Does not Exist
MULTIPURPOSE ROOM	Does not Exist
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SWIMMING POOL	Does not Exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Does not Exist
Recessed Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not Exist
Lighting Fixture - HID	Does not Exist
Lighting Fixture - Incandescent	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q822

Question	Response
TOILET ROOM - STUDENT	
Lighting	
Lighting Fixture - LED	Inspected
Pendant Mounted	Does not Exist
Surface Mounted	Does not Exist
Recessed Mounted	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Replacement Quantity	9,000
Replacement Uom	S.F.
Condition	3 - Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not Exist
EMERGENCY GENERATOR SET	Does not Exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Does not Exist
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not Exist
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not Exist
EXIT/EMERGENCY LIGHT	Does not Exist
FIRE ALARM SYSTEM	Inspected
Replacement Quantity	9,000
Replacement Uom	S.F.
Bell/Horn	Under Construction
Strobe	Under Construction
Manual Pull Station	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Under Construction
Duct Smoke Detector	Under Construction
Area Smoke Detector	Under Construction
CO Detector	Does not Exist
Heat Detector	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Elevator Recall	Does not Exist
Magnetic Door Holder/Contactor	Does not Exist
Fused Cutout Panel	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q822

Question	Response
FIRE ALARM SYSTEM	
Main Panel	Inspected
Bell At Panel	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Inspected
Instance	Main Entrance Lobby
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	General Electric
Equipment	Fire Alarm Control Panel
Model	EST 2
Installation Year	2010
Source of Installation	Documented
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Standard)	Does not Exist
Sub-Panel	Does not Exist
Remote Annunciator	Inspected
Display Monitor	Does not Exist
Panel	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Printer	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Punch Register	Does not Exist
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	5 - Poor
Deficiency	SWITCH NOT OPERATIONAL
Deficiency Location/Instance	Mechanical Room M-8
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Tamper Flow Switch/Chain	Inspected
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	
Condition	3 - Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q822

Question	Response
LAN	Inspected
Main Equipment Rack (MDF)	Does not Exist
LIGHTNING PROTECTION	Does not Exist
MOTOR CONTROLLER	Inspected
Motor Control Center	Does not Exist
Motor Starter/Contactor	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Does not Exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Does not Exist
Fused Knife Switch Type	Does not Exist
Fused Toggle Switch Type	Does not Exist
Molded Case Circuit Breaker Type	Inspected
Condition	3 - Fair
Deficiency	NO SPARE
Deficiency Location/Instance	Mechanical Room M-8
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL NEW PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	NO SPARE
Deficiency Location/Instance	Mechanical Room M-8
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE PANEL BOARD
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
PUBLIC ADDRESS SYSTEM	Inspected
Replacement Quantity	9,000
Replacement Uom	S.F.
Instance	Room M-14
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	N/A
Installation Year	2006
Source of Installation	Documented
Deficiency	No deficiencies recorded
SECURITY	Inspected
IPDVS/CCTV System	Does not Exist
Intrusion Alarm System	Inspected
Replacement Quantity	9,000

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q822

Question	Response
SECURITY	
Intrusion Alarm System	
Replacement Uom	S.F.
Central Control Panel	
Instance	Mechanical Room M-8
Instance Condition	2 - Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista-128BPT
Installation Year	2015
Source of Installation	Custodial Staff
Deficiency	PANEL NOT CONNECTED TO DOE CENTRAL STATION
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REWIRE
Urgency of Action	PRIORITY 4
Purpose of Action	LEVEL 3
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Infrared Sensor	
Condition	2 - Between Good and Fair
Deficiency	No deficiencies recorded
Panic Switch	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Remote Annunciator	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Siren/Strobe	
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lighting - Security	
Replacement Uom	EACH
Condition	1 - Good
Deficiency	No deficiencies recorded
SERVICE SWITCH	
Instance	Mechanical Room M-8
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Instance Manufacturer	Westinghouse
Equipment	Main Sw
Capacity/Size Quantity	800
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1974
Source of Installation	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	
	Does not Exist

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Electrical Inspection

Q822

Question	Response
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not Exist