

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q836

Asset: P.S. 36 MINISCHOOL - QUEENS, 187-01 FOCH BLVD, New York, 11412

Inspection Id	Inspection Type	Time In	Last Edited
ME : Q836	Mechanical	2024-03-04 7:23 AM	2024-03-19 6:05 PM

Asset Data

Question	Answer
Are there fuel tanks?	No
Total # of water main service entries to the asset	1
MERs/Fan Rooms Locations	MER
Are there any spaces with Missing or Defective CO Detectors?	No
Are there any Emergency Stop Switches with Missing Hammers?	No
Are there any Painted/Obstructed Sprinkler Heads?	No
Have any Systems/Major Building Components been upgraded?	Yes
	Systems: Fixtures - Student: Toilets , Urinals, Lavatory/Sinks
	Years: 2022
	Systems: Electric Domestic Water Heater
	Years: 2019

Priority Condition

Priority Condition Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Status	PhotoImage
No condition recorded								

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not Exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not Exist
Cooling Coil in Ductwork	Does not Exist
Cooling Tower	Does not Exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Dry Cooler	Does not Exist
Packaged / Rooftop Unit	Does not Exist
Packaged Terminal A/C	Does not Exist
Refrigerant Leak Detection System	Does not Exist
Refrigerant Piping	Inspected
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q836

Question	Response
AIR CONDITIONING	
Refrigerant Piping	
Violations	No violations recorded.
Return Fan	Does not Exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not Exist
CLIMATE CONTROL SYSTEM	Does not Exist
COMPACTOR	Does not Exist
CONVEYING	Does not Exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not Exist
Pressure Booster System	Does not Exist
Water Service	Inspected
Instance	MER
Instance Condition	3 - Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Deficiency	WATER MAIN: MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	MER
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not Exist
Domestic Water Heat Exchanger	Does not Exist
Electric Domestic Water Heater	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Does not Exist
Heat Pump Domestic Water Heater	Does not Exist
Oil Fired Domestic Water Heater	Does not Exist
Domestic Water Distribution Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Does not Exist
Sewage/Waste/Vent Piping	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Sewage Ejector Pump	Does not Exist
Sump Pump	Does not Exist
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not Exist
FIXTURES	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q836

Question	Response
FIXTURES	
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Teacher Lounge M13
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Toilet	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Urinal	Does not Exist
Student	Inspected
Drinking Fountain	Inspected
Condition	3 - Fair
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Corridor adjacent to Room M12A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Lavatory/Sink	Inspected
Condition	1 - Good
Deficiency	DEFECTIVE AUXILIARY (FAUCET, SHUT OFF VALVE,ETC.)
Deficiency Location/Instance	Boys Toilet Room M9
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Locker Room Shower	Does not Exist
Sink And Fountain Combo Unit	Does not Exist
Toilet	Inspected
Condition	1 - Good
Deficiency	No deficiencies recorded
Urinal	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q836

Question	Response
FIXTURES	Inspected
Student	
Urinal	
Condition	1 - Good
Deficiency	No deficiencies recorded
GAS FIRED FURNACE	Does not Exist
GAS SERVICE	Does not Exist
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3 - Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not Exist
Radiator/Convactor/Fin Tube	Does not Exist
Steam Heating	Does not Exist
Steam supplied by External Sources	Does not Exist
Unit Heater/Cabinet Heater	Does not Exist
HEATING PLANT	Does not Exist
Enclosed IDF Room	Inspected
Instance on Custodial Closet M12A	Inspected
Dedicated A/C Equipment	Inspected
Instance on Custodial Closet M12A	Inspected
Condition	4 - Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Custodial Closet M12A
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
KITCHEN	Does not Exist
MDF Room	Does not Exist
SCIENCE DEMO ROOM	Does not Exist
SCIENCE LAB	Does not Exist
SCIENCE PREP ROOM	Does not Exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Does not Exist
SWIMMING POOL	Does not Exist
VENTILATION	Inspected
Is the building mechanically ventilated?	Yes
Exhaust Fan	Inspected
Approximate Total # of Fans	1-25
Condition	3 - Fair
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not Exist
Metal Ductwork	Inspected
Are there any uninsulated ductwork by design in Mechanical Rooms?	No
Are there chain operated dampers?	No

NYC Department of Education
Building Condition Assessment Survey 2023 - 2024

Mechanical Inspection

Q836

Question	Response
VENTILATION	
Metal Ductwork	
Condition	3 - Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Deficiency	DEFECTIVE DUCTWORK
Deficiency Location/Instance	MER
Deficiency Quantity	10
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Deficiency Photo1	No photo recorded
Violations	No violations recorded.
Supply Fan	Does not Exist
Unit Ventilator	Does not Exist